

INTERNATIONAL ELECTROTECHNICAL COMMISSION
COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE

IEC 61992-6
Edition 1.0 2006-02

**RAILWAY APPLICATIONS – FIXED
INSTALLATIONS – DC SWITCHGEAR –**

Part 6: DC switchgear assemblies

IEC 61992-6
Édition 1.0 2006-02

**APPLICATIONS FERROVIAIRES –
INSTALLATIONS FIXES – APPAREILLAGE A
COURANT CONTINU –**

**Partie 6: Ensembles d'appareillage à courant
continu**

CORRIGENDUM 1

8.3.8 Electrical operation test

Replace the ninth paragraph with the following new paragraph:

All switching devices shall have satisfactorily passed the test if they still work correctly and withstand a voltage test as per 8.3.3.3 but with a voltage having a r.m.s. a.c. value equal to

8.3.8 Essai de manœuvre électrique

Remplacer le neuvième alinéa par le nouvel alinéa suivant :

Tous les appareils de connexion doivent avoir passé l'essai avec satisfaction, s'ils continuent à fonctionner correctement et s'ils résistent à un essai de tension comme celui de 8.3.3.3 mais avec une tension alternative efficace égale à $U_{Ne} \times \sqrt{2}$.