

INTERNATIONAL STANDARD

COMMENTED VERSION

**Electrical insulating materials - Thermal endurance properties -
Part 1: Ageing procedures and evaluation of test results**

CONTENTS

FOREWORD	3
INTRODUCTION	5
1 Scope	6
2 Normative references	6
3 Terms, definitions, symbols and abbreviated terms	7
3.1 Terms and definitions	7
3.2 Symbols and abbreviated terms	9
4 Synopsis of procedures - Full procedures	10
5 Detailed experimental procedures	10
5.1 Selection of test procedures	10
5.1.1 General considerations	10
5.1.2 Selection of material	10
5.1.3 Selection of test properties for TI	11
5.1.4 Determination of TI for times other than 20 000 h	11
5.2 Selection of end-points	11
5.3 Preparation and number of test specimens	11
5.3.1 Preparation	11
5.3.2 Number of specimens	12
5.4 Establishment of initial property value	13
5.5 Exposure temperatures and times	13
5.6 Ageing ovens	14
5.7 Environmental conditions	14
5.7.1 General	14
5.7.2 Atmospheric conditions during ageing	14
5.7.3 Conditions for property measurement	14
5.8 Procedure for ageing	14
5.8.1 General	14
5.8.2 Procedure using a non-destructive test	15
5.8.3 Procedure using a proof test	15
5.8.4 Procedure using a destructive test	15
6 Evaluation	16
6.1 Numerical analysis of test data	16
6.2 Thermal endurance characteristics and formats	16
6.3 Times to end-point, x- and y-values	17
6.3.1 General	17
6.3.2 Non-destructive tests	18
6.3.3 Proof tests	18
6.3.4 Destructive tests	18
6.4 Means and variances	20
6.4.1 Complete data	20
6.4.2 Incomplete (censored) data	21
6.5 General means and variances and regression analysis	21
6.6 Thickness dependence	21
6.7 Statistical tests and data requirements	21
6.7.1 General	21
6.7.2 Data of all types	21

6.7.3	Proof tests	22
6.7.4	Destructive tests	23
6.8	Thermal endurance graph and thermal endurance characteristics	23
6.9	Test report	23
Annex A (informative)	Dispersion and non-linearity	27
A.1	Data dispersion	27
A.2	Non-linearity	27
A.2.1	Mechanisms of thermal degradation	27
A.2.2	Non-linearity of data groups	27
Annex B (informative)	Exposure temperatures and times	29
B.1	General	29
B.2	Temperatures	29
B.3	Times	29
B.3.1	Cyclic ageing	29
B.3.2	Continuous ageing	29
B.4	Delayed groups of specimens	30
Annex C (informative)	Concepts in earlier editions	27
C.1	Relative temperature index (RTI)	27
C.2	Thermal endurance profile (TEP)	27
	Bibliography	34
	List of comments	35
Figure 1	– Thermal endurance graph	16
Figure 2	– Property variation - Determination of time to end-point at each temperature (destructive tests and non-destructive tests)	18
Figure 3	– Estimation of times to end-point - Property value (ordinate, arbitrary units) versus time (abscissa, log scale, arbitrary units)	19
Figure 4	– Destructive tests - Estimation of time to end-point	20
Figure C.1	– Relative temperature index	27
Table 1	– Suggested exposure temperatures and times	25
Table B.1	– Groups	30

INTERNATIONAL ELECTROTECHNICAL COMMISSION

Electrical insulating materials - Thermal endurance properties - Part 1: Ageing procedures and evaluation of test results

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

This commented version (CMV) of the official standard IEC 60216-1:2025 edition 7.0 allows the user to identify the changes made to the previous IEC 60216-1:2013 edition 6.0. Furthermore, comments from IEC TC 112 experts are provided to explain the reasons of the most relevant changes, or to clarify any part of the content.

A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text. Experts' comments are identified by a blue-background number. Mouse over a number to display a pop-up note with the comment.

This publication contains the CMV and the official standard. The full list of comments is available at the end of the CMV.

IEC 60216-1 has been prepared by IEC technical committee 112: Evaluation and qualification of electrical insulating materials and systems. It is an International Standard.

This seventh edition cancels and replaces the sixth edition published in 2013. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) the definition for temperature index (TI) has been updated;
- b) requirements for selection of related materials used, e.g. in different colours (5.1.2), have been added;
- c) test procedure for thickness sensitivity (5.5 and 6.6) has been added;
- d) Annex C "Concepts in earlier editions" has been deleted.

The text of this International Standard is based on the following documents:

Draft	Report on voting
112/698/FDIS	112/706/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

A list of all parts in the [IEC 60216 series \[1\]](#), published under the general title *Electrical insulating materials – Thermal endurance properties*, can be found on the IEC website.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

INTRODUCTION

The listing of the thermal capabilities of electrical insulating materials, based on service experience, was found to be impractical, owing to the rapid development of polymer and insulation technologies and the long time necessary to acquire appropriate service experience. Accelerated ageing and test procedures were therefore ~~required~~ needed to obtain the necessary information. The IEC 60216 series [1] has been developed to formalize these procedures and the interpretation of their results.

Physico-chemical models postulated for the ageing processes led to the almost universal assumption of the Arrhenius equations to describe the rate of ageing. Out of this arose the concept of the temperature index (TI) as a single-point characteristic based upon accelerated ageing data. This is the numerical value of the temperature in degrees Celsius at which the time taken for deterioration of a selected property to reach an accepted end-point is that specified (usually 20 000 h).

NOTE The term Arrhenius is widely used (and understood) to indicate a linear relationship between the logarithm of a time and the reciprocal of the thermodynamic (absolute or kelvin) temperature. The correct usage is restricted to such a relationship between a reaction rate constant and the thermodynamic temperature. The common usage is employed throughout this document.

The large statistical scatter of test data which was found, together with the frequent occurrence of substantial deviations from the ideal behaviour, demonstrated the need for tests to assess the validity of the basic physico-chemical model. The application of conventional statistical tests, as set out in IEC 60493-1:2011 [2], fulfilled this requirement, resulting in the confidence limit (TC) of TI, but the simple, single-point TI was found inadequate to describe the capabilities of materials. This led to the concept of the thermal endurance profile (TEP), incorporating the temperature index, its variation with specified ageing time, and a confidence limit.

A complicating factor is that the properties of a material subjected to thermal ageing ~~may~~ possibly do not all deteriorate at the same rate, and different end-points ~~may~~ can be relevant for different applications. Consequently, a material ~~may~~ can be assigned more than one temperature index, derived, for example, from the measurement of different properties and the use of different end-point times.

It was subsequently found that the statistical confidence index included in the TEP was not widely understood or used. However, the statistical tests were considered essential, particularly after minor modifications to make them relate better to practical circumstances: the concept of the halving interval (HIC) was introduced to indicate the rate of change of ageing time with temperature. TEP was then abandoned, with the TI and HIC being reported in a way which indicated whether or not the statistical tests had been fully satisfied. At the same time, the calculation procedures were made more comprehensive, enabling full statistical testing of data obtained using a diagnostic property of any type, including the particular case of partially incomplete data. Simultaneously with the development of the IEC 60216 series [1], other standards were being developed in ISO, intended to satisfy a similar requirement for plastics and rubber materials. These are ISO 2578:1993 [3] and ISO 11346 [4], respectively, which use less rigorous statistical procedures and more restricted experimental techniques. A simplified calculation procedure is defined in IEC 60216-8 [5].

1 Scope

This part of IEC 60216 specifies the general ageing conditions and procedures to be used for deriving thermal endurance characteristics and gives guidance in using the detailed instructions and guidelines in the other parts of IEC 60216.

Although originally developed for use with electrical insulating materials and simple combinations of such materials, the procedures are considered to be of more general applicability and are widely used in the assessment of materials not intended for use as electrical insulation.

In the application of this document, it is assumed that a practically linear relationship exists between the logarithm of the time required to cause the predetermined property change and the reciprocal of the corresponding absolute temperature (Arrhenius relationship).

For the valid application of this document, no transition, in particular no first-order transition ~~should~~, is expected to occur in the temperature range under study.

~~Throughout the rest of this standard the term "insulating materials" is always taken to mean "insulating materials and simple combinations of such materials".~~

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60212, *Standard conditions for use prior to and during the testing of solid electrical insulating materials*

~~IEC 60216-2, *Electrical insulating materials – Thermal endurance properties – Part 2: Determination of thermal endurance properties of electrical insulating materials – Choice of test criteria*~~

IEC 60216-3:2006/2021, *Electrical insulating materials - Thermal endurance properties - Part 3: Instructions for calculating thermal endurance characteristics*

IEC 60216-3, *Electrical insulating materials - Thermal endurance properties - Part 3: Instructions for calculating thermal endurance characteristics*

~~IEC 60216-4 (all Parts 4), *Electrical insulating materials – Thermal endurance properties – Part 4: Ageing ovens*~~

IEC 60216-4-1, *Electrical insulating materials - Thermal endurance properties - Part 4-1: Ageing ovens - Single-chamber ovens*

~~IEC 60216-8, *Electrical insulating materials – Thermal endurance properties – Part 8: Instructions for calculating thermal endurance characteristics using simplified procedures*¹~~

IEC 60493-1:2011, *Guide for the statistical analysis of ageing test data - Part 1: Methods based on mean values of normally distributed test results*

¹~~To be published.~~

IEC 60216-4 series, *Electrical insulating materials – Thermal endurance properties – Part 4: Ageing ovens*

Bibliography

~~IEC 60216-1:1974, Guide for the determination of thermal endurance properties of electrical insulating materials — Part 1: General procedures for the determination of thermal endurance properties, temperature indices and thermal endurance profiles (withdrawn)~~

~~ISO 291, Plastics — Standard atmospheres for conditioning and testing~~

- [1] IEC 60216 series, *Electrical insulating materials – Thermal endurance properties*
- [2] IEC 60493-1:2011, *Guide for the statistical analysis of ageing test data - Part 1: Methods based on mean values of normally distributed test results*
- [3] ISO 2578:1993, *Plastics - Determination of time-temperature limits after prolonged exposure to heat*
- [4] ISO 11346, *Rubber, vulcanized or thermoplastic - Estimation of life-time and maximum temperature of use*
- [5] IEC 60216-8, *Electrical insulating materials - Thermal endurance properties - Part 8: Instructions for calculating thermal endurance characteristics using simplified procedures*
- [6] IEC 60216-2, *Electrical insulating materials - Thermal endurance properties - Part 2: Determination of thermal endurance properties of electrical insulating materials - Choice of test criteria*
- [7] IEC 60050-212:2010, *International Electrotechnical Vocabulary - Part 212: Electrical insulating solids, liquids and gases*
- [8] IEC 60216-3, *Electrical insulating materials - Thermal endurance properties - Part 3: Instructions for calculating thermal endurance characteristics*
- [9] IEC 60212, *Standard conditions for use prior to and during the testing of solid electrical insulating materials*
- [10] IEC 60216-3:2021, *Electrical insulating materials - Thermal endurance properties - Part 3: Instructions for calculating thermal endurance characteristics*
- [11] IEC 60216-8:2013, *Electrical insulating materials - Thermal endurance properties - Part 8: Instructions for calculating thermal endurance characteristics using simplified procedures*