



IEC 60755-1

Edition 1.0 2022-10

# INTERNATIONAL STANDARD

GROUP SAFETY PUBLICATION

**General safety requirements for residual current operated protected devices –  
Part 1: Residual current operated protective devices for DC systems**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

ICS 29.120.50

ISBN 978-2-8322-5867-5

**Warning! Make sure that you obtained this publication from an authorized distributor.**

## CONTENTS

FOREWORD.....	3
INTRODUCTION.....	5
1 Scope.....	6
2 Normative references .....	7
3 Terms and definitions .....	7
4 Classification.....	9
5 Characteristics of residual current devices.....	9
6 Marking and other product information.....	12
7 Conditions for operation in service and for installation .....	12
8 Requirements for construction and operation.....	12
9 Tests .....	15
Annex A (informative) Recommended diagram for short-circuit tests.....	29
Bibliography.....	32
Figure 118 – Example of test circuit for verification of ageing of electronic components .....	27
Figure 200 – Examples of installation.....	28
Figure A.101 – Diagram for all the short-circuit tests.....	30
Table 100 – Example for values of rated operational voltage ( $U_e$ ).....	22
Table 101 – Values of influencing quantities .....	22
Table 102 – Marking for DC-RCDs according to 4.15.1 .....	23
Table 103 – Marking for DC-RCDs according to 4.15.2 and 4.15.3.....	24
Table 104 – Standard values of maximum break time for non-time-delay DC-RCDs .....	24
Table 108 – Standard values of break time and non-actuating time for time-delay DC-RCDs.....	25
Table 113 – Tripping current limits .....	25
Table 130 – Withstand values and duration of temporary overvoltages .....	25
Table 145 – Immunity tests .....	26
Table 146 – Voltage dips and short interruptions levels .....	26

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

---

**GENERAL SAFETY REQUIREMENTS FOR RESIDUAL  
CURRENT OPERATED PROTECTED DEVICES –**
**Part 1: Residual current operated protective devices for DC systems****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 60755-1 has been prepared by subcommittee 23E: Circuit breakers and similar equipment for household use, of IEC technical committee 23: Electrical accessories. It is an International Standard.

This document is intended to be used in conjunction with IEC 60755.

The text of this International Standard is based on the following documents:

Draft	Report on voting
23E/1273/FDIS	23E/1299/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at [www.iec.ch/members\\_experts/refdocs](http://www.iec.ch/members_experts/refdocs). The main document types developed by IEC are described in greater detail at [www.iec.ch/standardsdev/publications](http://www.iec.ch/standardsdev/publications).

A list of all parts in the IEC 60755 series, published under the general title *General safety requirements for residual current operated protected devices*, can be found on the IEC website.

This International Standard is to be used in conjunction with IEC 60755:2017.

The following differing practices of a less permanent nature exist in the countries indicated below:

- IEC 60755:2017, IEC 60755:2017, 5.3.1.12: 1 000 A, 2 000 A, 2 500 A, 7 500 A and 9 000 A are also considered preferred values (Korea and Japan);
- IEC 60755:2017, IEC 60755:2017, 8.1.1: multiple settings are not allowed (Australia, Germany, Denmark, the UK and Switzerland);
- IEC 60755:2017, IEC 60755:2017, 8.1.2: the colours red and green are not used for contact position indication (US).

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under [webstore.iec.ch](http://webstore.iec.ch) in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

## INTRODUCTION

Residual current devices are used for protection against electric shocks.

In IEC 60364 (all parts), residual current devices are used for automatic disconnection of supply in case of fault (see Clause 411 of IEC 60364-4-41:2005+AMD1:2017) and residual current devices with rated residual operating current not exceeding 30 mA are used as additional protection (see Clause 415 of IEC 60364-4-41:2005+AMD1:2017). The IEC has developed a set of standards for residual current operated protective devices intended to be used in AC systems.

DC systems are used for applications such as photovoltaic installations, data and telecom centres and electric vehicle charging systems. In addition, standards for plugs and socket-outlets for ICT equipment installed in data centres and telecom centres have been published.

Residual current devices for DC systems are used to provide fault protection and/or additional protection (according to IEC 60364-4-41:2005 and IEC 60364-4-41:2005/AMD1:2017).

This document defines the operating characteristics for residual current operated protective devices for DC systems. Details of how they should be installed to provide the desired level of protection are specified in the various parts of the IEC 60364 series. The operating characteristics given in this document are based on the information contained in IEC 60479 (all parts).

This document has been prepared as a Group Safety Publication by subcommittee 23E in accordance with its Group Safety Function for residual current devices. It is intended for use by technical committees in the preparation of standards for residual current unit, function or devices when it is intended to provide protective measures according to IEC 60364 (all parts). It is not intended for use as a stand-alone document, for example, for certification.

This document is intended for use in conjunction with IEC 60755. Where a particular subclause of IEC 60755 is not mentioned in this Part 1, that subclause applies as far as is reasonable. Where this Part 1 states "addition", "deletion" or "replacement", the corresponding requirement, test specification or explanatory material in IEC 60755 should be adapted accordingly.

# GENERAL SAFETY REQUIREMENTS FOR RESIDUAL CURRENT OPERATED PROTECTED DEVICES –

## Part 1: Residual current operated protective devices for DC systems

*Replacement of Clause 1 of IEC 60755:2017 by:*

### 1 Scope

This document gives requirements, recommendations and information for the drafting of standards for residual current operated protective devices, intended to be used in DC systems, hereafter referred to as DC-RCDs.

NOTE 1 When referring to IEC 60755, "RCD" shall be understood as "DC-RCD".

This document is primarily intended to be used as a reference for drafting product safety standards for:

- DC-RCD intended for general use;
- DC-RCD specifically intended to be incorporated in a specific item of equipment;
- DC-RCD embedded in an equipment.

This document is applicable for standards covering devices:

- which detect a residual current,
- compare it to a reference value, and
- open the contacts when the residual current exceeds this reference value.

Any association of devices, each one of them performing separately one or two of the above-mentioned functions but acting together in order to accomplish all three functions, is also covered by this document.

DC-RCDs are intended to provide fault protection, the exposed conductive parts of the installation being connected to a protective conductor, in accordance with IEC 60364-4-41:2005 and IEC 60364-4-41:2005/AMD1/2017.

DC-RCDs having a rated residual operating direct current not exceeding 80 mA and having a rated voltage not exceeding 220 V DC for single-pole or 440 V DC for two-pole are also used as a provision for additional protection, according to IEC 60364-4-41.

NOTE 2 Further requirements for higher voltages are under consideration.

NOTE 3 The value of 80 mA was the result of a calculation based on the content of clause 6 of IEC 60479-1:2018 and 5.3.4 of IEC 60479-2:2019.

NOTE 4 In Austria the value of 80 mA is considered as provisional until a broader and more solid set of data than the actual basis of the IEC 60479 series is available for DC.

In accordance with IEC 60364-4-42, residual current devices with a rated residual operating current not exceeding 300 mA can also be used to provide protection against fire hazards due to insulation faults.

DC-RCDs are suitable for isolation. They are suitable for use in TN, TT, and, under specific conditions, IT systems.

DC-RCDs are resistant to unwanted tripping including the case where surge voltages (as a result of switching transients or induced by lightning) cause loading currents in the installation without occurrence of flashover.

This group safety publication is primarily intended for use by technical committees in the preparation of standards in accordance with the principles laid down in IEC Guide 104 and ISO/IEC Guide 51. It is not intended for use by manufacturers or certification bodies.

One of the responsibilities of a technical committee is, wherever applicable, to make use of group safety publications in the preparation of its publications. The requirements, test methods or test conditions of this group safety publication will not apply unless specifically referred to or included in the relevant publications.

## 2 Normative references

Clause 2 of IEC 60755:2017 is applicable except as follows:

*Addition:*

IEC 61000-4-2, *Electromagnetic compatibility (EMC) – Part 4-2: Testing and measurement techniques – Electrostatic discharge immunity test*

IEC 61000-4-3, *Electromagnetic compatibility (EMC) – Part 4-3: Testing and measurement techniques – Radiated, radio-frequency, electromagnetic field immunity test*

IEC 61000-4-4, *Electromagnetic compatibility (EMC) – Part 4-4: Testing and measurement techniques – Electrical fast transient/burst immunity test*

IEC 61000-4-5, *Electromagnetic compatibility (EMC) – Part 4-5: Testing and measurement techniques – Surge immunity test*

IEC 61000-4-6, *Electromagnetic compatibility (EMC) – Part 4-6: Testing and measurement techniques – Immunity to conducted disturbances, induced by radio-frequency fields*

IEC 61000-4-16, *Electromagnetic compatibility (EMC) – Part 4-16: Testing and measurement techniques – Test for immunity to conducted, common mode disturbances in the frequency range 0 Hz to 150 kHz*

IEC 61000-4-17, *Electromagnetic compatibility (EMC) – Part 4-17: Testing and measurement techniques – Ripple on d.c. input power port immunity test*

IEC 61000-4-29, *Electromagnetic compatibility (EMC) – Part 4-29: Testing and measurement techniques – Voltage dips, short interruptions and voltage variations on d.c. input power port immunity tests*

IEC 61543:2022, *Residual current-operated protective devices (RCDs) for household and similar use – Electromagnetic compatibility*