



Edition 1.0 2008-10

TECHNICAL SPECIFICATION

Selection and dimensioning of high-voltage insulators intended for use in polluted conditions – Part 3: Polymer insulators for a.c. systems

INTERNATIONAL ELECTROTECHNICAL COMMISSION

PRICE CODE

ICS 29.080.10

ISBN 2-8318-1015-6

R

CONTENTS

| FO | REWORD | 3 | | |
|-----|---|----|--|--|
| 1 | Scope and object | 5 | | |
| 2 | Normative references | 5 | | |
| 3 | Terms, definitions and abbreviations | 6 | | |
| | 3.1 Terms and definitions | 6 | | |
| | 3.2 Abbreviations | 6 | | |
| 4 | Principles | 6 | | |
| 5 | Materials | 7 | | |
| | 5.1 General information on common polymer housing materials | 7 | | |
| | 5.2 Issues specific to polymer housing materials under pollution | | | |
| | 5.2.1 Reduction of creepage distance | | | |
| _ | 5.2.2 Extreme pollution | | | |
| 6 | Site severity determination | | | |
| 7 | Determination of the reference USCD | | | |
| 8 | General recommendations for polymer profiles | | | |
| 9 | Checking of profile parameters | | | |
| | 9.1 General remark | | | |
| | 9.2 Alternating sheds and shed overhang | | | |
| | 9.3 Spacing versus shed overhang9.4 Minimum distance between sheds | | | |
| | 9.5 Creepage distance versus clearance | | | |
| | 9.6 Shed angle | | | |
| | 9.7 Creepage factor | | | |
| 10 | | | | |
| | 10.1 Correction for altitude <i>K</i> _a | 14 | | |
| | 10.2 Correction for insulator diameter K _{ad} | | | |
| 11 | Determination of the final minimum creepage distance | 15 | | |
| 12 | Confirmation by testing | 15 | | |
| Anr | nex A (informative) Background information on pollution induced degradation of | | | |
| 1 | ymers | | | |
| Bib | liography | 20 | | |
| Fig | ure 1 – RUSCD as a function of SPS class | 9 | | |
| Fig | ure 2 – Typical "open" profiles | 10 | | |
| Fig | ure 3 – Typical steep polymeric profile | 10 | | |
| Fig | ure 4 – Typical shallow under-ribs on open profile | 10 | | |
| Fig | ure 5 – Typical deep under-rib profile | 11 | | |
| Fig | ure 6 – Typical "alternating" profiles | 11 | | |
| Fig | Figure 7 – K_{ad} versus average diameter and illustration of parameters | | | |
| | ure A.1 – Operating areas as a function of pollution severity and USCD (for a fixed ulating length) | 19 | | |

INTERNATIONAL ELECTROTECHNICAL COMMISSION

SELECTION AND DIMENSIONING OF HIGH-VOLTAGE INSULATORS INTENDED FOR USE IN POLLUTED CONDITIONS –

Part 3: Polymer insulators for a.c. systems

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committee; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. In exceptional circumstances, a technical committee may propose the publication of a technical specification when

- the required support cannot be obtained for the publication of an International Standard, despite repeated efforts, or
- The subject is still under technical development or where, for any other reason, there is the future but no immediate possibility of an agreement on an International Standard.

Technical specifications are subject to review within three years of publication to decide whether they can be transformed into International Standards.

IEC/TS 60815-3, which is a technical specification, has been prepared by technical committee 36: Insulators.

The text of this technical specification is based on the following documents:

| Enquiry draft | Report on voting |
|---------------|------------------|
| 36/266/DTS | 36/272A/RVC |

Full information on the voting for the approval of this technical specification can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all the parts in the future IEC 60815 series, under the general title Selection and dimensioning of high-voltage insulators intended for use in polluted conditions, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- transformed into an International standard,
- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

SELECTION AND DIMENSIONING OF HIGH-VOLTAGE INSULATORS INTENDED FOR USE IN POLLUTED CONDITIONS –

Part 3: Polymer insulators for a.c. systems

1 Scope and object

IEC/TS 60815-3, which is a technical specification, is applicable to the selection of polymer insulators for a.c. systems, and the determination of their relevant dimensions, to be used in high voltage systems with respect to pollution.

This part of IEC/TS 60815 gives specific guidelines and principles to arrive at an informed judgement on the probable behaviour of a given insulator in certain pollution environments.

The contents of this technical specification are based on CIGRE 33.13 TF 01 documents [1], [2]¹, which form a useful complement to this technical specification for those wishing to study in greater depth the performance of insulators under pollution.

This technical specification does not deal with the effects of snow or ice on polluted insulators. Although this subject is dealt with by CIGRE [3], current knowledge is very limited and practice is too diverse.

The object of this technical specification is to give the user means to

- determine the reference unified specific creepage distance (USCD) from site pollution severity (SPS) class,
- choose appropriate profiles,
- apply correction factors for altitude, insulator shape, size and position, etc. to the reference USCD.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-471, International Electrotechnical Vocabulary – Part 471: Insulators

IEC/TS 60815-1, Selection and dimensioning of high-voltage insulators for polluted conditions – Part 1: Definitions, information and general principles

IEC/TR 62039, Selection guide for polymeric materials for outdoor use under HV stress

IEC/TS 62073, Guidance on the measurement of wettability of insulator surfaces

¹ Figures in square brackets refer to the bibliography.