



IEC 60885-3

Edition 2.0 2015-04
REDLINE VERSION

INTERNATIONAL STANDARD



**Electrical test methods for electric cables –
Part 3: Test methods for partial discharge measurements on lengths of extruded
power cables**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.060.20

ISBN 978-2-8322-2617-9

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	4
1 SECTION ONE GENERAL.....	6
1 Scope.....	6
2 Normative references	6
2 SECTION TWO PARTIAL DISCHARGE TESTS	6
3 Terms, definitions and symbols.....	6
3.1 Terms and definitions.....	6
3.2 Symbols used in Figures 1 to 14	6
4 Overview	7
4.1 General.....	7
4.2 Object.....	7
4.3 Problem of superposition of travelling waves for long lengths.....	7
5 Partial discharge tests	10
5.1 Test apparatus.....	10
5.1.1 Equipment	10
5.1.2 Test circuit and instruments	10
5.1.3 Double pulse generator	10
5.1.4 Terminal impedance (characteristic impedance)	10
5.1.5 Reflection suppressor	10
5.2 Setting up the test circuit	11
5.2.1 Determination of characteristic properties of the test circuit	11
5.2.2 Terminal impedance	11
5.2.3 Superposition Determination of superposition of travelling waves	11
5.2.4 Reflection suppressor	11
5.2.5 Calibration charge of the measuring system in the complete test circuit.....	11
5.2.6 Sensitivity.....	12
5.3 Measurement procedures.....	12
5.3.1 General	13
5.3.2 Short cable lengths including type test lengths	13
5.3.3 Long cable lengths tested without a terminal impedance.....	14
5.3.4 Long cable lengths tested with a terminal impedance	15
5.3.5 Long cable lengths tested with a reflection suppressor	16
5.4 Voltage levels/partial discharge limits	17
5.5 Double pulse behaviour and plotting the double pulse diagram	17
5.6 Requirements for the terminal impedance	18
5.6.1 General	18
5.6.2 RC element	18
5.6.3 RLC element series resonance circuit.....	19
3 SECTION THREE APPLICATION GUIDE.....	19
3.1 Background information	19
3.1.1 Introduction	19
3.1.2 Superposition and attenuation	19
3.2 Procedures and parameters	19
3.2.1 Determination of characteristic properties of the test circuit (see 2.3)	19
3.2.2 Measurement procedures (see 2.4)	19

Bibliography.....	31
-------------------	----

~~LIST OF SYMBOLS~~

Figure 1 – Discharge site exactly at the cable end remote from the detector ($x = l$).....	7
Figure 2 – Discharge site at a distance $x = x_1$ – Travelling waves	8
Figure 3 – Attenuation of PD pulses along the cable	8
Figure 4 – Superposition and attenuation of PD pulses	9
Figure 5 – Input unit Z_A connected in series with the coupling capacitor, C_K	20
Figure 6 – Input unit Z_A connected in series with the cable, C_X	20
Figure 7 – Bridge circuit.....	20
Figure 8 – Connection of the terminal impedance Z_W	21
Figure 9 – Connection of the reflection suppressor, RS.....	21
Figure 10 – Connection of the double pulse generator into the measuring circuit in Figure 5	21
Figure 11 – Double pulse diagram type 1 without negative superposition	22
Figure 12 – Double pulse diagram type 2 with negative superposition between t_1 and t_2	22
Figure 13 – Double pulse diagram type 3 with negative and positive superpositions between t_1 and t_2	22
Figure 14 – Connection of the double pulse generator for the test circuit in Figure 9 with the reflection suppressor	23
Figure 15 – Maximum attenuation error, both cable ends connected together
Figure 16 – Maximum attenuation error at the centre of the cable if measurements are made from both ends
Figure 17 – Double pulse diagram type 2. Negative superposition between I_1 and I_2 (forbidden length)
Figure 18 – Measurement from both ends to avoid negative error
Figure 19 – Negative superposition for $2l_1 < l < 2l_2$
Figure 20 – Only positive superposition for $l < 2l_1$

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ELECTRICAL TEST METHODS FOR ELECTRIC CABLES –

Part 3: Test methods for partial discharge measurements on lengths of extruded power cables

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This redline version of the official IEC Standard allows the user to identify the changes made to the previous edition. A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text.

International Standard IEC 60885-3 has been prepared by IEC technical committee 20: Electric cables.

This second edition of IEC 60885-3 cancels and replaces the first edition, published in 1988 and constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- The definition of sensitivity as twice the background noise level has been removed and replaced by a practical assessment of sensitivity based on the minimum level of detectable discharge.
- References to measurements of pulse heights in mm on an oscilloscope have been replaced by measurements of partial discharge magnitude in pC.
- The order of the clauses has been revised in line with the general numbering scheme of IEC standards and to provide clarity in order to facilitate its practical use. Section 3 of the first edition (Application guide) has been removed as it is considered that background information is better obtained from the original references as listed in the bibliography.

The text of this standard is based on the following documents:

FDIS	Report on voting
20/1560/FDIS	20/1587/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 60885 series, published under the general title *Electrical test methods for electric cables*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The “colour inside” logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.

ELECTRICAL TEST METHODS FOR ELECTRIC CABLES –

Part 3: Test methods for partial discharge measurements on lengths of extruded power cables

~~1 SECTION ONE – GENERAL~~

1 Scope

This part of IEC 60885 specifies the ~~essential requirements test methods~~ for partial discharge (PD) measurements on lengths of extruded power cable, ~~but does not include measurements made on installed cable systems.~~

Reference is made to IEC 60270 which gives the techniques and considerations applicable to partial discharge measurements in general. ~~The first edition of IEC 60270 appeared in 1968. All references in this standard apply to the second edition (1981).~~

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60270:2000, *High-voltage test techniques – Partial discharge measurements*

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Electrical test methods for electric cables –
Part 3: Test methods for partial discharge measurements on lengths of extruded
power cables**

**Méthodes d'essais électriques pour les câbles électriques –
Partie 3: Méthodes d'essais pour la mesure des décharges partielles sur des
longueurs de câbles de puissance extrudés**

CONTENTS

FOREWORD.....	4
1 Scope.....	6
2 Normative references.....	6
3 Terms, definitions and symbols.....	6
3.1 Terms and definitions.....	6
3.2 Symbols used in Figures 1 to 14.....	6
4 Overview.....	7
4.1 General.....	7
4.2 Object.....	7
4.3 Problem of superposition of travelling waves for long lengths.....	7
5 Partial discharge tests.....	10
5.1 Test apparatus.....	10
5.1.1 Equipment.....	10
5.1.2 Test circuit and instruments.....	10
5.1.3 Double pulse generator.....	10
5.1.4 Terminal impedance.....	10
5.1.5 Reflection suppressor.....	10
5.2 Setting up the test circuit.....	10
5.2.1 Determination of characteristic properties of the test circuit.....	10
5.2.2 Terminal impedance.....	10
5.2.3 Determination of superposition of travelling waves.....	11
5.2.4 Reflection suppressor.....	11
5.2.5 Calibration of the measuring system in the complete test circuit.....	11
5.2.6 Sensitivity.....	11
5.3 Measurement procedures.....	11
5.3.1 General.....	11
5.3.2 Short cable lengths including type test lengths.....	12
5.3.3 Long cable lengths tested without a terminal impedance.....	12
5.3.4 Long cable lengths tested with a terminal impedance.....	13
5.3.5 Long cable lengths tested with a reflection suppressor.....	14
5.4 Voltage levels/partial discharge limits.....	15
5.5 Double pulse behaviour and plotting the double pulse diagram.....	15
5.6 Requirements for the terminal impedance.....	16
5.6.1 General.....	16
5.6.2 RC element.....	16
5.6.3 RLC element series resonance circuit.....	17
Bibliography.....	21
Figure 1 – Discharge site exactly at the cable end remote from the detector ($x = l$).....	7
Figure 2 – Discharge site at a distance $x = x_1$ – Travelling waves.....	8
Figure 3 – Attenuation of PD pulses along the cable.....	8
Figure 4 – Superposition and attenuation of PD pulses.....	9
Figure 5 – Input unit Z_A connected in series with the coupling capacitor, C_K	17
Figure 6 – Input unit Z_A connected in series with the cable, C_X	18
Figure 7 – Bridge circuit.....	18

Figure 8 – Connection of the terminal impedance Z_W 18

Figure 9 – Connection of the reflection suppressor, RS..... 19

Figure 10 – Connection of the double pulse generator into the measuring circuit in
Figure 5..... 19

Figure 11 – Double pulse diagram type 1 without negative superposition 19

Figure 12 – Double pulse diagram type 2 with negative superposition between t_1 and t_2 20

Figure 13 – Double pulse diagram type 3 with negative and positive superpositions
between t_1 and t_2 20

Figure 14 – Connection of the double pulse generator for the test circuit in Figure 9
with the reflection suppressor.....20

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ELECTRICAL TEST METHODS FOR ELECTRIC CABLES –

Part 3: Test methods for partial discharge measurements on lengths of extruded power cables

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60885-3 has been prepared by IEC technical committee 20: Electric cables.

This second edition of IEC 60885-3 cancels and replaces the first edition, published in 1988 and constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- The definition of sensitivity as twice the background noise level has been removed and replaced by a practical assessment of sensitivity based on the minimum level of detectable discharge.
- References to measurements of pulse heights in mm on an oscilloscope have been replaced by measurements of partial discharge magnitude in pC.

- The order of the clauses has been revised in line with the general numbering scheme of IEC standards and to provide clarity in order to facilitate its practical use. Section 3 of the first edition (Application guide) has been removed as it is considered that background information is better obtained from the original references as listed in the bibliography.

The text of this standard is based on the following documents:

FDIS	Report on voting
20/1560/FDIS	20/1587/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 60885 series, published under the general title *Electrical test methods for electric cables*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

ELECTRICAL TEST METHODS FOR ELECTRIC CABLES –

Part 3: Test methods for partial discharge measurements on lengths of extruded power cables

1 Scope

This part of IEC 60885 specifies the test methods for partial discharge (PD) measurements on lengths of extruded power cable, but does not include measurements made on installed cable systems.

Reference is made to IEC 60270 which gives the techniques and considerations applicable to partial discharge measurements in general.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60270:2000, *High-voltage test techniques – Partial discharge measurements*