



TECHNICAL REPORT

BASIC EMC PUBLICATION

**Electromagnetic compatibility (EMC) –
Part 3-13: Limits – Assessment of emission limits for the connection of
unbalanced installations to MV, HV and EHV power systems**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

PRICE CODE
CODE PRIX



CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
ACKNOWLEDGMENT.....	7
1 Scope.....	8
2 Normative references	9
3 Terms and definitions	9
4 Basic EMC concepts related to voltage unbalance.....	14
4.1 Compatibility levels	14
4.2 Planning levels.....	15
4.2.1 Indicative values of planning levels.....	15
4.2.2 Assessment procedure for evaluation against planning levels.....	15
4.3 Illustration of EMC concepts.....	16
4.4 Emission levels	17
5 General principles	18
5.1 Stage 1: simplified evaluation of disturbance emission	19
5.2 Stage 2: emission limits relative to actual system characteristics.....	19
5.3 Stage 3: acceptance of higher emission levels on a conditional basis.....	19
5.4 Responsibilities	19
6 General guidelines for the assessment of emission levels	20
6.1 Point of evaluation.....	20
6.2 Definition of unbalance emission level.....	20
6.3 Assessment of emission levels from unbalanced installations.....	21
7 General summation law	21
8 Emission limits for unbalanced installations in MV systems	22
8.1 Stage 1: simplified evaluation of disturbance emission	22
8.2 Stage 2: emission limits relative to actual system characteristics.....	23
8.2.1 Global emission to be shared between the sources of unbalance	23
8.2.2 Individual emission limits.....	24
8.3 Stage 3: acceptance of higher emission levels on a conditional basis.....	26
8.4 Summary diagram of the evaluation procedure.....	27
9 Emission limits for unbalanced installations in HV or EHV systems.....	29
9.1 Stage 1: simplified evaluation of disturbance emission	29
9.2 Stage 2: emission limits relative to actual system characteristics.....	29
9.2.1 Assessment of the total available power	29
9.2.2 Individual emission limits.....	30
9.3 Stage 3: acceptance of higher emission levels on a conditional basis.....	32
Annex A (informative) Guidance for setting planning levels and emission limits	33
Annex B (informative) Calculation examples for determining emission limits	38
Annex C (informative) List of principal letter symbols, subscripts and symbols.....	39
Bibliography.....	41

Figure 1 – Illustration of basic voltage quality concepts with time/ location statistics covering the whole system.....	17
Figure 2 – Illustration of basic voltage quality concepts with time statistics relevant to one site within the whole system.....	17
Figure 3 – Illustration of the emission vector $\underline{U}_{2i}/\underline{U}_1$ and its contribution to the measured unbalance at the point of evaluation.	20
Figure 4 – Example of a system for sharing global contribution at MV.....	23
Figure 5 – Diagram of evaluation procedure.....	28
Figure 6 – Determination of S_i for a simple HV or EHV system.....	29
Figure 7 – Determination of S_i for a meshed HV or EHV system	30
Figure A.1 – The reduction factor T_{uML} as a function of the factors k_m , k_S , and k_{SC}	36
Figure A.2 – Example of unbalance ratio measurement for a remote mine with largely motor loading.....	36
Table 1 – Compatibility levels for voltage unbalance in low and medium voltage systems reproduced from references IEC 61000-2-2 and IEC 61000-2-12	14
Table 2 – Indicative values of planning levels for voltage unbalance (negative-sequence component) in MV, HV and EHV power systems	15
Table 3 – Indicative value of exponent for the summation of general unbalanced installations	22
Table A.1 – Portion of unbalance for accounting for the system inherent asymmetries	34
Table A.2 – Summation of unbalance from different sources	35
Table A.3 – Range of values of planning levels given different parameters	37

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ELECTROMAGNETIC COMPATIBILITY (EMC) –

Part 3-13: Limits – Assessment of emission limits for the connection of unbalanced installations to MV, HV and EHV power systems

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC/TR 61000-3-13, which is a technical report, has been prepared by subcommittee 77A: Low frequency phenomena, of IEC technical committee 77: Electromagnetic compatibility.

It has the status of a basic EMC publication in accordance with IEC Guide 107 [12]¹.

This first edition of this technical report has been harmonised with IEC/TR 61000-3-6 [10] and IEC/TR 61000-3-7 [11].

¹ Figures in square brackets refer to the bibliography.

The text of this technical report is based on the following documents:

Enquiry draft	Report on voting
77A/577/DTR	77A/616/RVC

Full information on the voting for the approval of this technical report can be found in the report on voting indicated in the above table.

A list of all parts of the IEC 61000 series, under the general title *Electromagnetic compatibility (EMC)*, can be found on the IEC website.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

INTRODUCTION

IEC 61000 is published in separate parts according to the following structure:

Part 1: General

General considerations (introduction, fundamental principles)

Definitions, terminology

Part 2: Environment

Description of the environment

Classification of the environment

Compatibility levels

Part 3: Limits

Emission limits

Immunity limits

(in so far as they do not fall under the responsibility of product committees)

Part 4: Testing and measurement techniques

Measurement techniques

Testing techniques

Part 5: Installation and mitigation guidelines

Installation guidelines

Mitigation methods and devices

Part 6: Generic standards

Part 9: Miscellaneous

Each part is further subdivided into several parts published either as International Standards or as technical specifications or technical reports, some of which have already been published as sections. Others will be published with the part number followed by a dash and a second number identifying the subdivision (example: IEC 61000-6-1).

ACKNOWLEDGMENT

In 2002, the IEC subcommittee 77A made a request to CIGRE Study Committee C4 and CIREN study committee S2, to organize an appropriate technical forum (joint working group) whose main scope was to prepare, among other tasks, a technical report concerning emission limits for the connection of unbalanced installations to public supply systems at MV, HV and EHV.

To this effect, joint working group CIGRE C4.103/CIREN entitled "*Emission Limits for Disturbing Installations*" was appointed in 2003. Some previous work produced by CIGRE JWG C4.07/CIREN has been used as an input to the revision, in particular the planning levels and associated indices. Additional survey data was also collected by the Joint Working Group in the process of setting indicative planning levels.

Subsequent endorsement of the document by IEC was the responsibility of SC 77A.

ELECTROMAGNETIC COMPATIBILITY (EMC) –

Part 3-13: Limits – Assessment of emission limits for the connection of unbalanced installations to MV, HV and EHV power systems

1 Scope

This part of IEC 61000 provides guidance on principles which can be used as the basis for determining the requirements for the connection of unbalanced installations (i.e. three-phase installations causing voltage unbalance) to MV, HV and EHV public power systems (LV installations are covered in other IEC documents). For the purposes of this report, an unbalanced installation means a three-phase installation (which may be a load or a generator) that produces voltage unbalance on the system. The connection of single-phase installations is not specifically addressed, as the connection of such installations is under the control of the system operator or owner. The general principles however may be adapted when considering the connection of single-phase installations. The primary objective is to provide guidance to system operators or owners on engineering practices, which will facilitate the provision of adequate service quality for all connected customers. In addressing installations, this document is not intended to replace equipment standards for emission limits.

The report addresses the allocation of the capacity of the system to absorb disturbances. It does not address how to mitigate disturbances, nor does it address how the capacity of the system can be increased.

Since the guidelines outlined in this report are necessarily based on certain simplifying assumptions, there is no guarantee that this approach will always provide the optimum solution for all unbalanced load situations. The recommended approach should be used with flexibility and judgment as far as engineering is concerned, when applying the given assessment procedures in full or in part.

The system operator or owner is responsible for specifying requirements for the connection of installations which may cause unbalance on the system. The disturbing installation is to be understood as the complete customer's installation (i.e. including balanced and unbalanced parts).

Problems related to unbalance fall into two basic categories.

- Unbalanced installations that draw negative-sequence currents which produce negative-sequence voltages on the supply system. Examples of such installations include arc furnaces and traction loads (typically connected to the public network at HV), and three phase installations where the individual loads are not balanced (typically connected at MV and LV). Negative-sequence voltage superimposed onto the terminal voltage of rotating machines can produce additional heat losses. Negative-sequence voltage can also cause non-characteristic harmonics (typically positive-sequence 3rd harmonic) to be produced by power converters.
- Unbalanced installations connected line-to-neutral can also draw zero-sequence currents which can be transferred or not into the supply system depending on the type of connection of the coupling transformer. The flow of zero-sequence currents in a grounded neutral system causes zero-sequence unbalance affecting line-to-neutral voltages. This is not normally controlled by setting emission limits, but rather by system design and maintenance. Ungrounded-neutral systems and phase-to-phase connected installations are not, however, affected by this kind of voltage unbalance.

This report gives guidance only for the coordination of the negative-sequence type of voltage unbalance between different voltage levels in order to meet the compatibility levels at the point of utilisation. No compatibility levels are defined for zero-sequence type of voltage unbalance as this is often considered as being less relevant to the coordination of unbalance levels compared to the first type of voltage unbalance. However, for situations where a non-zero impedance exists between neutral and earth with the system still being effectively grounded (i.e., where the ratio between zero-sequence, X_0 and positive sequence reactance X_1 is $0 < X_0/X_1 \leq 3$), this type of voltage unbalance can be of concern especially when the type of connection of the coupling transformer allows zero-sequence path to flow from MV to LV and vice-versa.

NOTE The boundaries between the various voltage levels may be different for different countries (see IEC 601 01-28) [9]. This report uses the following terms for system voltage:

- low voltage (LV) refers to $Un \leq 1 \text{ kV}$;
- medium voltage (MV) refers to $1 \text{ kV} < Un \leq 35 \text{ kV}$;
- high voltage (HV) refers to $35 \text{ kV} < Un \leq 230 \text{ kV}$;
- extra high voltage (EHV) refers to $230 \text{ kV} < Un$.

In the context of this report, the function of the system is more important than its nominal voltage. For example, a HV system used for distribution may be given a "planning level" which is situated between those of MV and HV systems.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050(161), *International Electrotechnical Vocabulary – Chapter 161: Electromagnetic compatibility*