



IEC/TS 61000-5-9

Edition 1.0 2009-07

TECHNICAL SPECIFICATION

BASIC EMC PUBLICATION

**Electromagnetic compatibility (EMC) –
Part 5-9: Installation and mitigation guidelines – System-level susceptibility
assessments for HEMP and HPEM**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

PRICE CODE

XB

ICS 33.100.20

ISBN 2-8318-1051-0

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	8
2 Normative references	8
3 Terms and definitions	9
4 General	11
4.1 Introduction	11
4.2 Systems and subsystems	12
5 Interaction mechanisms and protection methods	13
5.1 General.....	13
5.2 Front-door coupling	13
5.3 Back-door coupling.....	13
5.4 Protection methods	14
6 Description of overall assessment methodology	14
6.1 Methodology.....	14
6.2 Subsystems and equipment characterization phase.....	16
6.3 System analysis phase	17
6.4 System test phase.....	17
6.4.1 General	17
6.4.2 Low-level tests	18
6.4.3 High-level testing.....	18
6.5 Susceptibility assessment phase	20
6.6 The use of reverberation chambers to characterise immunity	20
Annex A (informative) Classification of effect.....	24
Annex B (informative) Good measurement practice.....	27
Annex C (informative) Computational electromagnetics	30
Annex D (informative) System level assessment – HEMP	33
Annex E (informative) System level assessment – HPEM	35
Annex F (informative) Limitations.....	39
Annex G (informative) Detailed description of low-level techniques.....	42
Annex H (informative) Detailed description of high-level test techniques.....	54
Annex I (informative) Data processing and analysis	61
Bibliography.....	66
Figure 1 – Example system architecture	12
Figure 2 – Example of radiated HPEM at high frequencies [3].....	14
Figure 3 – Methodology flowchart	15
Figure 4 – Reverberation chamber results: all effects.....	21
Figure 5 – Reverberation chamber results: susceptibilities.....	22
Figure 6 – Frequency spectrum of several HPEM sources	23
Figure A.1 – Classification of effect.....	24
Figure B.1 – Effect of adding ferrites to connecting cable: swept frequency example	27

Figure B.2 – Effect of adding ferrite to connecting cable: reverberation chamber example	28
Figure B.3 – Effect of adding ferrite to connecting cable: transient example (time domain)	28
Figure B.4 – Effect of adding ferrite to connecting cable: transient example (frequency domain)	29
Figure E.1 – Steps taken in the system assessment	36
Figure E.2 – Maximum free-space separation distances.....	38
Figure E.3 – Critical regions for permanent damage.....	38
Figure G.1 – Electromagnetic interaction sequence diagram for a facility illuminated by an external antenna	43
Figure G.2 – Illustration of the difference of a directed, narrow-beam antenna exciting the facility with a spot beam, along with a plane wave providing illumination to the entire facility	45
Figure G.3 – Measurement equipment and configuration for measuring transient responses in a buried facility, as reported by [G-6]	47
Figure G.4 – Example of a measured transient cable current (a) and the resulting spectral magnitude, as computed by a Fourier transform (b)	48
Figure G.5 – Plots of the analytical pulser output open circuit voltage waveform (a) and spectral magnitude (b), which are used as reference for computing the transfer function T_{SC}	48
Figure G.6 – The radiated E-field from the IRA at a distance of 6 meters for the analytical pulser excitation (a) and the resulting spectral magnitude (b).....	49
Figure G.7 – The spectral magnitude of the computed transfer function T_{SC} (a) and the corresponding transient transfer function (b).....	49
Figure G.8 – The spectral magnitude of the computed transfer function T_{EC} (a) and the corresponding transient transfer function (b).....	50
Figure G.9 – LLCW reference field measurement.....	51
Figure G.10 – LLCW induced current measurement	51
Figure G.11 – Typical magnitude-only transfer function.....	52
Figure H.1 – Microwave injection testing of a low noise amplifier, LNA [H-2]. LNA at the tip of the arrow.....	54
Figure H.2 – Aircraft testing at the Swedish Microwave Test Facility, MTF [H-3]	55
Figure H.3 – Measured shielding effectiveness of an equipment compared to the MTF test frequencies (dashed bars) [3].....	56
Figure H.4 – Reverberation chamber	58
Figure I.1 – Prediction of induced current using magnitude-only transfer functions [I-1]	61
Figure I.2 – IEC 61000-2-9 HEMP Waveform	62
Figure I.3 – Convolution process.....	62
Figure I.4 – Predicted induced current	63
Figure I.5 – Comparison of transfer function predictions with simulator measurements	64
Figure I.6 – Extrapolation of measured transients	65

Table A.1 – Categorisation of effect by criticality.....	25
Table A.2 – Categorisation of effect duration	26
Table A.3 – Combination of criticality level and duration category	26
Table I.1 – Comparison of transfer function predictions and simulator measured currents	63

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ELECTROMAGNETIC COMPATIBILITY (EMC) –**Part 5-9: Installation and mitigation guidelines –
System-level susceptibility assessments for HEMP and HPEM**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. In exceptional circumstances, a technical committee may propose the publication of a technical specification when

- the required support cannot be obtained for the publication of an International Standard, despite repeated efforts, or
- the subject is still under technical development or where, for any other reason, there is the future but no immediate possibility of an agreement on an International Standard.

Technical specifications are subject to review within three years of publication to decide whether they can be transformed into International Standards.

IEC/TS 61000-5-9, which is a technical specification, has been prepared by subcommittee 77C: High power transient phenomena, of IEC technical committee 77: Electromagnetic compatibility.

This Technical Specification forms Part 5-9 of IEC 61000. It has the status of a basic EMC publication in accordance with IEC Guide 107 [1]¹.

The text of this technical specification is based on the following documents:

Enquiry draft	Report on voting
77C/190/DTS	77C/194/RVC

Full information on the voting for the approval of this technical specification can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- transformed into an International standard,
- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

¹ Figures in square brackets refer to the Bibliography.

INTRODUCTION

IEC 61000 is published in separate parts according to the following structure:

Part 1: General

General considerations (introduction, fundamental principles)

Definitions, terminology

Part 2: Environment

Description of the environment

Classification of the environment

Compatibility levels

Part 3: Limits

Emission limits

Immunity limits (in so far as they do not fall under the responsibility of the product committees)

Part 4: Testing and measurement techniques

Measurement techniques

Testing techniques

Part 5: Installation and mitigation guidelines

Installation guidelines

Mitigation methods and devices

Part 6: Generic standards

Part 9: Miscellaneous

Each part is further subdivided into several parts and published either as International Standards or as technical specifications or technical reports, some of which have already been published as sections. Others will be published with the part number followed by a dash and a second number identifying the subdivision (example: IEC 61000-6-1).

ELECTROMAGNETIC COMPATIBILITY (EMC) –

Part 5-9: Installation and mitigation guidelines – System-level susceptibility assessments for HEMP and HPEM

1 Scope

The aim of this part of IEC 61000 is to present a methodology to assess the impact of High-altitude Electromagnetic Pulse (HEMP) and High Power Electromagnetic (HPEM) environments on electronic systems. In this context a system refers to a collection of sub-systems, equipment and components brought together to perform a function. (A more complete definition is given in 3.20.) The techniques associated with this methodology and their advantages and disadvantages will be presented along with examples of how the techniques can be applied to evaluate the susceptibility of electronic systems such as those found in installations. This work is closely related to the evaluation of EMC system level susceptibility.

The purpose of this Technical Specification is to provide information on available methods for the assessment of system-level susceptibility as a result of HEMP and HPEM environments. The advantages and disadvantages of the methods will be discussed along with examples of how the techniques should be employed.

Typical systems have external connections, wired or wireless, and the assessment of these are included within this specification.

This specification gives general guidance. It does not cover safety issues nor does it conflict with ITU-T efforts concerning the protection of telecommunications equipment [2]².

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050(161), *International electrotechnical vocabulary – Chapter 161: Electromagnetic compatibility*

IEC/TR 61000-1-5:2004, *Electromagnetic compatibility (EMC) – Part 1-5: General – High power electromagnetic (HPEM) effects on civil systems*

IEC 61000-2-9:1996, *Electromagnetic compatibility (EMC) – Part 2: Environment – Section 9: Description of HEMP environment – Radiated disturbance. Basic EMC publication*

IEC 61000-2-10:1998, *Electromagnetic compatibility (EMC) – Part 2-10: Environment – Description of HEMP environment – Conducted disturbance*

IEC 61000-2-13:2005, *Electromagnetic compatibility (EMC) – Part 2-13: Environment – High-power electromagnetic (HPEM) environments – Radiated and conducted*

² Figures in square brackets refer to the Bibliography.

IEC/TR 61000-4-32:2002, *Electromagnetic compatibility (EMC) – Part 4-32: Testing and measurement techniques – High-altitude electromagnetic pulse (HEMP) simulator compendium*

IEC 61000-4-33:2005, *Electromagnetic compatibility (EMC) – Part 4-33: Testing and measurement techniques – Measurement methods for high-power transient parameters*

IEC 61000-4-35:2009, *Electromagnetic compatibility (EMC) – Part 4-35: Testing and measurement techniques – HPEM simulator compendium*

IEC/TR 61000-5-3:1999, *Electromagnetic compatibility (EMC) – Part 5-3: Installation and mitigation guidelines – HEMP protection concepts*

IEC/TS 61000-5-4:1996, *Electromagnetic compatibility (EMC) – Part 5: Installation and mitigation guidelines – Section 4: Immunity to HEMP – Specifications for protective devices against HEMP radiated disturbance. Basic EMC Publication*

IEC 61000-5-5:1996, *Electromagnetic compatibility (EMC) – Part 5: Installation and mitigation guidelines – Section 5: Specification of protective devices for HEMP conducted disturbance. Basic EMC Publication*

IEC/TR 61000-5-6:2002, *Electromagnetic compatibility (EMC) – Part 5-6: Installation and mitigation guidelines – Mitigation of external EM influences*

IEC 61000-5-7:2001, *Electromagnetic compatibility (EMC) – Part 5-7: Installation and mitigation guidelines – Degrees of protection provided by enclosures against electromagnetic disturbances (EM code)*