



IEC 61558-2-13

Edition 3.0 2022-10
REDLINE VERSION

INTERNATIONAL STANDARD



GROUP SAFETY PUBLICATION

Safety of transformers, reactors, power supply units and ~~similar products for supply voltages up to 1 100 V~~ combinations thereof –
Part 2-13: Particular requirements and tests for auto-transformers and power supply units incorporating auto-transformers for general applications

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.180

ISBN 978-2-8322-5925-2

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD	3
INTRODUCTION	6
1 Scope	7
2 Normative references	8
3 Terms and definitions	8
4 General requirements	9
5 General notes on tests	9
6 Ratings	9
7 Classification	10
8 Marking and other information	10
9 Protection against electric shock	12
10 Change of input voltage setting	12
11 Output voltage and output current under load	12
12 No-load output voltage	12
13 Short-circuit voltage	13
14 Heating	13
15 Short-circuit and overload protection	13
16 Mechanical strength	13
17 Protection against harmful ingress of dust, solid objects and moisture	13
18 Insulation resistance, dielectric strength and leakage current	13
19 Construction	14
20 Components	15
21 Internal wiring	15
22 Supply connection and other external flexible cable or cords	15
23 Terminals for external conductors	15
24 Provisions for protective earthing	15
25 Screws and connections	15
26 Creepage distances, clearances and distances through insulation	15
27 Resistance to heat, fire and tracking	16
28 Resistance to rusting	16
Annexes	17
Bibliography	18
Figure 101 – Windings	9
Figure 102 – Tappings	9
Figure 103 – Windings separated by functional isolation	9
Table 101 – Symbols indicating the kind of transformer	11
Table 101 102 – Output voltage ratio difference ratio	13

INTERNATIONAL ELECTROTECHNICAL COMMISSION

SAFETY OF TRANSFORMERS, REACTORS, POWER SUPPLY UNITS AND ~~SIMILAR PRODUCTS FOR SUPPLY VOLTAGES UP TO 1-100 V~~ COMBINATIONS THEREOF –

Part 2-13: Particular requirements and tests for auto-transformers and power supply units incorporating auto-transformers for general applications

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This redline version of the official IEC Standard allows the user to identify the changes made to the previous edition IEC 61558-2-13:2009. A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text.

International standard IEC 61558-2-13 has been prepared by IEC technical committee 96: Transformers, reactors, power supply units and combinations thereof.

This third edition cancels and replaces the second edition published in 2009. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) adjustment of structure and references in accordance with IEC 61558-1:2017;
- b) description of constructions moved to IEC 61558-1:2017;
- c) new symbol for power supply unit with linearly regulated output voltage.

The text of this document is based on the following documents:

Draft	Report on voting
96/549/FDIS	96/555/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

It has the status of a group safety publication in accordance with IEC Guide 104.

This document is to be used in conjunction with IEC 61558-1:2017.

This document supplements or modifies the corresponding clauses in IEC 61558-1:2017, so as to convert that publication into the IEC standard: *Particular requirements and tests for auto-transformers and power supply units incorporating auto-transformers for general applications*.

A list of all parts in the IEC 61558 series published under the general title *Safety of transformers, reactors, power supply units and combinations thereof*, can be found on the IEC website.

Future standards in this series will carry the new general title as cited above. Titles of existing standards in this series will be updated at the time of the next edition.

Where a particular subclause of IEC 61558-1:2017 is not mentioned in this part, that subclause applies as far as is reasonable. Where this part states "*addition*", "*modification*" or "*replacement*", the relevant text of IEC 61558-1:2017 is to be adapted accordingly.

In this document, the following print types are used:

- requirements proper: in roman type;
- *test specifications: in italic type*;
- explanatory matter: in smaller roman type:

In the text of this document, the words in **bold** are defined in Clause 3.

Subclauses, notes, figures and tables additional to those in IEC 61558-1:2017 are numbered starting from 101; supplementary annexes are entitled AA, BB, etc.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

IEC TC 96 has a group safety function in accordance with IEC Guide 104 for transformers other than those intended to supply distribution networks, in particular transformers and power supply units intended to allow the application of protective measures against electric shock as defined by TC 64, but in certain cases including the limitation of voltage and horizontal safety function for SELV, in accordance with IEC 60364-4-41.

The group safety function (GSF) is used because of responsibility for example for safety extra-low voltage (SELV) in accordance with IEC 61140:2016, 5.2.6 and IEC 60364-4-41:2005, 414.3.1 or control circuits in accordance with IEC 60204-1:2016, 7.2.4.

The group safety function is used for each part of IEC 61558-2 because different standards of the IEC 61558 series can be combined in one construction but in certain cases with no limitation of rated output power.

For example an auto-transformer in accordance with IEC 61558-2-13 can be designed with a separate SELV-circuit in accordance with the particular requirements for IEC 61558-2-6 relating to the general requirements of IEC 61558-1.

SAFETY OF TRANSFORMERS, REACTORS, POWER SUPPLY UNITS AND ~~SIMILAR PRODUCTS FOR SUPPLY VOLTAGES UP TO 1 100 V~~ COMBINATIONS THEREOF –

Part 2-13: Particular requirements and tests for auto-transformers and power supply units incorporating auto-transformers for general applications

1 Scope

Replacement:

This part of IEC 61558 deals with the safety of **auto-transformers** for general applications and **power supply units** incorporating **auto-transformers** for general applications. **Transformers** incorporating **electronic circuits** are also covered by this document.

NOTE 1 Safety includes electrical, thermal and mechanical aspects.

Unless otherwise specified, from here onward, the term **transformer** covers **auto-transformers** for general applications and **power supply units** incorporating **auto-transformers** for general applications.

NOTE 2—For **power supply units** (linear) this document is applicable. For **switch mode power supply units** IEC 61558-2-16 is applicable ~~together with this part~~.

This document is applicable to **stationary** or **portable**, single-phase or polyphase, air-cooled (natural or forced) **independent** or **associated dry-type transformers**. The windings ~~may~~ can be encapsulated or non-encapsulated.

The **rated supply voltage** does not exceed ~~1 100~~ 1 000 V AC, and the **rated supply frequency** and the **internal operating frequencies** do not exceed 500 Hz.

The **core power** does not exceed:

- 2 kVA for single-phase **transformers**;
- 10 kVA for polyphase **transformers**.

The **rated output** does not exceed:

- 40 kVA for single-phase **transformers**;
- 200 kVA for polyphase **transformers**.

This document is applicable to **transformers** without limitations of the **core power** and the **rated output** both being subject to an agreement between the purchaser and the manufacturer.

Where applicable, the **no-load output voltage** or the **rated output voltage** does not exceed 1 000 V AC or 1 415 V ripple-free DC. For **independent transformers**, the **no-load output voltage** and the **rated output voltage** ~~exceeds~~ is not less than 50 V AC or 120 V ripple-free DC.

This document is not applicable to external circuits and their components intended to be connected to the input terminals and output terminals of the **transformers**.

NOTE 2 Transformers covered by this document are used only in applications where no **insulation** between circuits is required by the installation rules or by the end product standard.

~~NOTE 3~~ Attention is drawn to the following, if necessary:

- for **transformers** intended to be used in vehicles, on board ships, and aircraft, additional requirements (from other applicable standards, national rules, etc.) ~~may be necessary~~;
- measures to protect the **enclosure** and the components inside the enclosure against external influences such as fungus, vermin, termites, solar-radiation, and icing ~~should also be considered~~;
- the different conditions for transportation, storage, and operation of the **transformers** ~~should also be considered~~;
- additional requirements in accordance with other appropriate standards and national rules ~~may~~ can be applicable to **transformers** intended for use in special environments.

~~NOTE 4~~ Future technological development of **transformers** ~~may~~ can necessitate a need to increase the upper limit of the frequencies. Until then this document ~~may~~ can be used as a guidance document.

This group safety publication focusing on safety guidance is primarily intended to be used as a product safety standard for the products mentioned in the scope, but is also intended to be used by technical committees in the preparation of publications for products similar to those mentioned in the scope of this group safety publication, in accordance with the principles laid down in IEC Guide 104 and ISO/IEC Guide 51.

One of the responsibilities of a technical committee is, wherever applicable, to make use of basic safety publications and/or group safety publications in the preparation of its publications.

2 Normative references

This clause of IEC 61558-1:2017 is applicable except as follows:

Addition:

IEC 61558-1:~~2005~~2017, *Safety of ~~power~~ transformers, ~~power supplies~~, reactors, power supply units and ~~similar products~~ combinations thereof – Part 1: General requirements and tests*

INTERNATIONAL STANDARD

NORME INTERNATIONALE

GROUP SAFETY PUBLICATION
PUBLICATION GROUPEE DE SÉCURITÉ

**Safety of transformers, reactors, power supply units and combinations thereof –
Part 2-13: Particular requirements and tests for auto-transformers and power
supply units incorporating auto-transformers for general applications**

**Sécurité des transformateurs, bobines d'inductance, blocs d'alimentation et
combinaisons de ces éléments –
Partie 2-13: Exigences particulières et essais pour les autotransformateurs et les
blocs d'alimentation qui incorporent des autotransformateurs pour applications
d'ordre général**

CONTENTS

FOREWORD	3
INTRODUCTION	5
1 Scope	6
2 Normative references	7
3 Terms and definitions	7
4 General requirements	8
5 General notes on tests	8
6 Ratings	8
7 Classification	9
8 Marking and other information	9
9 Protection against electric shock	10
10 Change of input voltage setting	10
11 Output voltage and output current under load	10
12 No-load output voltage	10
13 Short-circuit voltage	11
14 Heating	11
15 Short-circuit and overload protection	12
16 Mechanical strength	12
17 Protection against harmful ingress of dust, solid objects and moisture	12
18 Insulation resistance, dielectric strength and leakage current	12
19 Construction	12
20 Components	12
21 Internal wiring	12
22 Supply connection and other external flexible cable or cords	12
23 Terminals for external conductors	13
24 Provisions for protective earthing	13
25 Screws and connections	13
26 Creepage distances, clearances and distances through insulation	13
27 Resistance to heat, fire and tracking	13
28 Resistance to rusting	13
Annexes	14
Bibliography	15
Figure 101 – Windings	8
Figure 102 – Tappings	8
Figure 103 – Windings separated by functional isolation	8
Table 101 – Symbols indicating the kind of transformer	10
Table 102 – Output voltage ratio	11

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**SAFETY OF TRANSFORMERS, REACTORS, POWER
SUPPLY UNITS AND COMBINATIONS THEREOF –****Part 2-13: Particular requirements and tests for
auto-transformers and power supply units incorporating
auto-transformers for general applications**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International standard IEC 61558-2-13 has been prepared by IEC technical committee 96: Transformers, reactors, power supply units and combinations thereof.

This third edition cancels and replaces the second edition published in 2009. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) adjustment of structure and references in accordance with IEC 61558-1:2017;
- b) description of constructions moved to IEC 61558-1:2017;
- c) new symbol for power supply unit with linearly regulated output voltage.

The text of this document is based on the following documents:

Draft	Report on voting
96/549/FDIS	96/555/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

It has the status of a group safety publication in accordance with IEC Guide 104.

This document is to be used in conjunction with IEC 61558-1:2017.

This document supplements or modifies the corresponding clauses in IEC 61558-1:2017, so as to convert that publication into the IEC standard: *Particular requirements and tests for auto-transformers and power supply units incorporating auto-transformers for general applications*.

A list of all parts in the IEC 61558 series published under the general title *Safety of transformers, reactors, power supply units and combinations thereof*, can be found on the IEC website.

Future standards in this series will carry the new general title as cited above. Titles of existing standards in this series will be updated at the time of the next edition.

Where a particular subclause of IEC 61558-1:2017 is not mentioned in this part, that subclause applies as far as is reasonable. Where this part states "*addition*", "*modification*" or "*replacement*", the relevant text of IEC 61558-1:2017 is to be adapted accordingly.

In this document, the following print types are used:

- requirements proper: in roman type;
- *test specifications: in italic type;*
- explanatory matter: in smaller roman type:

In the text of this document, the words in **bold** are defined in Clause 3.

Subclauses, notes, figures and tables additional to those in IEC 61558-1:2017 are numbered starting from 101; supplementary annexes are entitled AA, BB, etc.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

INTRODUCTION

IEC TC 96 has a group safety function in accordance with IEC Guide 104 for transformers other than those intended to supply distribution networks, in particular transformers and power supply units intended to allow the application of protective measures against electric shock as defined by TC 64, but in certain cases including the limitation of voltage and horizontal safety function for SELV, in accordance with IEC 60364-4-41.

The group safety function (GSF) is used because of responsibility for example for safety extra-low voltage (SELV) in accordance with IEC 61140:2016, 5.2.6 and IEC 60364-4-41:2005, 414.3.1 or control circuits in accordance with IEC 60204-1:2016, 7.2.4.

The group safety function is used for each part of IEC 61558-2 because different standards of the IEC 61558 series can be combined in one construction but in certain cases with no limitation of rated output power.

For example an auto-transformer in accordance with IEC 61558-2-13 can be designed with a separate SELV-circuit in accordance with the particular requirements for IEC 61558-2-6 relating to the general requirements of IEC 61558-1.

SAFETY OF TRANSFORMERS, REACTORS, POWER SUPPLY UNITS AND COMBINATIONS THEREOF –

Part 2-13: Particular requirements and tests for auto-transformers and power supply units incorporating auto-transformers for general applications

1 Scope

Replacement:

This part of IEC 61558 deals with the safety of **auto-transformers** for general applications and **power supply units** incorporating **auto-transformers** for general applications. **Transformers** incorporating **electronic circuits** are also covered by this document.

NOTE 1 Safety includes electrical, thermal and mechanical aspects.

Unless otherwise specified, from here onward, the term **transformer** covers **auto-transformers** for general applications and **power supply units** incorporating **auto-transformers** for general applications.

For **power supply units** (linear) this document is applicable. For **switch mode power supply units** IEC 61558-2-16 is applicable.

This document is applicable to **stationary** or **portable**, single-phase or polyphase, air-cooled (natural or forced) **independent** or **associated dry-type transformers**. The windings can be encapsulated or non-encapsulated.

The **rated supply voltage** does not exceed 1 000 V AC, and the **rated supply frequency** and the **internal operating frequencies** do not exceed 500 Hz.

The **core power** does not exceed:

- 2 kVA for single-phase **transformers**;
- 10 kVA for polyphase **transformers**.

The **rated output** does not exceed:

- 40 kVA for single-phase **transformers**;
- 200 kVA for polyphase **transformers**.

This document is applicable to **transformers** without limitations of the **core power** and the **rated output** both being subject to an agreement between the purchaser and the manufacturer.

Where applicable, the **no-load output voltage** or the **rated output voltage** does not exceed 1 000 V AC or 1 415 V ripple-free DC. For **independent transformers**, the **no-load output voltage** and the **rated output voltage** is not less than 50 V AC or 120 V ripple-free DC.

This document is not applicable to external circuits and their components intended to be connected to the input terminals and output terminals of the **transformers**.

NOTE 2 **Transformers** covered by this document are used only in applications where no **insulation** between circuits is required by the installation rules or by the end product standard.

Attention is drawn to the following, if necessary:

- for **transformers** intended to be used in vehicles, on board ships, and aircraft, additional requirements (from other applicable standards, national rules, etc.);
- measures to protect the **enclosure** and the components inside the enclosure against external influences such as fungus, vermin, termites, solar-radiation, and icing;
- the different conditions for transportation, storage, and operation of the **transformers**;
- additional requirements in accordance with other appropriate standards and national rules can be applicable to **transformers** intended for use in special environments.

Future technological development of **transformers** can necessitate a need to increase the upper limit of the frequencies. Until then this document can be used as a guidance document.

This group safety publication focusing on safety guidance is primarily intended to be used as a product safety standard for the products mentioned in the scope, but is also intended to be used by technical committees in the preparation of publications for products similar to those mentioned in the scope of this group safety publication, in accordance with the principles laid down in IEC Guide 104 and ISO/IEC Guide 51.

One of the responsibilities of a technical committee is, wherever applicable, to make use of basic safety publications and/or group safety publications in the preparation of its publications.

2 Normative references

This clause of IEC 61558-1:2017 is applicable except as follows:

Addition:

IEC 61558-1:2017, *Safety of transformers, reactors, power supply units and combinations thereof – Part 1: General requirements and tests*

SOMMAIRE

AVANT-PROPOS	17
INTRODUCTION.....	20
1 Domaine d'application	21
2 Références normatives	22
3 Termes et définitions	22
4 Exigences générales	23
5 Généralités sur les essais.....	23
6 Caractéristiques assignées.....	23
7 Classification	24
8 Marquage et indications.....	25
9 Protection contre les chocs électriques.....	25
10 Changement de la tension primaire d'alimentation	26
11 Tension secondaire et courant secondaire en charge	26
12 Tension secondaire à vide	26
13 Tension de court-circuit	27
14 Echauffements.....	27
15 Protection contre les courts-circuits et les surcharges	27
16 Résistance mécanique.....	27
17 Protection contre les effets nuisibles dus à la pénétration de poussière, d'objets solides et de l'humidité	27
18 Résistance d'isolement, rigidité diélectrique et courant de fuite	28
19 Construction	28
20 Composants	28
21 Conducteurs internes.....	28
22 Raccordement à l'alimentation et câbles souples externes	28
23 Bornes pour conducteurs externes	28
24 Dispositions en vue de la mise à la terre de protection	28
25 Vis et connexions	28
26 Lignes de fuite, distances d'isolement et distances à travers l'isolation.....	29
27 Résistance à la chaleur, au feu et aux courants de cheminement	29
28 Protection contre la rouille	29
Annexes	30
Bibliographie.....	31
Figure 101 – Enroulements	23
Figure 102 – Prises.....	23
Figure 103 – Enroulements séparés par une isolation fonctionnelle	23
Tableau 101 – Symboles qui indiquent le type de transformateur	25
Tableau 102 – Rapport de la tension secondaire	27

COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE

SÉCURITÉ DES TRANSFORMATEURS, BOBINES D'INDUCTANCE, BLOCS D'ALIMENTATION ET COMBINAISONS DE CES ÉLÉMENTS –

Partie 2-13: Exigences particulières et essais pour les autotransformateurs et les blocs d'alimentation qui incorporent des autotransformateurs pour applications d'ordre général

AVANT-PROPOS

- 1) La Commission Electrotechnique Internationale (IEC) est une organisation mondiale de normalisation composée de l'ensemble des comités électrotechniques nationaux (Comités nationaux de l'IEC). L'IEC a pour objet de favoriser la coopération internationale pour toutes les questions de normalisation dans les domaines de l'électricité et de l'électronique. A cet effet, l'IEC – entre autres activités – publie des Normes internationales, des Spécifications techniques, des Rapports techniques, des Spécifications accessibles au public (PAS) et des Guides (ci-après dénommés "Publication(s) de l'IEC"). Leur élaboration est confiée à des comités d'études, aux travaux desquels tout Comité national intéressé par le sujet traité peut participer. Les organisations internationales, gouvernementales et non gouvernementales, en liaison avec l'IEC, participent également aux travaux. L'IEC collabore étroitement avec l'Organisation Internationale de Normalisation (ISO), selon des conditions fixées par accord entre les deux organisations.
- 2) Les décisions ou accords officiels de l'IEC concernant les questions techniques représentent, dans la mesure du possible, un accord international sur les sujets étudiés, étant donné que les Comités nationaux de l'IEC intéressés sont représentés dans chaque comité d'études.
- 3) Les Publications de l'IEC se présentent sous la forme de recommandations internationales et sont agréées comme telles par les Comités nationaux de l'IEC. Tous les efforts raisonnables sont entrepris afin que l'IEC s'assure de l'exactitude du contenu technique de ses publications; l'IEC ne peut pas être tenue responsable de l'éventuelle mauvaise utilisation ou interprétation qui en est faite par un quelconque utilisateur final.
- 4) Dans le but d'encourager l'uniformité internationale, les Comités nationaux de l'IEC s'engagent, dans toute la mesure possible, à appliquer de façon transparente les Publications de l'IEC dans leurs publications nationales et régionales. Toutes divergences entre toutes Publications de l'IEC et toutes publications nationales ou régionales correspondantes doivent être indiquées en termes clairs dans ces dernières.
- 5) L'IEC elle-même ne fournit aucune attestation de conformité. Des organismes de certification indépendants fournissent des services d'évaluation de conformité et, dans certains secteurs, accèdent aux marques de conformité de l'IEC. L'IEC n'est responsable d'aucun des services effectués par les organismes de certification indépendants.
- 6) Tous les utilisateurs doivent s'assurer qu'ils sont en possession de la dernière édition de cette publication.
- 7) Aucune responsabilité ne doit être imputée à l'IEC, à ses administrateurs, employés, auxiliaires ou mandataires, y compris ses experts particuliers et les membres de ses comités d'études et des Comités nationaux de l'IEC, pour tout préjudice causé en cas de dommages corporels et matériels, ou de tout autre dommage de quelque nature que ce soit, directe ou indirecte, ou pour supporter les coûts (y compris les frais de justice) et les dépenses découlant de la publication ou de l'utilisation de cette Publication de l'IEC ou de toute autre Publication de l'IEC, ou au crédit qui lui est accordé.
- 8) L'attention est attirée sur les références normatives citées dans cette publication. L'utilisation de publications référencées est obligatoire pour une application correcte de la présente publication.
- 9) L'attention est attirée sur le fait que certains des éléments du présent document de l'IEC peuvent faire l'objet de droits de brevet. L'IEC ne saurait être tenue pour responsable de ne pas avoir identifié de tels droits de brevets.

La Norme internationale IEC 61558-2-13 a été établie par le comité d'études 96 de l'IEC: Transformateurs, bobines d'inductance, blocs d'alimentation et combinaisons de ces éléments.

Cette troisième édition annule et remplace la deuxième édition parue en 2009. Cette édition constitue une révision technique.

Cette édition inclut les modifications techniques majeures suivantes par rapport à l'édition précédente:

- a) la structure et les références ont été alignées sur l'IEC 61558-1:2017;
- b) la description des constructions a été déplacée dans l'IEC 61558-1:2017;

- c) un nouveau symbole a été ajouté pour les blocs d'alimentation dont la régulation de la tension secondaire est linéaire.

Le texte de ce document est issu des documents suivants:

Projet	Rapport de vote
96/549/FDIS	96/555/RVD

Le rapport de vote indiqué dans le tableau ci-dessus donne toute information sur le vote ayant abouti à son approbation.

La langue employée pour l'élaboration de cette Norme internationale est l'anglais.

Ce document a été rédigé selon les Directives ISO/IEC, Partie 2, il a été développé selon les Directives ISO/IEC, Partie 1 et les Directives ISO/IEC, Supplément IEC, disponibles sous www.iec.ch/members_experts/refdocs. Les principaux types de documents développés par l'IEC sont décrits plus en détail sous www.iec.ch/standardsdev/publications.

Il a le statut de publication groupée de sécurité conformément au Guide 104 de l'IEC.

Le présent document doit être utilisé conjointement avec l'IEC 61558-1:2017.

Le présent document complète ou modifie les articles correspondants de l'IEC 61558-1:2017, de façon à transformer cette publication en norme IEC: *Exigences particulières et essais pour les autotransformateurs et les blocs d'alimentation qui incorporent des autotransformateurs pour applications d'ordre général*.

Une liste de toutes les parties de la série IEC 61558, publiées sous le titre général *Sécurité des transformateurs, bobines d'inductance, blocs d'alimentation et des combinaisons de ces éléments*, se trouve sur le site web de l'IEC.

Les futures normes de cette série porteront le nouveau titre général cité ci-dessus. Le titre des normes qui existent déjà dans cette série sera mis à jour lors de la prochaine édition.

Lorsqu'un paragraphe particulier de l'IEC 61558-1:2017 n'est pas mentionné dans la présente partie, ce paragraphe s'applique pour autant que cela soit raisonnable. Lorsque la présente partie mentionne "*addition*", "*modification*" ou "*remplacement*", le texte correspondant de l'IEC 61558-1:2017 doit être adapté en conséquence.

Dans le présent document, les caractères d'imprimerie suivants sont utilisés:

- exigences proprement dites: caractères romains;
- *modalités d'essais: caractères italiques*;
- commentaires: petits caractères romains.

Dans le texte du présent document, les termes en **gras** sont définis à l'Article 3.

Les paragraphes, notes, figures et tableaux qui s'ajoutent à ceux de l'IEC 61558-1:2017 sont numérotés à partir de 101; les annexes qui sont ajoutées sont désignées AA, BB, etc.

Le comité a décidé que le contenu de ce document ne sera pas modifié avant la date de stabilité indiquée sur le site web de l'IEC sous "<http://webstore.iec.ch>" dans les données relatives au document recherché. A cette date, le document sera

- reconduit,
- supprimé,
- remplacé par une édition révisée, ou
- amendé.

INTRODUCTION

Le CE 96 de l'IEC a une fonction groupée de sécurité, conformément au Guide 104 de l'IEC relatif aux transformateurs autres que ceux destinés à alimenter les réseaux de distribution, notamment les transformateurs et les blocs d'alimentation destinés à permettre l'application de mesures de protection contre les chocs électriques, comme cela est défini par le CE 64, mais qui incluent également dans certains cas la limitation de la tension et de la fonction de sécurité horizontale pour la TBTS, conformément à l'IEC 60364-4-41.

La fonction groupée de sécurité (GSF, *Group Safety Function*) est utilisée en raison, par exemple, de la responsabilité de la très basse tension de sécurité (TBTS), conformément au 5.2.6 de l'IEC 61140:2016 et au 414.3.1 de l'IEC 60364-4-41:2005, ou des circuits de commande, conformément au 7.2.4 de l'IEC 60204-1:2016.

La fonction groupée de sécurité est utilisée pour chacune des parties de l'IEC 61558-2, car différentes normes de la série IEC 61558 peuvent être combinées en une seule et même construction, mais dans certains cas sans aucune limitation de la puissance secondaire assignée.

Un autotransformateur conforme à l'IEC 61558-2-13 peut par exemple être conçu avec un circuit TBTS séparé, conformément aux exigences particulières de l'IEC 61558-2-6 liées aux exigences générales de l'IEC 61558-1.

SÉCURITÉ DES TRANSFORMATEURS, BOBINES D'INDUCTANCE, BLOCS D'ALIMENTATION ET COMBINAISONS DE CES ÉLÉMENTS –

Partie 2-13: Exigences particulières et essais pour les autotransformateurs et les blocs d'alimentation qui incorporent des autotransformateurs pour applications d'ordre général

1 Domaine d'application

Remplacement:

La présente partie de l'IEC 61558 traite de la sécurité des **autotransformateurs** pour applications d'ordre général et des **blocs d'alimentation** qui incorporent des **autotransformateurs** pour applications d'ordre général. Les **transformateurs** qui incorporent des **circuits électroniques** sont également couverts par le présent document.

NOTE 1 La sécurité comprend les aspects électrique, thermique et mécanique.

Sauf spécification contraire dans la suite du présent document, le terme **transformateur** couvre les **autotransformateurs** pour applications d'ordre général et les **blocs d'alimentation** qui incorporent des **autotransformateurs** pour applications d'ordre général.

Pour les **blocs d'alimentation** (linéaires), le présent document s'applique. Pour les **blocs d'alimentation à découpage**, l'IEC 61558-2-16 s'applique.

Le présent document s'applique aux **transformateurs** de **type sec fixes** ou **mobiles**, monophasés ou polyphasés, à refroidissement par air (naturel ou forcé) **indépendants** ou **associés**. Les enroulements peuvent être enrobés ou non enrobés.

La **tension primaire assignée** ne dépasse pas 1 000 V en courant alternatif, et la **fréquence d'alimentation assignée** et les **fréquences de fonctionnement interne** ne dépassent pas 500 Hz.

La **puissance du noyau** ne dépasse pas:

- 2 kVA pour les **transformateurs** monophasés;
- 10 kVA pour les **transformateurs** polyphasés.

La **puissance assignée** ne dépasse pas:

- 40 kVA pour les **transformateurs** monophasés;
- 200 kVA pour les **transformateurs** polyphasés.

Le présent document s'applique aux **transformateurs** sans limitations de la **puissance du noyau** et de la **puissance assignée**, qui font l'objet d'un accord entre l'acheteur et le fabricant.

Le cas échéant, la **tension secondaire à vide** ou la **tension secondaire assignée** ne dépasse pas 1 000 V en courant alternatif ou 1 415 V en courant continu lissé. Pour les **transformateurs indépendants**, la **tension secondaire à vide** et la **tension secondaire assignée** ne sont pas inférieures à 50 V en courant alternatif ou 120 V en courant continu lissé.

Le présent document ne s'applique pas aux circuits externes et à leurs composants destinés à être connectés aux bornes primaires et bornes secondaires des **transformateurs**.

NOTE 2 Les **transformateurs** couverts par le présent document ne sont utilisés que dans le cadre d'applications pour lesquelles les règles d'installation ou la norme du produit final n'exigent aucune **isolation** entre les circuits.

L'attention est attirée sur les points suivants, si nécessaire:

- exigences supplémentaires (issues d'autres normes applicables, règles nationales, etc.) pour les **transformateurs** destinés à être utilisés dans des véhicules, à bord de navires ou d'avions;
- mesures qui visent à protéger l'**enveloppe** et les composants à l'intérieur de l'enveloppe contre les influences externes, telles que les champignons, la vermine, les termites, le rayonnement solaire et le givre;
- différentes conditions de transport, de stockage et de fonctionnement pour les **transformateurs**;
- exigences supplémentaires qui peuvent s'appliquer aux **transformateurs** destinés à être utilisés dans un environnement particulier, au regard d'autres normes et règles nationales applicables.

Les évolutions techniques futures des **transformateurs** peuvent nécessiter une augmentation de la limite supérieure des fréquences. En attendant, le présent document peut être utilisé à titre de recommandation.

La présente publication groupée de sécurité portant sur des recommandations de sécurité est avant tout destinée à être utilisée en tant que norme en matière de sécurité des produits qui sont cités dans le domaine d'application, mais elle est également destinée à être utilisée par les comités d'études dans le cadre de l'élaboration de publications pour des produits similaires à ceux cités dans le domaine d'application de la présente publication groupée de sécurité, conformément aux principes établis dans le Guide 104 de l'IEC et le Guide 51 de l'ISO/IEC.

L'une des responsabilités d'un comité d'études consiste, le cas échéant, à utiliser les publications fondamentales de sécurité et/ou les publications groupées de sécurité dans le cadre de l'élaboration de ses publications.

2 Références normatives

L'article de l'IEC 61558-1:2017 s'applique, avec l'exception suivante:

Addition:

IEC 61558-1:2017, *Sécurité des transformateurs, bobines d'inductance, blocs d'alimentation et des combinaisons de ces éléments – Partie 1: Exigences générales et essais*