



IEC 61992-6

Edition 1.2 2020-05
CONSOLIDATED VERSION

INTERNATIONAL STANDARD



**Railway applications – Fixed installations – DC switchgear –
Part 6: DC switchgear assemblies**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 45.060.01

ISBN 978-2-8322-8411-7

Warning! Make sure that you obtained this publication from an authorized distributor.

REDLINE VERSION



Railway applications – Fixed installations – DC switchgear – Part 6: DC switchgear assemblies

CONTENTS

1	Scope	6
2	Normative references	6
3	Terms and definitions	6
4	Service requirements	7
5	Characteristics of the assemblies	7
6	Construction characteristics	7
6.1	General	7
6.2	Insulation requirements	8
6.3	Primary connections	9
6.4	Location of the primary connections	9
6.5	Earthing	9
6.5.1	Earthing of the main circuit	9
6.5.2	Earthing of the enclosure	9
6.6	Degree of protection and internal fault	10
6.6.1	Protection against approach to live parts and contact with moving parts	10
6.6.2	Internal arcing	11
6.7	Covers and doors	11
6.8	Inspection windows	11
6.9	Ventilating openings	12
6.10	Partitions and shutters	12
6.10.1	General	12
6.10.2	Partitions	12
6.10.3	Shutters	12
6.10.4	Isolating distances	13
6.11	Interlocks	13
6.12	Temperature-rises	14
6.13	Dielectric strength	14
6.14	Painting and finishing	14
6.15	Noise emission	14
6.16	Cooling and heating	14
6.17	Operating temperature of auxiliary and control equipment	14
6.18	Rated short-time withstand current of busbars	14
7	Information and marking	15
7.1	Information	15
7.2	Marking	15
8	Tests	15
8.1	General	15
8.2	List of the applicable tests	16
8.3	Performance of tests	16
8.3.1	Verification of conformity to the manufacturing drawings and to characteristics of the assembly	16
8.3.2	Operation test	17
8.3.3	Dielectric tests	17
8.3.4	Short-time withstand current tests	19
8.3.5	Mechanical operation test	21

8.3.6	Verification of the degree of protection	21
8.3.7	Temperature-rise tests	21
8.3.8	Electrical operation test	23
8.3.9	Internal arc test	24
Annex A (informative)	Information required	25
A.1	General	25
A.2	Procurement specification	25
A.3	Manufacturer's tender specification	26
A.4	Information and data to be supplied by the manufacturer during the delivery stage	27
Annex B (normative)	Method for testing under conditions of arcing due to an internal fault	29
B.1	Purpose of the test	29
B.2	Characteristics – Rated short-circuit current under internal arcing conditions (I_{Narc})	29
B.3	Test arrangements	29
B.3.1	Test specimen	29
B.3.2	Test circuit	30
B.3.3	Voltage	30
B.3.4	Duration of the test	30
B.4	Test procedure	30
B.4.1	Supply circuit	30
B.4.2	Arc initiation	31
B.4.3	Indicators	32
B.4.4	Repetition of the test	32
B.5	Assessment of the test	32
B.6	Test report	33
Figure 1	– Test arrangement for short-time current withstand test on busbars	20
Figure 2	– Test arrangement for temperature-rise test on main circuits	22
Figure 3	– Test arrangement for temperature-rise test on the busbars	23
Figure B.1	– Room simulation and indicator positioning, functional unit fitted with roof	34
Figure B.2	– Mounting frame for vertical indicators	35
Figure B.3	– Indicators arranged in a checkerboard pattern	35
Table 1	– Degrees of protection	11
Table 2	– List of applicable tests	16
Table B.1	– Sizes of the copper ignition wire	31

INTERNATIONAL ELECTROTECHNICAL COMMISSION

RAILWAY APPLICATIONS – FIXED INSTALLATIONS – DC SWITCHGEAR –

Part 6: DC switchgear assemblies

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendments has been prepared for user convenience.

IEC 61992-6 edition 1.2 contains the first edition (2006-02) [documents 9/891/FDIS and 9/913/RVD], its amendment 1 (2014-04) [documents 9/1792/CDV and 9/1852/RVC] and its amendment 2 (2020-05) [documents 9/2542/CDV and 9/2584A/RVC].

In this Redline version, a vertical line in the margin shows where the technical content is modified by amendments 1 and 2. Additions are in green text, deletions are in strikethrough red text. A separate Final version with all changes accepted is available in this publication.

International Standard IEC 61992-6 has been prepared by IEC technical committee 9: Electrical equipment and systems for railways.

IEC 61992 consists of the following parts, under the general title *Railway applications – Fixed installations – DC switchgear*:

- Part 1: General
- Part 2: D.C. circuit breakers
- Part 3: Indoor d.c. disconnectors, switch-disconnectors and earthing switches
- Part 4: Outdoor d.c. disconnectors, switch-disconnectors and earthing switches
- Part 5: Surge arresters and low-voltage limiters for specific use in d.c. systems
- Part 6: D.C. switchgear assemblies
- Part 7-1: Measurement, control and protection devices for specific use in d.c. traction systems – Application guide
- Part 7-2: Measurement, control and protection devices for specific use in d.c. traction systems – Isolating current transducers and other current measuring devices
- Part 7-3: Measurement, control and protection devices for specific use in d.c. traction systems – Isolating voltage transducers and other voltage measuring devices

The committee has decided that the contents of the base publication and its amendments will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

IMPORTANT – The “colour inside” logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.

The content of the corrigendum 1 (2025-05) has been included in this copy.

RAILWAY APPLICATIONS – FIXED INSTALLATIONS – DC SWITCHGEAR –

Part 6: DC switchgear assemblies

1 Scope

This part of IEC 61992 covers d.c. metal-enclosed and non-metallic enclosed switchgear assemblies used in indoor stationary installations of traction systems, with nominal voltage not exceeding 3 000 V.

It is intended that individual items of equipment, for example circuit breakers, housed in the assembly are designed, manufactured and individually tested (simulating the enclosure when necessary) in accordance with their respective parts of IEC 61992 or, when appropriate, with another applicable standard.

NOTE 1 The requirements covered in this part of IEC 61992 are those concerning the assembly as such, its enclosure and the mutual influence of the equipment enclosed.

NOTE 2 EMC requirements are covered by IEC 62236-5 and additional requirements concerning dependability (RAMS) are covered by IEC 62278.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60243-1:1998, *Electrical strength of insulating materials – Test methods – Part 1: Tests at power frequencies*

IEC 60529:1989, *Degrees of protection provided by enclosures (IP Code)*

IEC 61992-1:2006+A1:2014, *Railway applications – Fixed installations – DC switchgear – Part 1: General*

IEC 61992-2:2006+A1:2014, *Railway applications – Fixed installations – DC switchgear – Part 2: DC circuit-breakers*

IEC 61992-3:2006, *Railway applications – Fixed installations – DC switchgear – Part 3: Indoor d.c. disconnectors, switch-disconnectors and earthing switches*

FINAL VERSION

Railway applications – Fixed installations – DC switchgear – Part 6: DC switchgear assemblies



CONTENTS

1	Scope	6
2	Normative references	6
3	Terms and definitions	6
4	Service requirements	7
5	Characteristics of the assemblies	7
6	Construction characteristics	7
6.1	General	7
6.2	Insulation requirements	8
6.3	Primary connections	9
6.4	Location of the primary connections	9
6.5	Earthing	9
6.5.1	Earthing of the main circuit	9
6.5.2	Earthing of the enclosure	9
6.6	Degree of protection and internal fault	10
6.6.1	Protection against approach to live parts and contact with moving parts	10
6.6.2	Internal arcing	10
6.7	Covers and doors	11
6.8	Inspection windows	11
6.9	Ventilating openings	11
6.10	Partitions and shutters	11
6.10.1	General	11
6.10.2	Partitions	12
6.10.3	Shutters	12
6.10.4	Isolating distances	12
6.11	Interlocks	13
6.12	Temperature-rises	13
6.13	Dielectric strength	14
6.14	Painting and finishing	14
6.15	Noise emission	14
6.16	Cooling and heating	14
6.17	Operating temperature of auxiliary and control equipment	14
6.18	Rated short-time withstand current of busbars	14
7	Information and marking	14
7.1	Information	14
7.2	Marking	15
8	Tests	15
8.1	General	15
8.2	List of the applicable tests	16
8.3	Performance of tests	16
8.3.1	Verification of conformity to the manufacturing drawings and to characteristics of the assembly	16
8.3.2	Operation test	16
8.3.3	Dielectric tests	17
8.3.4	Short-time withstand current tests	19
8.3.5	Mechanical operation test	20

8.3.6	Verification of the degree of protection	21
8.3.7	Temperature-rise tests	21
8.3.8	Electrical operation test	23
8.3.9	Internal arc test	23
Annex A	(informative) Information required	24
A.1	General	24
A.2	Procurement specification	24
A.3	Manufacturer's tender specification	25
A.4	Information and data to be supplied by the manufacturer during the delivery stage	26
Annex B	(normative) Method for testing under conditions of arcing due to an internal fault	28
B.1	Purpose of the test	28
B.2	Characteristics – Rated short-circuit current under internal arcing conditions (I_{Narc})	28
B.3	Test arrangements	28
B.3.1	Test specimen	28
B.3.2	Test circuit	29
B.3.3	Voltage	29
B.3.4	Duration of the test	29
B.4	Test procedure	29
B.4.1	Supply circuit	29
B.4.2	Arc initiation	30
B.4.3	Indicators	31
B.4.4	Repetition of the test	31
B.5	Assessment of the test	31
B.6	Test report	32
Figure 1	– Test arrangement for short-time current withstand test on busbars	20
Figure 2	– Test arrangement for temperature-rise test on main circuits	22
Figure 3	– Test arrangement for temperature-rise test on the busbars	22
Figure B.1	– Room simulation and indicator positioning, functional unit fitted with roof	33
Figure B.2	– Mounting frame for vertical indicators	34
Figure B.3	– Indicators arranged in a checkerboard pattern	34
Table 1	– Degrees of protection	10
Table 2	– List of applicable tests	16
Table B.1	– Sizes of the copper ignition wire	30

INTERNATIONAL ELECTROTECHNICAL COMMISSION

RAILWAY APPLICATIONS – FIXED INSTALLATIONS – DC SWITCHGEAR –

Part 6: DC switchgear assemblies

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendments has been prepared for user convenience.

IEC 61992-6 edition 1.2 contains the first edition (2006-02) [documents 9/891/FDIS and 9/913/RVD], its amendment 1 (2014-04) [documents 9/1792/CDV and 9/1852/RVC] and its amendment 2 (2020-05) [documents 9/2542/CDV and 9/2584A/RVC].

This Final version does not show where the technical content is modified by amendments 1 and 2. A separate Redline version with all changes highlighted is available in this publication.

International Standard IEC 61992-6 has been prepared by IEC technical committee 9: Electrical equipment and systems for railways.

IEC 61992 consists of the following parts, under the general title *Railway applications – Fixed installations – DC switchgear*:

- Part 1: General
- Part 2: D.C. circuit breakers
- Part 3: Indoor d.c. disconnectors, switch-disconnectors and earthing switches
- Part 4: Outdoor d.c. disconnectors, switch-disconnectors and earthing switches
- Part 5: Surge arresters and low-voltage limiters for specific use in d.c. systems
- Part 6: D.C. switchgear assemblies
- Part 7-1: Measurement, control and protection devices for specific use in d.c. traction systems – Application guide
- Part 7-2: Measurement, control and protection devices for specific use in d.c. traction systems – Isolating current transducers and other current measuring devices
- Part 7-3: Measurement, control and protection devices for specific use in d.c. traction systems – Isolating voltage transducers and other voltage measuring devices

The committee has decided that the contents of the base publication and its amendments will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

IMPORTANT – The “colour inside” logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.

The content of the corrigendum 1 (2025-05) has been included in this copy.

RAILWAY APPLICATIONS – FIXED INSTALLATIONS – DC SWITCHGEAR –

Part 6: DC switchgear assemblies

1 Scope

This part of IEC 61992 covers d.c. metal-enclosed and non-metallic enclosed switchgear assemblies used in indoor stationary installations of traction systems, with nominal voltage not exceeding 3 000 V.

It is intended that individual items of equipment, for example circuit breakers, housed in the assembly are designed, manufactured and individually tested (simulating the enclosure when necessary) in accordance with their respective parts of IEC 61992 or, when appropriate, with another applicable standard.

NOTE 1 The requirements covered in this part of IEC 61992 are those concerning the assembly as such, its enclosure and the mutual influence of the equipment enclosed.

NOTE 2 EMC requirements are covered by IEC 62236-5 and additional requirements concerning dependability (RAMS) are covered by IEC 62278.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60243-1:1998, *Electrical strength of insulating materials – Test methods – Part 1: Tests at power frequencies*

IEC 60529:1989, *Degrees of protection provided by enclosures (IP Code)*

IEC 61992-1:2006+A1:2014, *Railway applications – Fixed installations – DC switchgear – Part 1: General*

IEC 61992-2:2006+A1:2014, *Railway applications – Fixed installations – DC switchgear – Part 2: DC circuit-breakers*

IEC 61992-3:2006, *Railway applications – Fixed installations – DC switchgear – Part 3: Indoor d.c. disconnectors, switch-disconnectors and earthing switches*