



IEC 62541-11

Edition 3.0 2025-12

INTERNATIONAL STANDARD

REDLINE VERSION

**OPC unified architecture -
Part 11: Historical Access**

CONTENTS

FOREWORD	5
1 Scope	8
2 Normative references	8
3 Terms, definitions and abbreviations	8
3.1 Terms and definitions	8
3.2 Abbreviated terms	10
4 Concepts	11
4.1 General	11
4.2 Data architecture	11
4.3 Historians and interruption of data collection	12
4.4 Modification of Historical Data/Events	12
4.5 Timestamps	13
4.6 Bounding Values and time domain	13
4.7 Changes in AddressSpace over time	15
5 Historical Information Model	16
5.1 HistoricalNodes	16
5.1.1 General	16
5.1.2 Annotations Property	16
5.2 HistoricalDataNodes	17
5.2.1 General	17
5.2.2 HistoricalDataConfigurationType	17
5.2.3 Attributes	19
5.2.4 Historical Data Configuration Object	19
5.3 References	20
5.3.1 Overview	20
5.3.2 HasHistoricalConfiguration ReferenceType	21
5.3.3 HasCurrentData ReferenceType	21
5.3.4 HasCurrentEvent ReferenceType	22
5.4 HistoricalEventNodes	22
5.4.1 General	22
5.4.2 HistoricalEventFilter Property	22
5.4.3 HistoricalEventConfigurationType	23
5.4.4 HistoricalEventNode Attributes	23
5.5 External History sources	24
5.5.1 General	24
5.5.2 External Historical Event Node	24
5.6 Example Object Models in Historian Servers (informative)	25
5.6.1 Overview	25
5.6.2 HistoricalDataNodes Address Space Model	25
5.6.3 Historical data	27
5.6.4 HistoricalEventNodes Address Space Model	27
5.6.5 Historical Events	30
5.7 Exposing supported functions and capabilities	30
5.7.1 General	30
5.7.2 HistoryServerCapabilitiesType	32
5.7.3 Default configuration	35
5.8 Historical Audit Events	36

5.8.1	General	36
5.8.2	AuditHistoryEventUpdateEventType	36
5.8.3	AuditHistoryValueUpdateEventType	37
5.8.4	AuditHistoryAnnotationUpdateEventType	37
5.8.5	AuditHistoryDeleteEventType	38
5.8.6	AuditHistoryRawModifyDeleteEventType	39
5.8.7	AuditHistoryAtTimeDeleteEventType	40
5.8.8	AuditHistoryEventDeleteEventType	40
5.8.9	AuditHistoryConfigurationChangeEvent	41
5.8.10	AuditHistoryBulkInsertEventType	41
6	Historical Access specific usage of Services	42
6.1	General	42
6.2	Historical Nodes StatusCodes	43
6.2.1	Overview	43
6.2.2	Operation level result codes	43
6.2.3	Semantics changed	45
6.3	Continuation Points	45
6.4	Arrays, index ranges and substrings	45
6.5	HistoryReadDetails parameters	47
6.5.1	Overview	47
6.5.2	ReadEventDetails structure	49
6.5.3	ReadRawModifiedDetails structure	52
6.5.4	ReadProcessedDetails structure	55
6.5.5	ReadAtTimeDetails structure	57
6.5.6	ReadAnnotationDataDetails structure	58
6.6	HistoryData parameters returned	59
6.6.1	Overview	59
6.6.2	HistoryData type	59
6.6.3	HistoryModifiedData type	59
6.6.4	HistoryEvent type DataType	60
6.5.5	HistoryAnnotationData type	
6.6.5	HistoryModifiedEvent DataType	61
6.6.6	Annotation DataType	62
6.7	HistoryUpdateType Enumeration	62
6.8	PerformUpdateType Enumeration	63
6.9	HistoryUpdateDetails parameter	63
6.9.1	Overview	63
6.9.2	UpdateDataDetails structure	65
6.9.3	UpdateStructureDataDetails structure	67
6.9.4	UpdateEventDetails structure	69
6.9.5	DeleteRawModifiedDetails structure	71
6.9.6	DeleteAtTimeDetails structure	72
6.9.7	DeleteEventDetails structure	73
Annex A (informative)	Client conventions	75
A.1	How clients can request timestamps	75
A.2	Determining the first or last historical data point	76
Bibliography	78

Figure 1 – Possible OPC UA Server supporting Historical Access	11
Figure 2 – ReferenceType hierarchy	20
Figure 3 – Historical Variable with Historical Data Configuration and Annotations	26
Figure 4 – Historical Variable with Historical Data Configuration and Annotations	27
Figure 5 – Representation of an Event with History in the AddressSpace	29
Figure 6 – Event History configuration example	30
Figure 7 – Server and HistoryServer Capabilities	32
Figure 8 – History Array example	46
Figure 9 – Historian Array Illustration 2	47
Table 1 – Bounding Value examples	14
Table 2 – Annotations Property	16
Table 3 – HistoricalDataConfigurationType definition	17
Table 4 – ExceptionDeviationFormat Values Items	18
Table 5 – ExceptionDeviationFormat definition	19
Table 6 – Historical Access configuration definition	20
Table 7 – HasHistoricalConfiguration ReferenceType	21
Table 8 – HasCurrentData ReferenceType	21
Table 9 – HasCurrentEvent ReferenceType	22
Table 10 – Standard Historical Events Properties	23
Table 11 – HistoricalEventConfigurationType definition	23
Table 12 – HistoricalExternalEventSourceType definition	24
Table 13 – HistoryServerCapabilitiesType Definition	33
Table 14 – DefaultHAConfiguration definition	35
Table 15 – DefaultHEConfiguration definition	35
Table 16 – AuditHistoryEventUpdateEventType definition	36
Table 17 – AuditHistoryValueUpdateEventType definition	37
Table 18 – AuditHistoryAnnotationUpdateEventType definition	38
Table 19 – AuditHistoryDeleteEventType definition	39
Table 20 – AuditHistoryRawModifyDeleteEventType definition	39
Table 21 – AuditHistoryAtTimeDeleteEventType definition	40
Table 22 – AuditHistoryEventDeleteEventType definition	41
Table 23 – AuditHistoryConfigurationChangeEvent definition	41
Table 24 – AuditHistoryBulkInsertEventType definition	42
Table 25 – Bad operation level result codes	43
Table 26 – Good operation level result codes	44
Table 27 – HistoryReadDetails parameterType parameter Symbolic Names	48
Table 28 – HistoryReadDetails definition	49
Table 29 – ReadEventDetails Structure	49
Table 30 – ReadEventDetails definition	49
Table 31 – ReadEventDetails2 Structure	51
Table 32 – ReadEventDetails2 definition	51
Table 33 – ReadRawModifiedDetails structure	52

Table 34 – ReadRawModifiedDetails definition	52
Table 35 – ReadProcessedDetails structure.....	55
Table 36 – ReadProcessedDetails definition	55
Table 37 – ReadAtTimeDetails structure	57
Table 38 – ReadAtTimeDetails definition	57
Table 39 – ReadAnnotationDataDetails Structure	58
Table 40 – ReadAnnotationDataDetails definition	58
Table 41 – HistoryData-Details structure	59
Table 42 – HistoryData definition	59
Table 43 – HistoryModifiedData-Details structure.....	60
Table 44 – HistoryModifiedData definition	60
Table 45 – HistoryEvent-Details structure	60
Table 46 – HistoryEvent definition	61
Table 47 – HistoryModifiedEvent structure.....	61
Table 48 – HistoryModifiedEvent definition	61
Table 49 – Annotation Structure.....	62
Table 50 – <i>Annotation</i> definition.....	62
Table 51 – HistoryUpdateType-Enumeration Items.....	62
Table 52 – HistoryUpdateType definition.....	63
Table 53 – PerformUpdateType-Enumeration Items	63
Table 54 – PerformUpdateType definition	63
Table 55 – HistoryUpdateDetails parameter-Types Symbolic Names.....	64
Table 56 – HistoryUpdateDetails Structure.....	65
Table 57 – HistoryUpdateDetails definition.....	65
Table 58 – UpdateDataDetails Structure	66
Table 59 – UpdateDataDetails definition	66
Table 60 – UpdateStructureDataDetails Structure	67
Table 61 – UpdateStructureDataDetails definition	68
Table 62 – UpdateEventDetails Structure.....	69
Table 63 – UpdateEventDetails definition.....	70
Table 64 – DeleteRawModifiedDetails Structure	72
Table 65 – DeleteRawModifiedDetails definition.....	72
Table 66 – DeleteAtTimeDetails Structure.....	73
Table 67 – DeleteAtTimeDetails definition.....	73
Table 68 – DeleteEventDetails Structure.....	73
Table 69 – DeleteEventDetails definition.....	74
Table A.1 – Time keyword definitions.....	76
Table A.2 – Time offset definitions	76

INTERNATIONAL ELECTROTECHNICAL COMMISSION

OPC unified architecture - Part 11: Historical Access

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

This redline version of the official IEC Standard allows the user to identify the changes made to the previous edition IEC 62541-11:2020. A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text.

IEC 62541-11 has been prepared by subcommittee 65E: Devices and integration in enterprise systems, of IEC technical committee 65: Industrial-process measurement, control and automation. It is an International Standard.

This fourth edition cancels and replaces the third edition published in 2020. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) a functionality has been added to support retrieving of modified events;
- b) an Event has been added to indicate when a backfill occurred;
- c) a new ReferenceType that can be used to indicate an external node has been defined;
- d) the text has been improved to better explain the concept of annotation and remove conflicting explanations;
- e) a default historian configuration (and where to find it) has been defined;
- f) HistoricalEventConfigurationType, which provides general configuration information about the historical Event storage, has been added;
- g) the text has been updated and optional fields have been added to HA configuration object to allow configuration to be defined for periodic data collection, not just for exception-based collection;
- h) an ObjectType that can be used for external event collection has been provided as well as an example how historians can be configured.

The text of this International Standard is based on the following documents:

Draft	Report on voting
65E/1058/CDV	65E/1096/RVC

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

Throughout this document and the other parts of the IEC 62541 series, certain document conventions are used:

Italics are used to denote a defined term or definition that appears in the "Terms and definitions" clause in one of the parts of the IEC 62541 series.

Italics are also used to denote the name of a service input or output parameter or the name of a structure or element of a structure that are usually defined in tables.

The *italicized terms and names* are, with a few exceptions, written in camel-case (the practice of writing compound words or phrases in which the elements are joined without spaces, with each element's initial letter capitalized within the compound). For example, the defined term is *AddressSpace* instead of Address Space. This makes it easier to understand that there is a single definition for *AddressSpace*, not separate definitions for Address and Space.

A list of all parts in the IEC 62541 series, published under the general title *OPC Unified Architecture*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

1 Scope

This part of IEC 62541 belongs to the OPC Unified Architecture standards series and defines the *Information Model* associated with Historical Access (HA). It particularly includes additional and complementary descriptions of the *NodeClasses* and *Attributes* needed for Historical Access, additional standard *Properties*, and other information and behaviour.

The complete *AddressSpace* Model including all *NodeClasses* and *Attributes* is specified in IEC 62541-3. The predefined *Information Model* is defined in IEC 62541-5. The *Services* to detect and access historical data and events, and description of the *ExtensibleParameter* types are specified in IEC 62541-4.

This document includes functionality to compute and return *Aggregates* like minimum, maximum, average etc. The *Information Model* and the concrete working of *Aggregates* are defined in IEC 62541-13.

Conventions for Historical Access Clients are informatively provided in Annex A.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC ~~TR~~ 62541-1, *OPC Unified Architecture - Part 1: Overview and Concepts*

IEC 62541-3, *OPC Unified Architecture - Part 3: Address Space Model*

IEC 62541-4, *OPC Unified Architecture - Part 4: Services*

IEC 62541-5, *OPC Unified Architecture - Part 5: Information Model*

IEC 62541-7, *OPC Unified Architecture - Part 7: Profiles*

IEC 62541-8, *OPC Unified Architecture - Part 8: Data Access*

IEC 62541-13, *OPC Unified Architecture - Part 13: Aggregates*