



IEC 62705

Edition 2.0 2022-11
REDLINE VERSION

INTERNATIONAL STANDARD



**Nuclear ~~power plants~~ facilities –
Instrumentation and control important to safety – Radiation monitoring
systems (RMS): Characteristics and lifecycle**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 27.120.20

ISBN 978-2-8322-6126-2

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD	4
INTRODUCTION	2
1 Scope	11
2 Normative references	11
3 Terms and definitions	13
4 Symbols and abbreviated terms	17
5 RMS categorization and classification	18
5.1 Function categorization for RMS	18
5.2 System classification for RMS	18
5.3 Criteria for identifying the plant-specific variables	18
6 RMS detailed design and implementation	19
6.1 General	19
6.2 Radioactive noble gas off-line monitoring	19
6.3 Radioactive aerosol off-line monitoring	19
6.4 Radioactive iodine off-line monitoring	20
6.5 Liquid off-line monitoring	20
6.6 Tritium off-line monitoring	20
6.7 On-line or in-line monitoring	20
6.8 Area monitoring	20
6.9 Centralized system	21
6.10 Leak detection	21
7 RMS integration and validation	21
7.1 RMS integration	21
7.2 RMS validation	21
8 RMS installation	21
9 RMS design modification	21
10 RMS qualification	22
10.1 General	22
10.2 Environmental qualification	22
10.3 Seismic qualification	22
10.4 Electromagnetic interference	22
11 Calibration	23
11.1 General	23
11.2 Periodical calibration and functional check	23
11.2.1 General	23
11.2.2 Calibration check after installation	23
11.2.3 Functional check	23
11.2.4 Countermeasures to loss of monitoring during calibration or functional check	23
11.3 Radiation calibration	23
11.4 Calibration for other quantity	23
11.5 Traceability	23
Annex A (informative) Example of safety classification for RMS important to safety	24
Annex B (informative) Relation between IEC 61513 system lifecycle and IEC 62705 requirements	25

Bibliography..... 26

Table 1 – Overview of the standards covering the domain of radiation monitoring ~~in~~
NPPs 7

Table A.1 – Example of safety classification for RMS important to safety 24

Table B.1 – Relation between IEC 61513 system lifecycle and IEC 62705 requirements 25

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**NUCLEAR ~~POWER PLANTS~~ FACILITIES –
INSTRUMENTATION AND CONTROL IMPORTANT TO SAFETY –
RADIATION MONITORING SYSTEMS (RMS):
CHARACTERISTICS AND LIFECYCLE**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This redline version of the official IEC Standard allows the user to identify the changes made to the previous edition IEC 62705:2014. A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text.

IEC 62705 has been prepared by subcommittee 45A: Instrumentation, control and electrical power systems of nuclear facilities, of IEC technical committee 45: Nuclear instrumentation. It is an International Standard.

This second edition cancels and replaces the first edition published in 2014. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) Modification of the title.
- b) To be consistent with the categorization of the accident condition.
- c) To update the references to new standards published since the first edition.
- d) To update the terms and definitions.

The text of this International Standard is based on the following documents:

Draft	Report on voting
45A/1442/FDIS	45A/1451/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

a) Technical background, main issues and organisation of the Standard

~~This IEC standard sets out the requirements for the lifecycle management of radiation monitoring system (RMS) installed in the nuclear power plants (NPPs). This standard is applicable to the equipment of RMS and intended to be used during normal operations and anticipated operational occurrences, as well as, for certain monitors, in accident conditions. This standard may be applicable to other nuclear facilities (e.g. nuclear fuel storage and processing sites) by evaluating the differences from NPPs.~~

~~It is intended that the Standard be used by operators of NPPs (utilities), systems evaluators and by licensors.~~

This IEC standard sets out the requirements for the lifecycle management of radiation monitoring systems (RMS) installed in the nuclear facilities (e.g. nuclear power plants, nuclear fuel storage and processing sites).

This document is applicable to the equipment of RMS and intended for use during normal operations, anticipated operational occurrence (AOO), design basis accidents (DBA) and design extension conditions (DEC) including severe accidents (SA).

The document is intended for use by operators of nuclear facilities (utilities), systems evaluators and by licensors.

b) Situation of the current Standard in the structure of the IEC SC 45A standard series

IEC 62705 is the third level in the hierarchy of SC 45A standards. This document provides guidance on the application of existing IEC/ISO standards covering design and qualification of system and equipment for RMS. This document is an application supplement of IEC 61513 as shown in Annex B, and it is not intended that this document limits the application of other IEC 61513 requirements to RMS lifecycle.

For general requirements and guidance, the following standards provide requirements and guidance for RMS. IEC 61513 is the first level standard of SC 45A standards, and provides general requirements for I&C systems and equipment that are used to perform functions important to safety in ~~NPPs~~ nuclear facilities. IEC 61226 provides the criteria for classification of instrumentation and control functions. Most modern RMSs contain computer-based equipment. Hence RMS should often be treated as computer-based system. So the following standards required for computer-based system are generally applicable to RMS. IEC 60880 provides the software requirements for category A functions and IEC 62138 provides the software requirements for Category B or C functions. IEC 60987 provides hardware design requirements for computer-based systems. IEC 62566 provides the requirements for HDL-Programmed Device (HPD) for systems performing category A functions. IEC 62645 provides security requirements for computer based I&C systems. For qualification testing, the following SC 45A standards are applicable. IEC/IEEE 60780-323 provides guidance for the environmental qualification and IEC/IEEE 60980-344 provides guidance for seismic qualification for equipment performing category A or B functions. IEC 62003 provides the requirements for electromagnetic compatibility testing. In addition, IEC 61250 specifies the leak detection requirements by using RMS.

For radiation monitoring specific requirements, the following standards provide requirements and guidance for RMS. The IEC 60951 series provides guidance on the design and testing of radiation monitoring equipment used for ~~accident and post-accident conditions~~ anticipated operational occurrences (AOO), design basis accidents (DBA) and design extension conditions (DEC) including severe accident (SA). The IEC 60761 series provide requirements for equipment for continuous off-line monitoring of radioactivity in gaseous effluent in normal conditions. Some of the SC 45B standards (e.g. Gas offline: IEC 62302, Tritium: IEC 62303) are now replacing the IEC 60761 series. IEC 60861 provides requirements for equipment continuous off-line monitoring of radioactivity in liquid effluent in normal conditions. IEC 60768 provides requirements for equipment for continuous in-line and on-line monitoring of radioactivity in process stream in normal and incident conditions. IEC 61031 provides requirements for equipment for area radiation monitor in normal conditions in conjunction with IEC 60532. IEC 61504 provides requirements for centralized system for plant-wide radiation monitoring in conjunction with

the IEC 61559 series which specifies the requirements for centralized system. If the centralized system is a part of the safety parameter display system, IEC 60960 provides the functional design criteria. ISO 2889 gives guidance on gas and particulate sampling. The ISO 4037 series provides calibration methodology for radiation monitors.

The relationship between these various standards is given in Table 1.

IEC 63147/IEEE Std 497™ provides general guidance for accident monitoring instrumentation. IEEE Std 497™ was directly adopted as a joint logo standard and a technical report, IEC TR 63123, was prepared to discuss the application of the joint standard within the IEC context.

The structure of this standard is adapted from the structure of IEC 63147/IEEE Std 497™, and the technical requirements of this standard are consistent with the requirements given in IEC 63147/IEEE Std 497™ together with the application guidance given in IEC TR 63123.

For more details on the structure of the IEC SC 45A standard series, see item d) of this introduction.

Table 1 – Overview of the standards covering the domain of radiation monitoring ~~in NPPs~~

Developer	ISO		IEC		
			SC-45A	SC-45B	
Scope	Sampling	Calibration	Accident and post-accident conditions	Normal conditions	
Radioactive noble gas off-line monitoring	ISO-2889	ISO-4037-1, ISO-4037-3	IEC-60951-1, IEC-60951-2	N/A	IEC-62302-1, IEC-60761-1, IEC-60761-3
Radioactive aerosol off-line monitoring	ISO-2889	ISO-4037-1, ISO-4037-3	IEC-60951-1, IEC-60951-2	N/A	IEC-60761-1, IEC-60761-2
Radioactive iodine off-line monitoring	ISO-2889	ISO-4037-1, ISO-4037-3	IEC-60951-1, IEC-60951-2	N/A	IEC-60761-1, IEC-60761-4
Liquid off-line monitoring	N/A	N/A	N/A	N/A	IEC-60861
Tritium off-line monitoring	N/A	N/A	N/A	N/A	IEC-62303-1, IEC-60761-1, IEC-60761-5
On-line or in-line monitoring	N/A	ISO-4037-1, ISO-4037-3	IEC-60951-1, IEC-60951-4	IEC-60768	N/A
Area monitoring	N/A	ISO-4037-1, ISO-4037-3	IEC-60951-1, IEC-60951-3	IEC-61031	IEC-60532
Centralized system	N/A	N/A	IEC-61504, IEC-60960		IEC-61559-1
Classification/basic requirements	N/A	N/A	IEC-61513, IEC-60880, IEC-60987, IEC-61226, IEC-62138, IEC-62566, IEC-62645, IEC-61250		N/A
Qualification	N/A	N/A	IEC-60780, IEC-60980, IEC-62003		IEC-62706

Developer	ISO		IEC			
				SC45A		SC45B
Scope	Sampling (Normal operation)	Calibration (Normal operation)	Normal operation, AOO	DBA	DEC	Normal operation
Radioactive noble gas off-line monitoring	ISO 2889	ISO 4037-1, ISO 4037-3	N/A	IEC 60951-1, IEC 60951-2	N/A	IEC 62302, IEC 60761-1, IEC 60761-3
Radioactive aerosol off-line monitoring	ISO 2889	ISO 4037-1, ISO 4037-3	N/A	IEC 60951-1, IEC 60951-2	N/A	IEC 60761-1, IEC 60761-2
Radioactive iodine off-line monitoring	ISO 2889	ISO 4037-1, ISO 4037-3	N/A	IEC 60951-1, IEC 60951-2	N/A	IEC 60761-1, IEC 60761-4
Liquid off-line monitoring	N/A	N/A	N/A	N/A	N/A	IEC 60861
Tritium off-line monitoring	N/A	N/A	N/A	N/A	N/A	IEC 62303, IEC 60761-1, IEC 60761-5
On-line or in-line monitoring	N/A	ISO 4037-1, ISO 4037-3	IEC 60768	IEC 60951-1, IEC 60951-4	N/A	N/A
Area monitoring	N/A	ISO 4037-1, ISO 4037-3	IEC 61031	IEC 60951-1, IEC 60951-3		IEC 60532
Centralized system	N/A	N/A	IEC 61504, IEC 60960		N/A	IEC 61559-1
Classification/basic requirements	N/A	N/A	IEC 61513, IEC 60880, IEC 60987, IEC 61226, IEC 62138, IEC 62566, IEC 62566-2, IEC 62645, IEC 61250		N/A	N/A
Qualification	N/A	N/A	IEC/IEEE 60780-323, IEC/IEEE 60980-344, IEC 62003		N/A	IEC 62706

~~For more details on the structure of the IEC SC 45A standard series, see item d) of this introduction.~~

c) Recommendations and limitations regarding the application of this Standard

It is important to note that this document establishes no additional functional requirements for ~~safety~~ systems important to safety. Where requirements are given in this standard, they refer generally to the need to apply other IEC and ISO Standards and specific functional and technical requirements contained in these standards.

To ensure that the document will continue to be relevant in future years, the emphasis has been placed on issues of principle, rather than specific technologies.

d) Description of the structure of the IEC SC 45A standard series and relationships with other IEC documents and other bodies documents (IAEA, ISO)

~~The top-level document of the IEC SC 45A standard series is IEC 61513. It provides general requirements for I&C systems and equipment that are used to perform functions important to safety in NPPs. IEC 61513 structures the IEC SC 45A standard series.~~

~~IEC 61513 refers directly to other IEC SC 45A standards for general topics related to categorization of functions and classification of systems, qualification, separation of systems, defence against common cause failure, software aspects of computer-based systems, hardware aspects of computer-based systems, and control room design. The standards referenced directly at this second level should be considered together with IEC 61513 as a consistent document set.~~

~~At a third level, IEC SC 45A standards not directly referenced by IEC 61513 are standards related to specific equipment, technical methods, or specific activities. Usually these~~

~~documents, which make reference to second-level documents for general topics, can be used on their own.~~

~~A fourth level extending the IEC SC 45A standard series, corresponds to the Technical Reports which are not normative.~~

~~IEC 61513 has adopted a presentation format similar to the basic safety publication IEC 61508 with an overall safety life-cycle framework and a system life-cycle framework. Regarding nuclear safety, it provides the interpretation of the general requirements of IEC 61508-1, IEC 61508-2 and IEC 61508-4, for the nuclear application sector, regarding nuclear safety. In this framework IEC 60880 and IEC 62138 correspond to IEC 61508-3 for the nuclear application sector. IEC 61513 refers to ISO as well as to IAEA GS-R-3 and IAEA GS-G-3.1 and IAEA GS-G-3.5 for topics related to quality assurance (QA).~~

~~The IEC SC 45A standards series consistently implements and details the principles and basic safety aspects provided in the IAEA code on the safety of NPPs and in the IAEA safety series, in particular the Requirements NS-R-1, establishing safety requirements related to the design of Nuclear Power Plants, and the Safety Guide NS-G-1.3 dealing with instrumentation and control systems important to safety in Nuclear Power Plants. The terminology and definitions used by SC 45A standards are consistent with those used by the IAEA.~~

The IEC SC 45A standard series comprises a hierarchy of four levels. The top-level documents of the IEC SC 45A standard series are IEC 61513 and IEC 63046.

IEC 61513 provides general requirements for instrumentation and control (I&C) systems and equipment that are used to perform functions important to safety in nuclear power plants (NPPs). IEC 63046 provides general requirements for electrical power systems of NPPs; it covers power supply systems including the supply systems of the I&C systems.

IEC 61513 and IEC 63046 are to be considered in conjunction and at the same level. IEC 61513 and IEC 63046 structure the IEC SC 45A standard series and shape a complete framework establishing general requirements for instrumentation, control and electrical power systems for nuclear power plants.

IEC 61513 and IEC 63046 refer directly to other IEC SC 45A standards for general requirements for specific topics, such as categorization of functions and classification of systems, qualification, separation, defence against common cause failure, control room design, electromagnetic compatibility, human factors engineering, cybersecurity, software and hardware aspects for programmable digital systems, coordination of safety and security requirements and management of ageing. The standards referenced directly at this second level should be considered together with IEC 61513 and IEC 63046 as a consistent document set.

At a third level, IEC SC 45A standards not directly referenced by IEC 61513 or by IEC 63046 are standards related to specific requirements for specific equipment, technical methods, or activities. Usually these documents, which make reference to second-level documents for general requirements, can be used on their own.

A fourth level extending the IEC SC 45 standard series, corresponds to the Technical Reports which are not normative.

The IEC SC 45A standards series consistently implements and details the safety and security principles and basic aspects provided in the relevant IAEA safety standards and in the relevant documents of the IAEA nuclear security series (NSS). In particular this includes the IAEA requirements SSR-2/1, establishing safety requirements related to the design of nuclear power plants (NPPs), the IAEA safety guide SSG-30 dealing with the safety classification of structures, systems and components in NPPs, the IAEA safety guide SSG-39 dealing with the design of instrumentation and control systems for NPPs, the IAEA safety guide SSG-34 dealing with the design of electrical power systems for NPPs, the IAEA safety guide SSG-51 dealing with human factors engineering in the design of NPPs and the implementing guide NSS17 for computer security at nuclear facilities. The safety and security terminology and definitions used by the SC 45A standards are consistent with those used by the IAEA.

IEC 61513 and IEC 63046 have adopted a presentation format similar to the basic safety publication IEC 61508 with an overall life-cycle framework and a system life-cycle framework. Regarding nuclear safety, IEC 61513 and IEC 63046 provide the interpretation

of the general requirements of IEC 61508-1, IEC 61508-2 and IEC 61508-4, for the nuclear application sector. In this framework, IEC 60880, IEC 62138 and IEC 62566 correspond to IEC 61508-3 for the nuclear application sector.

IEC 61513 and IEC 63046 refer to ISO 9001 as well as to IAEA GSR part 2 and IAEA GS-G-3.1 and IAEA GS-G-3.5 for topics related to quality assurance (QA).

At level 2, regarding nuclear security, IEC 62645 is the entry document for the IEC/SC 45A security standards. It builds upon the valid high level principles and main concepts of the generic security standards, in particular ISO/IEC 27001 and ISO/IEC 27002; it adapts them and completes them to fit the nuclear context and coordinates with the IEC 62443 series. At level 2, IEC 60964 is the entry document for the IEC/SC 45A control rooms standards, IEC 63351 is the entry document for the human factors engineering standards and IEC 62342 is the entry document for the ageing management standards.

NOTE 1 It is assumed that for the design of I&C systems in NPPs that implement conventional safety functions (e.g. to address worker safety, asset protection, chemical hazards, process energy hazards) international or national standards would be applied, ~~that are based on the requirements of a standard such as IEC 61508.~~

NOTE 2 IEC TR 64000 provides a more comprehensive description of the overall structure of the IEC SC 45A standards series and of its relationship with other standards bodies and standards.

NUCLEAR ~~POWER PLANTS~~ FACILITIES – INSTRUMENTATION AND CONTROL IMPORTANT TO SAFETY – RADIATION MONITORING SYSTEMS (RMS): CHARACTERISTICS AND LIFECYCLE

1 Scope

~~This International Standard applies to radiation monitoring system (RMS) installed in the nuclear power plants (NPPs).~~ This document gives requirements for the lifecycle management of radiation monitoring systems (RMS) and gives guidance on the application of existing IEC standards covering the design and qualification of systems and equipment.

~~This International Standard is applicable to RMSs intended to be used during normal operations and anticipated operational occurrences, and to be used during and/or after accident conditions. The technical guidance contained in this Standard applies to NPPs, although the specific functions of individual facilities shall be considered during the design and operational lifecycle of RMS.~~ The purpose of this document is to lay down requirements for the lifecycle management of RMSs and give application guidance. This document is intended to be consistent with the latest versions of International Standards dealing with radiation monitors, sampling of radioactive materials, instruments calibration, hardware and software design, classification, and qualification. Unless otherwise specified in this document, top level IEC SC 45A standard, IEC 61513, and the second level IEC SC 45A standards apply to RMSs.

~~This standard may be applicable to other nuclear facilities (e.g. nuclear fuel storage and processing sites) by evaluating the differences from NPPs.~~

This document is applicable to RMSs installed in nuclear facilities intended for use during normal operation, anticipated operational occurrences (AOO), design basis accidents (DBA) and design extension conditions (DEC), including severe accidents (SA). The technical guidance contained in this document applies to nuclear facilities, although the specific functions of individual facilities are considered during the design and operational lifecycle of RMSs.

Laboratory analysis and associated sample extraction, which are essential to a complete programme of effluent monitoring, and investigation for fuel removal are not in the scope of this document.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60532, *Radiation protection instrumentation – Installed dose rate meters, warning assemblies and monitors – X and gamma radiation of energy between 50 keV and 7 MeV*

IEC 60761-1, *Equipment for continuous monitoring of radioactivity in gaseous effluents – Part 1: General requirements*

IEC 60761-2, *Equipment for continuous monitoring of radioactivity in gaseous effluents – Part 2: Specific requirements for radioactive aerosol monitors including transuranic aerosols*

IEC 60761-3, *Equipment for continuous monitoring of radioactivity in gaseous effluents – Part 3: Specific requirements for radioactive noble gas monitors*

IEC 60761-4, *Equipment for continuous monitoring of radioactivity in gaseous effluents – Part 4: Specific requirements for radioactive iodine monitors*

IEC 60761-5, *Equipment for continuous monitoring of radioactivity in gaseous effluents – Part 5: Specific requirements for tritium monitors*

IEC 60768, *Nuclear power plants – Instrumentation important to safety – Equipment for continuous in-line or on-line monitoring of radioactivity in process streams for normal and incident conditions*

~~IEC 60780:1998, Nuclear power plants – Electrical equipment of the safety system – Qualification~~

IEC/IEEE 60780-323:2016, *Nuclear facilities – Electrical equipment important to safety system – Qualification*

IEC 60861, *Equipment for monitoring of radionuclides in liquid effluents and surface waters*

IEC 60880, *Nuclear power plants – Instrumentation and control systems important to safety – Software aspects for computer-based systems performing category A functions*

IEC 60951-1:2022, *Nuclear power plants – Instrumentation important to safety – Radiation monitoring for accident and post-accident conditions – Part 1: General requirements*

IEC 60951-2, *Nuclear power plants – Instrumentation important to safety – Radiation monitoring for accident and post-accident conditions – Part 2: Equipment for continuous off-line monitoring of radioactivity in gaseous effluents and ventilation air*

IEC 60951-3, *Nuclear power plants – Instrumentation important to safety – Radiation monitoring for accident and post-accident conditions – Part 3: Equipment for continuous high range area gamma monitoring*

IEC 60951-4, *Nuclear power plants – Instrumentation important to safety – Radiation monitoring for accident and post-accident conditions – Part 4: Equipment for continuous in-line or on-line monitoring of radioactivity in process streams*

IEC 60960, *Functional design criteria for a safety parameter display system for nuclear power stations*

~~IEC 60980, Recommended practices for Seismic qualification of electrical equipment of the safety system for nuclear generating stations~~

IEC/IEEE 60980-344, *Nuclear facilities – Equipment important to safety – Seismic qualification*

IEC 60987, *Nuclear power plants – Instrumentation and control important to safety – Hardware ~~design~~ requirements ~~for computer-based systems~~*

IEC 61031, *Nuclear facilities – Instrumentation and control systems – Design, location and application criteria for installed area gamma radiation dose rate monitoring equipment for use ~~in nuclear power plants~~ during normal operation and anticipated operational occurrences*

IEC 61226:2009/2020, *Nuclear power plants – ~~Instrumentation and control important to safety – Classification of instrumentation and control functions~~ Instrumentation, control and electrical power systems important to safety – Categorization of functions and classification of systems*

IEC 61250, *Nuclear reactors – Instrumentation and control systems important for safety – Detection of leakage in coolant systems*

IEC 61504, *Nuclear ~~power plants~~ facilities – Instrumentation and control systems important to safety – ~~Plant-wide radiation monitoring~~ Centralized systems for continuous monitoring of radiation and/or levels of radioactivity*

IEC 61513:2011, *Nuclear power plants – Instrumentation and control important to safety – General requirements for systems*

IEC 61559 (all parts), *Radiation protection instrumentation in nuclear facilities – Centralized systems for continuous monitoring of radiation and/or levels of radioactivity*

IEC 62003, *Nuclear power plants – ~~Instrumentation and control important to safety~~ Instrumentation, control and electrical power systems – Requirements for electromagnetic compatibility testing*

IEC 62138, *Nuclear power plants – Instrumentation and control systems important ~~for~~ to safety – Software aspects for computer-based systems performing category B or C functions*

IEC 62302, *Radiation protection instrumentation – Equipment for sampling and monitoring radioactive noble gases*

IEC 62303, *Radiation protection instrumentation – Equipment for monitoring airborne tritium*

IEC 62566:2012, *Nuclear power plants – Instrumentation and control important to safety – Development of HDL-programmed integrated circuits for systems performing category A functions*

IEC 62566-2, *Nuclear power plants – Instrumentation and control systems important to safety – Development of HDL-programmed integrated circuits – Part 2: HDL-programmed integrated circuits for systems performing category B or C functions*

IEC 63147:2017/IEEE Std 497™, *Criteria for accident monitoring instrumentation for nuclear power generation stations*

ISO/IEC 17025, *General requirements for the competence of testing and calibration laboratories*

ISO 2889, *Sampling airborne radioactive materials from the stacks and ducts of nuclear facilities*

ISO 4037-1, *Radiological protection – X and gamma reference radiation for calibrating dosimeters and dose rate meters and for determining their response as a function of photon energy – Part 1: Radiation characteristics and production methods*

ISO 4037-3, *Radiological protection – X and gamma reference radiation for calibrating dosimeters and dose rate meters and for determining their response as a function of photon energy – Part 3: Calibration of area and personal dosimeters and the measurement of their response as a function of energy and angle of incidence*

INTERNATIONAL STANDARD

NORME INTERNATIONALE



Nuclear facilities – Instrumentation and control important to safety – Radiation monitoring systems (RMS): Characteristics and lifecycle

Installations nucléaires – Instrumentation et contrôle commande importants pour la sûreté – Systèmes de surveillance des rayonnements (RMS): Caractéristiques et cycle de vie

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	9
2 Normative references	9
3 Terms and definitions	11
4 Symbols and abbreviated terms.....	15
5 RMS categorization and classification.....	16
5.1 Function categorization for RMS	16
5.2 System classification for RMS.....	16
5.3 Criteria for identifying the plant-specific variables	16
6 RMS detailed design and implementation	16
6.1 General.....	16
6.2 Radioactive noble gas off-line monitoring.....	17
6.3 Radioactive aerosol off-line monitoring	17
6.4 Radioactive iodine off-line monitoring	17
6.5 Liquid off-line monitoring.....	18
6.6 Tritium off-line monitoring	18
6.7 On-line or in-line monitoring.....	18
6.8 Area monitoring	18
6.9 Centralized system	18
6.10 Leak detection	18
7 RMS integration and validation	19
7.1 RMS integration	19
7.2 RMS validation.....	19
8 RMS installation	19
9 RMS design modification	19
10 RMS qualification	19
10.1 General.....	19
10.2 Environmental qualification	20
10.3 Seismic qualification	20
10.4 Electromagnetic interference.....	20
11 Calibration.....	20
11.1 General.....	20
11.2 Periodical calibration and functional check.....	20
11.2.1 General	20
11.2.2 Calibration check after installation	20
11.2.3 Functional check.....	21
11.2.4 Countermeasures to loss of monitoring during calibration or functional check.....	21
11.3 Radiation calibration	21
11.4 Calibration for other quantity.....	21
11.5 Traceability	21
Annex A (informative) Example of safety classification for RMS important to safety	22
Annex B (informative) Relation between IEC 61513 system lifecycle and IEC 62705 requirements.....	23

Bibliography..... 24

Table 1 – Overview of the standards covering the domain of radiation monitoring7

Table A.1 – Example of safety classification for RMS important to safety 22

Table B.1 – Relation between IEC 61513 system lifecycle and IEC 62705 requirements 23

INTERNATIONAL ELECTROTECHNICAL COMMISSION

NUCLEAR FACILITIES – INSTRUMENTATION AND CONTROL IMPORTANT TO SAFETY – RADIATION MONITORING SYSTEMS (RMS): CHARACTERISTICS AND LIFECYCLE

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 62705 has been prepared by subcommittee 45A: Instrumentation, control and electrical power systems of nuclear facilities, of IEC technical committee 45: Nuclear instrumentation. It is an International Standard.

This second edition cancels and replaces the first edition published in 2014. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) Modification of the title.
- b) To be consistent with the categorization of the accident condition.
- c) To update the references to new standards published since the first edition.
- d) To update the terms and definitions.

The text of this International Standard is based on the following documents:

Draft	Report on voting
45A/1442/FDIS	45A/1451/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

INTRODUCTION

a) Technical background, main issues and organisation of the Standard

This IEC standard sets out the requirements for the lifecycle management of radiation monitoring systems (RMS) installed in the nuclear facilities (e.g. nuclear power plants, nuclear fuel storage and processing sites).

This document is applicable to the equipment of RMS and intended for use during normal operations, anticipated operational occurrence (AOO), design basis accidents (DBA) and design extension conditions (DEC) including severe accidents (SA).

The document is intended for use by operators of nuclear facilities (utilities), systems evaluators and by licensors.

b) Situation of the current Standard in the structure of the IEC SC 45A standard series

IEC 62705 is the third level in the hierarchy of SC 45A standards. This document provides guidance on the application of existing IEC/ISO standards covering design and qualification of system and equipment for RMS. This document is an application supplement of IEC 61513 as shown in Annex B, and it is not intended that this document limits the application of other IEC 61513 requirements to RMS lifecycle.

For general requirements and guidance, the following standards provide requirements and guidance for RMS. IEC 61513 is the first level standard of SC 45A standards, and provides general requirements for I&C systems and equipment that are used to perform functions important to safety in nuclear facilities. IEC 61226 provides the criteria for classification of instrumentation and control functions. Most modern RMSs contain computer-based equipment. Hence RMS should often be treated as computer-based system. So the following standards required for computer-based system are generally applicable to RMS. IEC 60880 provides the software requirements for category A functions and IEC 62138 provides the software requirements for Category B or C functions. IEC 60987 provides hardware design requirements for computer-based systems. IEC 62566 provides the requirements for HDL-Programmed Device (HPD) for systems performing category A functions. IEC 62645 provides security requirements for computer based I&C systems. For qualification testing, the following SC 45A standards are applicable. IEC/IEEE 60780-323 provides guidance for the environmental qualification and IEC/IEEE 60980-344 provides guidance for seismic qualification for equipment performing category A or B functions. IEC 62003 provides the requirements for electromagnetic compatibility testing. In addition, IEC 61250 specifies the leak detection requirements by using RMS.

For radiation monitoring specific requirements, the following standards provide requirements and guidance for RMS. The IEC 60951 series provides guidance on the design and testing of radiation monitoring equipment used for anticipated operational occurrences (AOO), design basis accidents (DBA) and design extension conditions (DEC) including severe accident (SA). The IEC 60761 series provide requirements for equipment for continuous off-line monitoring of radioactivity in gaseous effluent in normal conditions. Some of the SC 45B standards (e.g. Gas offline: IEC 62302, Tritium: IEC 62303) are now replacing the IEC 60761 series. IEC 60861 provides requirements for equipment continuous off-line monitoring of radioactivity in liquid effluent in normal conditions. IEC 60768 provides requirements for equipment for continuous in-line and on-line monitoring of radioactivity in process stream in normal and incident conditions. IEC 61031 provides requirements for equipment for area radiation monitor in normal conditions in conjunction with IEC 60532. IEC 61504 provides requirements for centralized system for plant-wide radiation monitoring in conjunction with the IEC 61559 series which specifies the requirements for centralized system. If the centralized system is a part of the safety parameter display system, IEC 60960 provides the functional design criteria. ISO 2889 gives guidance on gas and particulate sampling. The ISO 4037 series provides calibration methodology for radiation monitors.

The relationship between these various standards is given in Table 1.

IEC 63147/IEEE Std 497™ provides general guidance for accident monitoring instrumentation. IEEE Std 497™ was directly adopted as a joint logo standard and a technical report, IEC TR 63123, was prepared to discuss the application of the joint standard within the IEC context.

The structure of this standard is adapted from the structure of IEC 63147/IEEE Std 497™, and the technical requirements of this standard are consistent with the requirements given in IEC 63147/IEEE Std 497™ together with the application guidance given in IEC TR 63123.

For more details on the structure of the IEC SC 45A standard series, see item d) of this introduction.

Table 1 – Overview of the standards covering the domain of radiation monitoring

Developer	ISO		IEC		SC45A	SC45B
Scope	Sampling (Normal operation)	Calibration (Normal operation)	Normal operation, AOO	DBA	DEC	Normal operation
Radioactive noble gas off-line monitoring	ISO 2889	ISO 4037-1, ISO 4037-3	N/A	IEC 60951-1, IEC 60951-2	N/A	IEC 62302, IEC 60761-1, IEC 60761-3
Radioactive aerosol off-line monitoring	ISO 2889	ISO 4037-1, ISO 4037-3	N/A	IEC 60951-1, IEC 60951-2	N/A	IEC 60761-1, IEC 60761-2
Radioactive iodine off-line monitoring	ISO 2889	ISO 4037-1, ISO 4037-3	N/A	IEC 60951-1, IEC 60951-2	N/A	IEC 60761-1, IEC 60761-4
Liquid off-line monitoring	N/A	N/A	N/A	N/A	N/A	IEC 60861
Tritium off-line monitoring	N/A	N/A	N/A	N/A	N/A	IEC 62303, IEC 60761-1, IEC 60761-5
On-line or in-line monitoring	N/A	ISO 4037-1, ISO 4037-3	IEC 60768	IEC 60951-1, IEC 60951-4	N/A	N/A
Area monitoring	N/A	ISO 4037-1, ISO 4037-3	IEC 61031	IEC 60951-1, IEC 60951-3		IEC 60532
Centralized system	N/A	N/A	IEC 61504, IEC 60960		N/A	IEC 61559-1
Classification/basic requirements	N/A	N/A	IEC 61513, IEC 60880, IEC 60987, IEC 61226, IEC 62138, IEC 62566, IEC 62566-2, IEC 62645, IEC 61250		N/A	N/A
Qualification	N/A	N/A	IEC/IEEE 60780-323, IEC/IEEE 60980-344, IEC 62003		N/A	IEC 62706

c) Recommendations and limitations regarding the application of this Standard

It is important to note that this document establishes no additional functional requirements for systems important to safety. Where requirements are given in this standard, they refer generally to the need to apply other IEC and ISO Standards and specific functional and technical requirements contained in these standards.

To ensure that the document will continue to be relevant in future years, the emphasis has been placed on issues of principle, rather than specific technologies.

d) Description of the structure of the IEC SC 45A standard series and relationships with other IEC documents and other bodies documents (IAEA, ISO)

The IEC SC 45A standard series comprises a hierarchy of four levels. The top-level documents of the IEC SC 45A standard series are IEC 61513 and IEC 63046.

IEC 61513 provides general requirements for instrumentation and control (I&C) systems and equipment that are used to perform functions important to safety in nuclear power plants (NPPs). IEC 63046 provides general requirements for electrical power systems of NPPs; it covers power supply systems including the supply systems of the I&C systems.

IEC 61513 and IEC 63046 are to be considered in conjunction and at the same level. IEC 61513 and IEC 63046 structure the IEC SC 45A standard series and shape a complete framework establishing general requirements for instrumentation, control and electrical power systems for nuclear power plants.

IEC 61513 and IEC 63046 refer directly to other IEC SC 45A standards for general requirements for specific topics, such as categorization of functions and classification of systems, qualification, separation, defence against common cause failure, control room design, electromagnetic compatibility, human factors engineering, cybersecurity, software and hardware aspects for programmable digital systems, coordination of safety and security requirements and management of ageing. The standards referenced directly at this second level should be considered together with IEC 61513 and IEC 63046 as a consistent document set.

At a third level, IEC SC 45A standards not directly referenced by IEC 61513 or by IEC 63046 are standards related to specific requirements for specific equipment, technical methods, or activities. Usually these documents, which make reference to second-level documents for general requirements, can be used on their own.

A fourth level extending the IEC SC 45 standard series, corresponds to the Technical Reports which are not normative.

The IEC SC 45A standards series consistently implements and details the safety and security principles and basic aspects provided in the relevant IAEA safety standards and in the relevant documents of the IAEA nuclear security series (NSS). In particular this includes the IAEA requirements SSR-2/1, establishing safety requirements related to the design of nuclear power plants (NPPs), the IAEA safety guide SSG-30 dealing with the safety classification of structures, systems and components in NPPs, the IAEA safety guide SSG-39 dealing with the design of instrumentation and control systems for NPPs, the IAEA safety guide SSG-34 dealing with the design of electrical power systems for NPPs, the IAEA safety guide SSG-51 dealing with human factors engineering in the design of NPPs and the implementing guide NSS17 for computer security at nuclear facilities. The safety and security terminology and definitions used by the SC 45A standards are consistent with those used by the IAEA.

IEC 61513 and IEC 63046 have adopted a presentation format similar to the basic safety publication IEC 61508 with an overall life-cycle framework and a system life-cycle framework. Regarding nuclear safety, IEC 61513 and IEC 63046 provide the interpretation of the general requirements of IEC 61508-1, IEC 61508-2 and IEC 61508-4, for the nuclear application sector. In this framework, IEC 60880, IEC 62138 and IEC 62566 correspond to IEC 61508-3 for the nuclear application sector.

IEC 61513 and IEC 63046 refer to ISO 9001 as well as to IAEA GSR part 2 and IAEA GS-G-3.1 and IAEA GS-G-3.5 for topics related to quality assurance (QA).

At level 2, regarding nuclear security, IEC 62645 is the entry document for the IEC/SC 45A security standards. It builds upon the valid high level principles and main concepts of the generic security standards, in particular ISO/IEC 27001 and ISO/IEC 27002; it adapts them and completes them to fit the nuclear context and coordinates with the IEC 62443 series. At level 2, IEC 60964 is the entry document for the IEC/SC 45A control rooms standards, IEC 63351 is the entry document for the human factors engineering standards and IEC 62342 is the entry document for the ageing management standards.

NOTE 1 It is assumed that for the design of I&C systems in NPPs that implement conventional safety functions (e.g. to address worker safety, asset protection, chemical hazards, process energy hazards) international or national standards would be applied.

NOTE 2 IEC TR 64000 provides a more comprehensive description of the overall structure of the IEC SC 45A standards series and of its relationship with other standards bodies and standards.

NUCLEAR FACILITIES – INSTRUMENTATION AND CONTROL IMPORTANT TO SAFETY – RADIATION MONITORING SYSTEMS (RMS): CHARACTERISTICS AND LIFECYCLE

1 Scope

This document gives requirements for the lifecycle management of radiation monitoring systems (RMS) and gives guidance on the application of existing IEC standards covering the design and qualification of systems and equipment.

The purpose of this document is to lay down requirements for the lifecycle management of RMSs and give application guidance. This document is intended to be consistent with the latest versions of International Standards dealing with radiation monitors, sampling of radioactive materials, instruments calibration, hardware and software design, classification, and qualification. Unless otherwise specified in this document, top level IEC SC 45A standard, IEC 61513, and the second level IEC SC 45A standards apply to RMSs.

This document is applicable to RMSs installed in nuclear facilities intended for use during normal operation, anticipated operational occurrences (AOO), design basis accidents (DBA) and design extension conditions (DEC), including severe accidents (SA). The technical guidance contained in this document applies to nuclear facilities, although the specific functions of individual facilities are considered during the design and operational lifecycle of RMSs.

Laboratory analysis and associated sample extraction, which are essential to a complete programme of effluent monitoring, and investigation for fuel removal are not in the scope of this document.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60532, *Radiation protection instrumentation – Installed dose rate meters, warning assemblies and monitors – X and gamma radiation of energy between 50 keV and 7 MeV*

IEC 60761-1, *Equipment for continuous monitoring of radioactivity in gaseous effluents – Part 1: General requirements*

IEC 60761-2, *Equipment for continuous monitoring of radioactivity in gaseous effluents – Part 2: Specific requirements for radioactive aerosol monitors including transuranic aerosols*

IEC 60761-3, *Equipment for continuous monitoring of radioactivity in gaseous effluents – Part 3: Specific requirements for radioactive noble gas monitors*

IEC 60761-4, *Equipment for continuous monitoring of radioactivity in gaseous effluents – Part 4: Specific requirements for radioactive iodine monitors*

IEC 60761-5, *Equipment for continuous monitoring of radioactivity in gaseous effluents – Part 5: Specific requirements for tritium monitors*

IEC 60768, *Nuclear power plants – Instrumentation important to safety – Equipment for continuous in-line or on-line monitoring of radioactivity in process streams for normal and incident conditions*

IEC/IEEE 60780-323:2016, *Nuclear facilities – Electrical equipment important to safety system – Qualification*

IEC 60861, *Equipment for monitoring of radionuclides in liquid effluents and surface waters*

IEC 60880, *Nuclear power plants – Instrumentation and control systems important to safety – Software aspects for computer-based systems performing category A functions*

IEC 60951-1:2022, *Nuclear power plants – Instrumentation important to safety – Radiation monitoring for accident and post-accident conditions – Part 1: General requirements*

IEC 60951-2, *Nuclear power plants – Instrumentation important to safety – Radiation monitoring for accident and post-accident conditions – Part 2: Equipment for continuous off-line monitoring of radioactivity in gaseous effluents and ventilation air*

IEC 60951-3, *Nuclear power plants – Instrumentation important to safety – Radiation monitoring for accident and post-accident conditions – Part 3: Equipment for continuous high range area gamma monitoring*

IEC 60951-4, *Nuclear power plants – Instrumentation important to safety – Radiation monitoring for accident and post-accident conditions – Part 4: Equipment for continuous in-line or on-line monitoring of radioactivity in process streams*

IEC 60960, *Functional design criteria for a safety parameter display system for nuclear power stations*

IEC/IEEE 60980-344, *Nuclear facilities – Equipment important to safety – Seismic qualification*

IEC 60987, *Nuclear power plants – Instrumentation and control important to safety – Hardware requirements*

IEC 61031, *Nuclear facilities – Instrumentation and control systems – Design, location and application criteria for installed area gamma radiation dose rate monitoring equipment for use during normal operation and anticipated operational occurrences*

IEC 61226:2020, *Nuclear power plants – Instrumentation, control and electrical power systems important to safety – Categorization of functions and classification of systems*

IEC 61250, *Nuclear reactors – Instrumentation and control systems important for safety – Detection of leakage in coolant systems*

IEC 61504, *Nuclear facilities – Instrumentation and control systems important to safety – Centralized systems for continuous monitoring of radiation and/or levels of radioactivity*

IEC 61513:2011, *Nuclear power plants – Instrumentation and control important to safety – General requirements for systems*

IEC 61559 (all parts), *Radiation protection instrumentation in nuclear facilities – Centralized systems for continuous monitoring of radiation and/or levels of radioactivity*

IEC 62003, *Nuclear power plants – Instrumentation, control and electrical power systems – Requirements for electromagnetic compatibility testing*

IEC 62138, *Nuclear power plants – Instrumentation and control systems important to safety – Software aspects for computer-based systems performing category B or C functions*

IEC 62302, *Radiation protection instrumentation – Equipment for sampling and monitoring radioactive noble gases*

IEC 62303, *Radiation protection instrumentation – Equipment for monitoring airborne tritium*

IEC 62566:2012, *Nuclear power plants – Instrumentation and control important to safety – Development of HDL-programmed integrated circuits for systems performing category A functions*

IEC 62566-2, *Nuclear power plants – Instrumentation and control systems important to safety – Development of HDL-programmed integrated circuits – Part 2: HDL-programmed integrated circuits for systems performing category B or C functions*

IEC 63147:2017/IEEE Std 497™, *Criteria for accident monitoring instrumentation for nuclear power generating stations*

ISO/IEC 17025, *General requirements for the competence of testing and calibration laboratories*

ISO 2889, *Sampling airborne radioactive materials from the stacks and ducts of nuclear facilities*

ISO 4037-1, *Radiological protection – X and gamma reference radiation for calibrating dosimeters and dose rate meters and for determining their response as a function of photon energy – Part 1: Radiation characteristics and production methods*

ISO 4037-3, *Radiological protection – X and gamma reference radiation for calibrating dosimeters and dose rate meters and for determining their response as a function of photon energy – Part 3: Calibration of area and personal dosimeters and the measurement of their response as a function of energy and angle of incidence*

SOMMAIRE

AVANT-PROPOS	28
INTRODUCTION.....	30
1 Domaine d'application	35
2 Références normatives	35
3 Termes et définitions	38
4 Symboles et abréviations.....	42
5 Catégorisation et classement des RMS.....	42
5.1 Catégorisation des fonctions des RMS.....	42
5.2 Classement des systèmes pour les RMS.....	42
5.3 Critères d'identification des variables spécifiques à la centrale	43
6 Conception détaillée et mise en œuvre du RMS.....	43
6.1 Généralités	43
6.2 Surveillance avec prélèvements des gaz rares radioactifs.....	43
6.3 Surveillance avec prélèvements des aérosols radioactifs	44
6.4 Surveillance avec prélèvements de l'iode radioactif.....	44
6.5 Surveillance avec prélèvements des liquides	44
6.6 Surveillance avec prélèvements du tritium	44
6.7 Surveillance interne ou externe.....	45
6.8 Surveillance de zone.....	45
6.9 Système centralisé.....	45
6.10 Détection des fuites	45
7 Intégration et validation du RMS.....	45
7.1 Intégration du RMS	45
7.2 Validation du RMS	45
8 Installation du RMS	46
9 Modification de conception du RMS.....	46
10 Qualification du RMS.....	46
10.1 Généralités	46
10.2 Qualification environnementale	46
10.3 Qualification sismique	47
10.4 Perturbations électromagnétiques.....	47
11 Étalonnage	47
11.1 Généralités	47
11.2 Étalonnage périodique et vérification fonctionnelle.....	47
11.2.1 Généralités	47
11.2.2 Vérification de l'étalonnage après installation	47
11.2.3 Vérification fonctionnelle.....	47
11.2.4 Contre-mesures à la perte de fonctions de surveillance au cours de la vérification de l'étalonnage ou de la vérification fonctionnelle	48
11.3 Étalonnage des rayonnements.....	48
11.4 Étalonnage pour d'autres grandeurs	48
11.5 Traçabilité.....	48
Annex A (informative) Exemple de classement de sûreté pour les RMS importants pour la sûreté	49

Annex B (informative) Relation entre le cycle de vie du système de l'IEC 61513 et les exigences de l'IEC 62705	51
Bibliographie.....	52
Tableau 1 – Vue d'ensemble des normes qui traitent de la surveillance des rayonnements dans les installations nucléaires.....	32
Tableau A.1 – Exemple de classement de sûreté pour les RMS importants pour la sûreté	49
Tableau B.1 – Relation entre le cycle de vie du système de l'IEC 61513 et les exigences de l'IEC 62705	51

COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE

INSTALLATIONS NUCLÉAIRES – INSTRUMENTATION ET CONTRÔLE-COMMANDE IMPORTANTS POUR LA SÛRETÉ – SYSTÈMES DE SURVEILLANCE DES RAYONNEMENTS (RMS): CARACTÉRISTIQUES ET CYCLE DE VIE

AVANT-PROPOS

- 1) La Commission Electrotechnique Internationale (IEC) est une organisation mondiale de normalisation composée de l'ensemble des comités électrotechniques nationaux (Comités nationaux de l'IEC). L'IEC a pour objet de favoriser la coopération internationale pour toutes les questions de normalisation dans les domaines de l'électricité et de l'électronique. A cet effet, l'IEC – entre autres activités – publie des Normes internationales, des Spécifications techniques, des Rapports techniques, des Spécifications accessibles au public (PAS) et des Guides (ci-après dénommés "Publication(s) de l'IEC"). Leur élaboration est confiée à des comités d'études, aux travaux desquels tout Comité national intéressé par le sujet traité peut participer. Les organisations internationales, gouvernementales et non gouvernementales, en liaison avec l'IEC, participent également aux travaux. L'IEC collabore étroitement avec l'Organisation Internationale de Normalisation (ISO), selon des conditions fixées par accord entre les deux organisations.
- 2) Les décisions ou accords officiels de l'IEC concernant les questions techniques représentent, dans la mesure du possible, un accord international sur les sujets étudiés, étant donné que les Comités nationaux de l'IEC intéressés sont représentés dans chaque comité d'études.
- 3) Les Publications de l'IEC se présentent sous la forme de recommandations internationales et sont agréées comme telles par les Comités nationaux de l'IEC. Tous les efforts raisonnables sont entrepris afin que l'IEC s'assure de l'exactitude du contenu technique de ses publications; l'IEC ne peut pas être tenue responsable de l'éventuelle mauvaise utilisation ou interprétation qui en est faite par un quelconque utilisateur final.
- 4) Dans le but d'encourager l'uniformité internationale, les Comités nationaux de l'IEC s'engagent, dans toute la mesure possible, à appliquer de façon transparente les Publications de l'IEC dans leurs publications nationales et régionales. Toutes divergences entre toutes Publications de l'IEC et toutes publications nationales ou régionales correspondantes doivent être indiquées en termes clairs dans ces dernières.
- 5) L'IEC elle-même ne fournit aucune attestation de conformité. Des organismes de certification indépendants fournissent des services d'évaluation de conformité et, dans certains secteurs, accèdent aux marques de conformité de l'IEC. L'IEC n'est responsable d'aucun des services effectués par les organismes de certification indépendants.
- 6) Tous les utilisateurs doivent s'assurer qu'ils sont en possession de la dernière édition de cette publication.
- 7) Aucune responsabilité ne doit être imputée à l'IEC, à ses administrateurs, employés, auxiliaires ou mandataires, y compris ses experts particuliers et les membres de ses comités d'études et des Comités nationaux de l'IEC, pour tout préjudice causé en cas de dommages corporels et matériels, ou de tout autre dommage de quelque nature que ce soit, directe ou indirecte, ou pour supporter les coûts (y compris les frais de justice) et les dépenses découlant de la publication ou de l'utilisation de cette Publication de l'IEC ou de toute autre Publication de l'IEC, ou au crédit qui lui est accordé.
- 8) L'attention est attirée sur les références normatives citées dans cette publication. L'utilisation de publications référencées est obligatoire pour une application correcte de la présente publication.
- 9) L'attention est attirée sur le fait que certains des éléments de la présente Publication de l'IEC peuvent faire l'objet de droits de brevet. L'IEC ne saurait être tenue pour responsable de ne pas avoir identifié de tels droits de brevets.

L'IEC 62705 a été établie par le sous-comité 45A: Systèmes d'instrumentation, de contrôle-commande et d'alimentation électrique des installations nucléaires, du comité d'études 45 de l'IEC: Instrumentation nucléaire. Il s'agit d'une Norme internationale.

Cette deuxième édition annule et remplace la première édition parue en 2014. Cette édition constitue une révision technique.

Cette édition inclut les modifications techniques majeures suivantes par rapport à l'édition précédente:

- a) le titre a été modifié;
- b) la catégorisation des conditions accidentelles a été harmonisée;

- c) les références aux nouvelles normes publiées depuis la première édition ont été mises à jour;
- d) les termes et définitions ont été mis à jour.

Le texte de cette Norme internationale est issu des documents suivants:

Projet	Rapport de vote
45A/XX/FDIS	45A/XX/RVD

Le rapport de vote indiqué dans le tableau ci-dessus donne toute information sur le vote ayant abouti à son approbation.

La langue employée pour l'élaboration de cette Norme internationale est l'anglais.

Ce document a été rédigé selon les Directives ISO/IEC, Partie 2, il a été développé selon les Directives ISO/IEC, Partie 1 et les Directives ISO/IEC, Supplément IEC, disponibles sous www.iec.ch/members_experts/refdocs. Les principaux types de documents développés par l'IEC sont décrits plus en détail sous www.iec.ch/standardsdev/publications.

Le comité a décidé que le contenu de ce document ne sera pas modifié avant la date de stabilité indiquée sur le site web de l'IEC sous webstore.iec.ch dans les données relatives au document recherché. A cette date, le document sera

- reconduit,
- supprimé,
- remplacé par une édition révisée, ou
- amendé.

INTRODUCTION

a) Contexte technique, questions importantes et structure de la Norme

La présente norme IEC établit les exigences en matière de gestion du cycle de vie des systèmes de surveillance des rayonnements (RMS) installés dans les installations nucléaires (centrales nucléaires de puissance et sites de stockage et de traitement du combustible nucléaire, par exemple).

Le présent document s'applique au matériel des RMS et est destiné à être utilisé pendant le fonctionnement normal, en cas d'incident de fonctionnement prévu (IFP), lors d'accidents de dimensionnement (DBA) et en conditions additionnelles de dimensionnement (DEC), incluant les accidents graves (SA).

Le présent document est destiné à être utilisé par les exploitants d'installations nucléaires, les évaluateurs de système, les fournisseurs et par les régulateurs.

b) Positionnement de la présente Norme dans la structure de la collection de normes du SC 45A de l'IEC

L'IEC 62705 est le troisième niveau de la hiérarchie de normes du SC 45A. Le présent document fournit des recommandations pour l'application des normes IEC/ISO existantes qui traitent de la conception et de la qualification du système et du matériel pour les RMS. Le présent document est un complément pour l'application de l'IEC 61513, comme cela est indiqué à l'Annex B, et il n'a pas pour objet de limiter l'application des autres exigences de l'IEC 61513 au cycle de vie des RMS.

Les normes suivantes fournissent les exigences et recommandations générales relatives aux RMS. L'IEC 61513 est la norme de premier niveau des normes du SC 45A et établit les exigences générales relatives aux matériels et systèmes d'instrumentation et de contrôle-commande (systèmes d'I&C) utilisés pour réaliser des fonctions importantes pour la sûreté dans les installations nucléaires. L'IEC 61226 fournit les critères de classement de l'instrumentation et des fonctions de commande. La plupart des RMS modernes contiennent des matériels informatisés. De fait, il convient souvent de traiter le RMS comme un système informatisé. Les normes suivantes exigées pour le système informatisé s'appliquent donc généralement aux RMS. L'IEC 60880 fournit les exigences relatives au logiciel pour les fonctions de catégorie A, et l'IEC 62138 fournit les exigences relatives au logiciel pour les fonctions de catégorie B ou C. L'IEC 60987 fournit les exigences applicables à la conception du matériel des systèmes informatisés. L'IEC 62566 fournit les exigences applicables au circuit intégré programmé en HDL (HDP) des systèmes qui réalisent des fonctions de catégorie A. L'IEC 62645 fournit les exigences de sécurité applicables aux systèmes d'I&C informatisés. Pour les essais de qualification, les normes suivantes du SC 45A s'appliquent. L'IEC/IEEE 60780-323 fournit des recommandations relatives à la qualification environnementale et l'IEC/IEEE 60980-344 fournit des recommandations relatives à la qualification sismique des matériels qui réalisent des fonctions de catégorie A ou B. L'IEC 62003 fournit les exigences relatives aux essais de compatibilité électromagnétique. De plus, l'IEC 61250 spécifie les exigences de détection des fuites à l'aide des RMS.

Pour les exigences particulières à la surveillance des rayonnements, les normes suivantes fournissent les exigences et recommandations applicables aux RMS. La série IEC 60951 fournit des recommandations relatives à la conception et aux essais des matériels de surveillance des rayonnements utilisés pour les incidents de fonctionnement prévus (IFP), les accidents de dimensionnement (DBA) et les conditions additionnelles de dimensionnement (DEC), incluant les accidents graves (SA). La série IEC 60761 fournit des exigences applicables aux matériels pour la surveillance en continu des rayonnements avec prélèvements dans les effluents gazeux en conditions normales. La série IEC 60761 est désormais remplacée par certaines normes du SC 45B (par exemple, prélèvements de gaz: IEC 62302, prélèvements du tritium: IEC 62303). L'IEC 60861 fournit des exigences applicables aux matériels pour la surveillance en continu des rayonnements avec prélèvements dans les effluents liquides en conditions normales. L'IEC 60768 fournit des exigences applicables aux matériels pour la surveillance en continu, interne et externe, des rayonnements au niveau des fluides de procédés pour les conditions de fonctionnement normal et incidentel. L'IEC 61031 fournit des exigences applicables aux moniteurs de surveillance des rayonnements de zone dans les conditions normales, conjointement avec l'IEC 60532. L'IEC 61504 fournit des exigences applicables aux systèmes centralisés pour

la surveillance des rayonnements sur l'ensemble du site conjointement avec la série IEC 61559 qui spécifie les exigences des systèmes centralisés. Si le système centralisé fait partie intégrante du système de visualisation des paramètres de sûreté, l'IEC 60960 fournit les critères fonctionnels de conception. L'ISO 2889 fournit des recommandations pour l'échantillonnage de gaz et de particules. La série ISO 4037 fournit la méthode d'étalonnage des moniteurs de surveillance des rayonnements.

Les relations entre ces différentes normes sont données dans le Tableau 1.

L'IEC 63147/IEEE Std 497™ fournit des recommandations générales pour l'instrumentation de surveillance des accidents. L'IEEE Std 497™ a été adoptée directement en tant que norme double logo et un rapport technique, l'IEC TR 63123, a été établi pour étudier l'application de la norme commune dans le contexte de l'IEC.

La structure de la présente norme est alignée sur la structure de l'IEC 63147/IEEE Std 497™, et les exigences techniques de la présente norme sont cohérentes avec les exigences spécifiées dans l'IEC 63147/IEEE Std 497™ ainsi qu'avec les recommandations d'application fournies dans l'IEC TR 63123.

Pour plus d'informations sur la structure de la collection de normes du SC 45A de l'IEC, voir le point d) de la présente introduction.

Tableau 1 – Vue d'ensemble des normes qui traitent de la surveillance des rayonnements dans les installations nucléaires

Développeur	ISO		IEC			
				SC 45A		SC 45B
Domaine d'application	Echantillonnage (fonctionnement normal)	Etalonnage (fonctionnement normal)	Fonctionnement normal, IFP	DBA	DEC	Fonctionnement normal
Surveillance avec prélèvements des gaz rares radioactifs	ISO 2889	ISO 4037-1, ISO 4037-3	N/A	IEC 60951-1, IEC 60951-2	N/A	IEC 62302, IEC 60761-1, IEC 60761-3
Surveillance avec prélèvements des aérosols radioactifs	ISO 2889	ISO 4037-1, ISO 4037-3	N/A	IEC 60951-1, IEC 60951-2	N/A	IEC 60761-1, IEC 60761-2
Surveillance avec prélèvements de l'iode radioactif	ISO 2889	ISO 4037-1, ISO 4037-3	N/A	IEC 60951-1, IEC 60951-2	N/A	IEC 60761-1, IEC 60761-4
Surveillance avec prélèvements des liquides	N/A	N/A	N/A	N/A	N/A	IEC 60861
Surveillance avec prélèvements du tritium	N/A	N/A	N/A	N/A	N/A	IEC 62303, IEC 60761-1, IEC 60761-5
Surveillance interne ou externe	N/A	ISO 4037-1, ISO 4037-3	IEC 60768	IEC 60951-1, IEC 60951-4	N/A	N/A
Surveillance de zone	N/A	ISO 4037-1, ISO 4037-3	IEC 61031	IEC 60951-1, IEC 60951-3		IEC 60532
Système centralisé	N/A	N/A	IEC 61504, IEC 60960		N/A	IEC 61559-1
Exigences de classement/de base	N/A	N/A	IEC 61513, IEC 60880, IEC 60987, IEC 61226, IEC 62138, IEC 62566, IEC 62566-2, IEC 62645, IEC 61250		N/A	N/A
Qualification	N/A	N/A	IEC/IEEE 60780-323, IEC/IEEE 60980-344, IEC 62003		N/A	IEC 62706

c) Recommandations et limites relatives à l'application de la présente Norme

Il est important de noter que le présent document n'établit pas d'exigences fonctionnelles supplémentaires pour les systèmes importants pour la sûreté. Les exigences fournies par la présente norme font généralement référence à la nécessité d'appliquer d'autres normes IEC et ISO et aux exigences fonctionnelles et techniques contenues dans ces normes.

Afin d'assurer la pertinence du document pour les années à venir, l'accent est mis sur les questions de principes plutôt que sur des technologies particulières.

d) Description de la structure de la collection de normes du SC 45A de l'IEC et des relations avec d'autres documents de l'IEC, et avec les documents d'autres organisations (AIEA, ISO)

La collection de normes établies par le SC 45A de l'IEC est structurée en quatre niveaux. Les documents de niveau supérieur dans la collection de normes du SC 45A de l'IEC sont les normes IEC 61513 et IEC 63046.

La norme IEC 61513 établit les exigences générales relatives aux matériels et systèmes d'I&C utilisés pour réaliser des fonctions importantes pour la sûreté des centrales nucléaires de puissance. La norme IEC 63046 établit les exigences générales relatives aux systèmes d'alimentation électrique des centrales nucléaires de puissance; elle couvre les systèmes d'alimentation électrique y compris les alimentations des systèmes d'I&C.

Les normes IEC 61513 et IEC 63046 doivent être prises en compte ensemble et au même niveau. Les normes IEC 61513 et IEC 63046 structurent la collection de normes du SC 45A de l'IEC et forment un cadre complet qui établit les exigences générales relatives aux systèmes d'I&C et d'alimentation électrique des centrales nucléaires de puissance.

Les normes IEC 61513 et IEC 63046 font directement référence à d'autres normes du SC 45A de l'IEC qui établissent les exigences générales relatives à des sujets spécifiques, tels que la catégorisation des fonctions et le classement des systèmes, la qualification, la séparation des systèmes, la défense contre les défaillances de cause commune, la conception des salles de commande, la compatibilité électromagnétique, l'ingénierie des facteurs humains, la cybersécurité, les aspects logiciels et matériels relatifs aux systèmes numériques programmables, la coordination des exigences de sûreté et de sécurité, et la gestion du vieillissement. Il convient de considérer que ces normes, auxquelles il est fait référence à ce deuxième niveau, forment, avec les normes IEC 61513 et IEC 63046, un ensemble documentaire cohérent.

Au troisième niveau, les normes du SC 45A de l'IEC, qui ne sont généralement pas citées en référence directement par les normes IEC 61513 ou IEC 63046, établissent les exigences particulières aux matériels, méthodes techniques ou activités spécifiques. Généralement, ces documents, qui font référence aux documents de deuxième niveau pour les exigences générales, peuvent être utilisés de façon isolée.

Un quatrième niveau qui est une extension de la collection de normes du SC 45 de l'IEC correspond aux rapports techniques qui ne sont pas des documents normatifs.

Les normes de la collection du SC 45A de l'IEC mettent en œuvre de manière systématique et décrivent les principes de sûreté et de sécurité et les aspects fondamentaux donnés dans les normes de sûreté de l'AIEA pertinentes et dans les documents pertinents de la collection de l'AIEA pour la sécurité nucléaire de puissance (NSS), en particulier avec le document d'exigences SSR-2/1 qui établit les exigences de sûreté relatives à la conception des centrales nucléaires de puissance, avec le guide de sûreté SSG-30 qui traite du classement de sûreté des structures, systèmes et composants des centrales nucléaires de puissance, avec le guide de sûreté SSG-39 qui traite de la conception des systèmes d'I&C des centrales nucléaires de puissance, avec le guide de sûreté SSG-34 qui traite de la conception des systèmes d'alimentation électrique des centrales nucléaires de puissance, avec le guide de sûreté SSG-51 qui traite de l'ingénierie des facteurs humains lors de la conception des centrales nucléaires de puissance et avec le guide de mise en œuvre NSS17 qui traite de la sécurité informatique pour les installations nucléaires. La terminologie et les définitions utilisées pour la sûreté et la sécurité dans les normes établies par le SC 45A sont conformes à celles utilisées par l'AIEA.

Les normes IEC 61513 et IEC 63046 ont adopté une présentation similaire à celle de la publication fondamentale de sécurité IEC 61508, avec un cycle de vie d'ensemble et un cycle de vie des systèmes. En ce qui concerne la sûreté nucléaire, les normes IEC 61513 et IEC 63046 donnent l'interprétation des exigences générales des parties 1, 2 et 4 de l'IEC 61508 pour le secteur nucléaire. Dans ce cadre, l'IEC 60880, l'IEC 62138 et l'IEC 62566 correspondent à la partie 3 de l'IEC 61508 pour le secteur nucléaire.

Les normes IEC 61513 et IEC 63046 font référence à la norme ISO 9001, ainsi qu'aux documents AIEA GSR partie 2 et AIEA GS-G-3.1 et AIEA GS-G-3.5 pour ce qui concerne l'assurance qualité.

Au second niveau, en ce qui concerne la sûreté nucléaire, la norme IEC 62645 est le document chapeau des normes du SC 45A de l'IEC applicables à la cybersécurité. Elle se fonde sur les principes pertinents de haut niveau et sur les concepts principaux des normes génériques de sûreté, en particulier l'ISO/IEC 27001 et l'ISO/IEC 27002; elle les adapte et les complète pour qu'ils deviennent pertinents pour le secteur nucléaire; elle est coordonnée étroitement avec la norme IEC 62443. Au second niveau, la norme IEC 60964 est le document chapeau des normes du SC 45A de l'IEC applicables aux salles de commande, la norme IEC 63351 est le document chapeau des normes du SC 45A de l'IEC applicables

à l'ingénierie des facteurs humains et la norme IEC 62342 est le document chapeau des normes du SC 45A de l'IEC applicables à la gestion du vieillissement.

NOTE 1 On considère que pour la conception des systèmes d'I&C qui mettent en œuvre des fonctions de sûreté conventionnelle (par exemple, pour couvrir la sécurité des travailleurs, la protection des biens, la prévention contre les risques chimiques, la prévention contre les risques liés au procédé énergétique), des normes nationales ou internationales sont appliquées.

NOTE 2 L'IEC TR 64000 décrit plus en détail la structure générale de la collection de normes du SC 45A de l'IEC, ainsi que ses relations avec les autres organismes de normalisation et normes.

INSTALLATIONS NUCLÉAIRES – INSTRUMENTATION ET CONTRÔLE-COMMANDE IMPORTANTS POUR LA SÛRETÉ – SYSTÈMES DE SURVEILLANCE DES RAYONNEMENTS (RMS): CARACTÉRISTIQUES ET CYCLE DE VIE

1 Domaine d'application

Le présent document établit les exigences en matière de gestion du cycle de vie des systèmes de surveillance des rayonnements (RMS) et fournit des recommandations relatives à l'application des normes IEC existantes qui couvrent la conception et la qualification des systèmes et des matériels.

Le présent document a pour objet d'établir les exigences en matière de gestion du cycle de vie des RMS et de fournir des recommandations d'application. Le présent document est destiné à être cohérent avec les dernières versions des Normes internationales relatives aux moniteurs de surveillance des rayonnements, à l'échantillonnage des matériaux radioactifs, à l'étalonnage des instruments, à la conception des matériels et logiciels, au classement et à la qualification des systèmes. Sauf spécification contraire dans le présent document, la norme de niveau supérieur du SC 45A de l'IEC, l'IEC 61513, et les normes de deuxième niveau du SC 45A de l'IEC s'appliquent aux RMS.

Le présent document s'applique aux RMS installés dans les installations nucléaires et destinés à être utilisés pendant le fonctionnement normal, en cas d'incident de fonctionnement prévu (IFP), lors d'accidents de dimensionnement (DBA) et en conditions additionnelles de dimensionnement (DEC), incluant les accidents graves (SA). Les recommandations techniques fournies dans le présent document s'appliquent aux installations nucléaires, même si les fonctions particulières de chaque installation sont prises en compte pendant la conception et le cycle de vie opérationnel des RMS.

Les analyses en laboratoire et la réalisation associée de prélèvements, essentielles pour avoir un programme complet de surveillance des effluents, ainsi que les recherches relatives au déchargement du combustible ne relèvent pas du domaine d'application du présent document.

2 Références normatives

Les documents suivants sont cités dans le texte de sorte qu'ils constituent, pour tout ou partie de leur contenu, des exigences du présent document. Pour les références datées, seule l'édition citée s'applique. Pour les références non datées, la dernière édition du document de référence s'applique (y compris les éventuels amendements).

IEC 60532, *Instrumentation pour la radioprotection – Débitmètres à poste fixe, ensembles d'alarmes et moniteurs – Rayonnements X et gamma d'énergie comprise entre 50 keV et 7 MeV*

IEC 60761-1, *Equipements de surveillance en continu de la radioactivité dans les effluents gazeux – Partie 1: Exigences générales*

IEC 60761-2, *Equipements de surveillance en continu de la radioactivité dans les effluents gazeux – Partie 2: Exigences particulières aux moniteurs d'aérosols radioactifs, y compris les aérosols transuraniens*

IEC 60761-3, *Equipements de surveillance en continu de la radioactivité dans les effluents gazeux – Partie 3: Exigences particulières aux moniteurs de gaz rares radioactifs*

IEC 60761-4, *Equipements de surveillance en continu de la radioactivité dans les effluents gazeux – Partie 4: Exigences particulières aux moniteurs d'iode radioactif*

IEC 60761-5, *Equipements de surveillance en continu de la radioactivité dans les effluents gazeux – Partie 5: Exigences particulières aux moniteurs de tritium*

IEC 60768, *Centrales nucléaires de puissance – Instrumentation importante pour la sûreté – Matériels pour la surveillance des rayonnements en continu, interne et externe, au niveau des fluides de procédés pour les conditions de fonctionnement normal et incidentel*

IEC/IEEE 60780-323:2016, *Installations nucléaires – Equipements électriques importants pour la sûreté – Qualification*

IEC 60861, *Equipements pour la surveillance des radionucléides dans les effluents liquides et les eaux de surface*

IEC 60880, *Centrales nucléaires de puissance – Instrumentation et contrôle-commande importants pour la sûreté – Aspects logiciels des systèmes programmés réalisant des fonctions de catégorie A*

IEC 60951-1:2022, *Installations nucléaires – Instrumentation importante pour la sûreté – Surveillance des rayonnements pour les conditions accidentelles et post-accidentelles – Partie 1: Exigences générales*

IEC 60951-2, *Centrales nucléaires de puissance – Instrumentation importante pour la sûreté – Surveillance des rayonnements pour les conditions accidentelles et post-accidentelles – Partie 2: Matériels pour la surveillance des rayonnements en continu avec prélèvements dans les effluents gazeux et l'air de ventilation*

IEC 60951-3, *Centrales nucléaires de puissance – Instrumentation importante pour la sûreté – Surveillance des rayonnements pour les conditions accidentelles et post-accidentelles – Partie 3: Ensemble de surveillance locale en continu des rayonnements gamma à large gamme*

IEC 60951-4, *Centrales nucléaires de puissance – Instrumentation importante pour la sûreté – Surveillance des rayonnements pour les conditions accidentelles et post-accidentelles – Partie 4: Equipement pour la surveillance en continu des rayonnements internes ou externes aux flux de procédé*

IEC 60960, *Critères fonctionnels de conception pour un système de visualisation des paramètres de sûreté pour les centrales nucléaires*

IEC/IEEE 60980-344, *Nuclear facilities – Equipment important to safety – Seismic qualification* (disponible en anglais seulement)

IEC 60987, *Centrales nucléaires de puissance – Systèmes d'instrumentation et de contrôle-commande importants pour la sûreté – Exigences applicables au matériel*

IEC 61031, *Installations nucléaires – Systèmes d'instrumentation et de contrôle-commande – Critères de conception, d'implantation et d'application pour les matériels de surveillance du débit de dose de rayonnement gamma à poste fixe, utilisés pendant le fonctionnement normal et lors d'incidents de fonctionnement prévus*

IEC 61226:2020, *Centrales nucléaires de puissance – Systèmes d'instrumentation, de contrôle-commande et d'alimentation électrique importants pour la sûreté – Catégorisation des fonctions et classement des systèmes*

IEC 61250, *Réacteurs nucléaires – Systèmes d'instrumentation et de contrôle-commande pour la sûreté – Détection des fuites dans les systèmes de refroidissement*

IEC 61504, *Installations nucléaires – Systèmes d'instrumentation et de contrôle-commande importants pour la sûreté – Systèmes centralisés pour la surveillance en continu des rayonnements et/ou des niveaux de radioactivité*

IEC 61513:2011, *Centrales nucléaires de puissance – Instrumentation et contrôle-commande importants pour la sûreté – Exigences générales pour les systèmes*

IEC 61559 (toutes les parties), *Instrumentation pour la radioprotection dans les installations nucléaires – Ensembles centralisés pour la surveillance en continu des rayonnements et/ou des niveaux de radioactivité*

IEC 62003, *Centrales nucléaires de puissance – Systèmes d'instrumentation, de contrôle-commande et d'alimentation électrique – Exigences relatives aux essais de compatibilité électromagnétique*

IEC 62138, *Centrales nucléaires – Systèmes d'instrumentation et de contrôle-commande importants pour la sûreté – Aspects logiciels des systèmes informatisés réalisant des fonctions de catégorie B ou C*

IEC 62302, *Instrumentation pour la radioprotection – Matériel pour le prélèvement et la surveillance des gaz rares radioactifs*

IEC 62303, *Instrumentation pour la radioprotection – Matériel pour la surveillance du tritium atmosphérique*

IEC 62566:2012, *Centrales nucléaires de puissance – Instrumentation et contrôle-commande importants pour la sûreté – Développement des circuits intégrés programmés en HDL pour les systèmes réalisant des fonctions de catégorie A*

IEC 62566-2, *Centrales nucléaires de puissance – Instrumentation et contrôle-commande importants pour la sûreté – Développement des circuits intégrés programmés en HDL – Partie 2: Circuits intégrés programmés en HDL pour les systèmes réalisant des fonctions de catégorie B ou C*

IEC 63147:2017/IEEE Std 497™, *Criteria for accident monitoring instrumentation for nuclear power generating stations* (disponible en anglais seulement)

ISO/IEC 17025, *Exigences générales concernant la compétence des laboratoires d'étalonnages et d'essais*

ISO 2889, *Echantillonnage des substances radioactives en suspension dans l'air dans les émissaires de rejet et les conduits des installations nucléaires*

ISO 4037-1, *Radioprotection – Rayonnements X et gamma de référence pour l'étalonnage des dosimètres et des débitmètres, et pour la détermination de leur réponse en fonction de l'énergie des photons – Partie 1: Caractéristiques des rayonnements et méthodes de production*

ISO 4037-3, *Radioprotection – Rayonnements X et gamma de référence pour l'étalonnage des dosimètres et des débitmètres, et pour la détermination de leur réponse en fonction de l'énergie des photons – Partie 3: Etalonnage des dosimètres de zone et individuels et mesurage de leur réponse en fonction de l'énergie et de l'angle d'incidence*