



IEC 62792

Edition 2.0 2026-04

INTERNATIONAL STANDARD

Measurement method for the output of electroshock weapons

CONTENTS

FOREWORD.....	3
INTRODUCTION.....	5
1 Scope.....	6
2 Normative references	6
3 Terms and definitions	6
4 <i>ESW</i> measurement system.....	15
4.1 General.....	15
4.1.1 Overview	15
4.1.2 Environmental conditions.....	16
4.2 Instrumentation requirements.....	16
4.2.1 General	16
4.2.2 Minimum performance requirements	17
4.2.3 Measurement system traceability.....	18
4.2.4 System calibration	19
4.2.5 Timebase calibration	22
4.2.6 Resistors	22
4.3 Electrostatic discharge (ESD) and high voltage protection	22
4.4 Current waveform measurements.....	23
4.4.1 General	23
4.4.2 Measurement set-up.....	23
4.4.3 Current probe requirements	24
4.4.4 Waveform acquisition	24
4.5 Voltage waveform measurements	25
4.5.1 General	25
4.5.2 Measurement set-up.....	25
4.5.3 Voltage probe requirements.....	25
4.5.4 Waveform acquisition	26
4.6 High voltage arcing charge delivery distance	26
4.6.1 General	26
4.6.2 Instruments	26
4.6.3 Preparation.....	28
4.6.4 Measurement.....	28
5 Waveform parameters	30
5.1 General.....	30
5.2 Waveform parsing.....	31
5.3 Initial and final instants	31
5.4 Average level.....	32
5.5 Average absolute level.....	32
5.6 Charge, net.....	32
5.7 Charge, total.....	33
5.8 Current, aggregate.....	33
5.9 Energy, pulse.....	33
5.10 Impulse amplitude.....	34
5.11 Peak, maximum (minimum).....	35
5.12 Peak-to-peak value	35
5.13 Pulse duration.....	35

5.14	Pulse rate	35
5.15	Pulse separation	35
5.16	Offset.....	36
5.17	Transition duration.....	36
5.18	Transition settling duration.....	36
5.19	Transition settling error.....	36
5.20	Waveform period.....	36
Annex A (informative) Impedance matching network		37
Bibliography.....		41
Figure 1 – <i>Long-range wired ESW</i> showing components		7
Figure 2 – Diagram of the ESW measurement system with voltage and current probes in place.....		15
Figure 3 –Set up for calibrating the vertical channel of the ESW measurement system		20
Figure 4 –Set up for calibration of the magnitude frequency response of the ESW measurement system.....		21
Figure 5 – Set up for calibration of impulse response or step response of ESW measurement system.....		22
Figure 6 – Instrument arrangement for arcing charge-delivery-distance test method, shown with jumpers (represented by double dashed lines) placed to measure arcing distance for the top air gap		26
Figure 7 – Diagram of air-gap test fixture		27
Figure 8 – Air-gap test fixture set to measure arcing distance for both ESW darts.....		28
Figure 9 – Typical arc		29
Figure 10 – Example arc waveforms for two arcing distances, 5 mm and 20 mm.....		30
Figure A.1 – Impedance matching network (IMN).....		37
Figure A.2 – Input impedance		38
Table 1 –Waveform recorder minimum performance specifications		17
Table 2 – Initial instants and final instants for the <i>waveform</i> sub-epochs.....		31
Table A.1 – Resistance values.....		40

INTERNATIONAL ELECTROTECHNICAL COMMISSION

Measurement method for the output of electroshock weapons

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 62792 has been prepared by IEC technical committee 85: Measuring equipment for electrical and electromagnetic quantities. It is an International Standard.

This second edition cancels and replaces the first edition published in 2015. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) addition of a new clause describing a method for measuring the high voltage arcing charge delivery distance; and
- b) an annex describing an impedance matching network that is necessary to calibrate the measurement system.

The text of this International Standard is based on the following documents:

Draft	Report on voting
85/988/FDIS	85/995/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

Words in *italics* in the text are defined in Clause 3.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

INTRODUCTION

Manufacturers, medical researchers, policy makers, users, and other interested parties involved with different aspects of *electroshock weapons (ESWs)* use a variety of different measurement methods, different terminologies, and different *parameters* to measure and describe the performance of an *ESW*. These differences generate confusion and misunderstanding within this stakeholder community, and this impacts the ability to perform accurate, reliable, and reproducible measurement comparisons. By developing a generally-accepted terminology, set of performance *parameters*, and test methods, this document will facilitate accurate and precise communication for the *parameters* that describe the electrical outputs, current and *high voltage*, of *ESWs*. This improved communication will aid this stakeholder community in collectively developing uniform methods for describing the *ESW* output and its effect on human physiology consistently and accurately, thereby enabling the development of safe use performance standards or regulations by the appropriate standardization body.

1 Scope

This document specifies a method for measuring the electrical outputs, current and *high voltage*, from *electroshock weapons (ESWs)* that deliver an electrical stimulus to humans. This document is applicable to any and all *ESWs*. This document describes *ESW* measurement systems to help guide the user of this document in developing their own *ESW* measurement system. It includes methods for measuring or computing a variety of *parameters* that can be used to characterize the electrical output of the *ESW*. The user of this document will select those *parameters* that are appropriate for their applications and stakeholders.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60469:2013, *Transitions, pulses and related waveforms - Terms, definitions and algorithms*

ISO/IEC 17025, *General requirements for the competence of testing and calibration laboratories*

BIPM, *The International System of Units (SI)*, 9th Edition, 2019

Bibliography

- [1] P. Daponte, L. De Vito, F. Picariello, S. Rapuano, I. Tudosa, "A review of measurement methods for traceable calibration of waveform recorders used in ElectroShock Weapons (ESWs) testing", in Proc. of 1st IEEE International Workshop on Technologies for Defense and Security (TechDefense), Rome, Italy, 2023, pp. 22-27. <https://doi.org/10.1109/TechDefense59795.2023.10380858>
- [2] N. Paulter, Jr., "Method for measuring the phase spectrum of the output of a frequency source used in the calibration of an electroshock weapon characterization system," Journal of research of the National Institute of Standards and Technology, vol. 122, no. 35, pp. 1–14, 2017. <https://doi.org/10.6028/jres.122.035>
- [3] S. Rapuano, P. Daponte, L. De Vito, F. Picariello, I. Tudosa, N. Paulter, "A phase measurement method to guarantee the traceability of the calibration systems," in Proc. of Conference on Precision Electromagnetic Measurements (CPEM), Denver, Colorado, USA, 2020, pp. 1–2. <https://doi.org/10.1109/CPEM49742.2020.9191708>
- [4] P. Daponte, L. De Vito, F. Picariello, S. Rapuano, I. Tudosa, "Sensitivity assessment of a phase measurement method used in a waveform recorder traceable testing for ElectroShock Weapons (ESW)", in Proc. of 1st IEEE International Workshop on Technologies for Defense and Security (TechDefense), Rome, Italy, 2023, pp. 245-250. <http://dx.doi.org/10.1109/TechDefense59795.2023.10380852>
- [5] I. Tudosa, F. Picariello, P. Daponte, L. De Vito, S. Rapuano, N. Paulter, Jr., "Prototype of high accuracy single input phase measurement instrument", Measurement, vol. 201, 2022, pp.1-17. <https://doi.org/10.1016/j.measurement.2022.111595>
- [6] IEC 60050 (all parts), International Electrotechnical Vocabulary (available at <http://www.electropedia.org>)
- [7] IEC 60359:2001, *Electrical and electronic measurement equipment - Expression of performance*
- [8] IEC 60469:2013, *Transitions, pulses and related waveforms - Terms, definitions and algorithms*
- [9] IEC 60479-2:2019, *Effects Of Current On Human Beings And Livestock - Part 2: Special Aspects*
- [10] IEEE Std. 4-1995, *IEEE Standard techniques for high-voltage testing*
- [11] IEEE Std. 1057-2017, *IEEE Standard for digitizing waveform recorders*
- [12] ISO/IEC Guide 98-3:2008, *Uncertainty of measurement - Part 3: Guide to the expression of uncertainty in measurement (GUM: 1995)*
- [13] ISO/IEC Guide 99:2007, *International vocabulary of metrology - Basic and general concepts and associated terms (VIM)*