

TECHNICAL REPORT



Low-voltage switchgear and controlgear – Fire risk analysis and risk reduction measures

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.130.20

ISBN 978-2-8322-4622-1

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	3
INTRODUCTION.....	5
1 Scope.....	6
2 Normative references	6
3 Terms and definitions	7
4 Ignition modes for electrical fires	8
4.1 General.....	8
4.2 Overheating at the connection point due to loose connections	10
4.2.1 General	10
4.2.2 Ignition mechanisms	11
4.2.3 Loose connections mitigation measures.....	11
4.3 Overheating of internal power conductors	14
4.4 Arcs.....	14
4.4.1 General	14
4.4.2 Breaking and making arcs	15
4.4.3 Arcs occurring at loose connections.....	15
4.4.4 Arcing through char and tracking arcs.....	16
4.4.5 Sparks.....	16
4.4.6 Arcs due to excessive overvoltage.....	16
4.5 Failure of electronic components	16
4.5.1 Basic description of the ignition mechanism.....	16
4.5.2 Mitigation measures.....	17
5 Conclusion	17
Bibliography.....	19
Figure 1 – Voltage drop and power dissipation versus current values (schematic) [5].....	11
Figure 2 – Current and voltage conditions for switching arcs (schematic) [10].....	15
Table 1 – Ignition phenomena in electrotechnical products	9
Table 2 – Root causes of electrical fires according to [6]	10
Table 3 – Potential failure modes for low-voltage switchgear and controlgear	10
Table 4 – Function of the equipment and glow-wire test temperatures	13
Table 5 – Relevant source ignition modes for low-voltage switchgear and controlgear	18

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR –
FIRE RISK ANALYSIS AND RISK REDUCTION MEASURES**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC TR 63054, which is a technical report, has been prepared by subcommittee 121A: Low-voltage switchgear and controlgear, of IEC technical committee 121: Switchgear and controlgear and their assemblies for low voltage.

The text of this technical report is based on the following documents:

Enquiry draft	Report on voting
121A/115/DTR	121A/155/RVDTR

Full information on the voting for the approval of this technical report can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

As fire-ignition hazards are inherent with electricity, installation rules and product standards for electrical equipment are aimed at providing risk reduction measures and minimizing residual risk without compromising product safety and function.

Residual risk of low-voltage switchgear and controlgear compliant with IEC 60947 relevant publications is generally low and, when selected, installed and used according to manufacturer instruction and installation rules, do not ignite fire in normal operation or reasonably foreseeable fault conditions.

This document, in accordance to ISO/IEC Guide 51 and IEC Guide 116, describes the fire risk analysis of electrical equipment and risk reduction measures in IEC 60947 relevant publications. While intended to apply specifically to low voltage switchgear and controlgear, it is suggested that other product committees may find this information useful.

The fire hazards, namely the flame ignition mechanisms, relevant for low-voltage switchgear and controlgear are reviewed and discussed. The related risk reduction measures included in IEC 60947 relevant publications are subsequently reported for each of those mechanisms.

These measures are based on a system approach, not limited to construction materials requirements and include design rules and type testing to ensure equipment do not cause fires in normal operation or due to reasonably foreseeable faulty conditions.

LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR – FIRE RISK ANALYSIS AND RISK REDUCTION MEASURES

1 Scope

This document applies to the fire risk analysis of low-voltage switchgear and controlgear (hereinafter referred to as "equipment") referring to the IEC 60947 relevant publications, where the following applies:

- only the case where a fire originates (typically under fault or misuse conditions) within the equipment;
- only equipment installed in normal environments. Hazardous environments, for example in presence of combustible materials, is not to be considered;
- only the case of products selected, installed and used according to the manufacturer instructions and installation rules.

In addition, the following cases are not considered:

- faults addressed by IEC TR 61641;
- risks due to smoke emissions;
- double faults, i.e. multiple phenomenon, potentially combined.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC Guide 116:2010, *Guidelines for safety related risk assessment and risk reduction for low voltage equipment*

IEC 60695-1-10:2015, *Fire hazard testing – Guidance for assessing the fire hazard of electrotechnical products – General guidelines*

IEC 60947-1:2007, *Low-voltage switchgear and controlgear – Part 1: General rules*

IEC 60947-1:2007/AMD1:2010

IEC 60947-1:2007/AMD2:2014

IEC 60947-2, *Low-voltage switchgear and controlgear – Part 2: Circuit-breakers*

IEC 60947-3, *Low-voltage switchgear and controlgear – Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units*

IEC 60947-5-1, *Low-voltage switchgear and controlgear – Part 5-1: Control circuit devices and switching elements – Electromechanical control circuit devices*

IEC 60947-6-1, *Low-voltage switchgear and controlgear – Part 6-1: Multiple function equipment – Transfer switching equipment*

IEC 60947-7-1:2009, *Low-voltage switchgear and controlgear – Part 7-1: Ancillary equipment – Terminal blocks for copper conductors*

IEC 60999-1, *Connecting devices – Electrical copper conductors – Safety requirements for screw-type and screwless-type clamping units – Part 1: General requirements and particular requirements for clamping units for conductors from 0,2 mm² up to 35 mm² (included)*

IEC 60999-2, *Connecting devices – Electrical copper conductors – Safety requirements for screw-type and screwless-type clamping units – Part 2: Particular requirements for clamping units for conductors above 35 mm² up to 300 mm² (included)*

IEC 62477-1:2012, *Safety requirements for power electronic converter systems and equipment – Part 1: General*