



IEC 63260

Edition 1.0 2020-05

INTERNATIONAL IEEE Std 1082™ STANDARD

Guide for incorporating human reliability analysis into probabilistic risk assessments for nuclear power generating stations and other nuclear facilities

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 27.120.20

ISBN 978-2-8322-7547-4

Warning! Make sure that you obtained this publication from an authorized distributor.

Contents

| | |
|-----------------------------------------------------------------|----|
| 1. Overview..... | 11 |
| 1.1 Scope..... | 11 |
| 1.2 Purpose..... | 11 |
| 2. Definitions, acronyms, and abbreviations | 11 |
| 2.1 Definitions..... | 11 |
| 2.2 Acronyms and abbreviations | 13 |
| 3. Overview of an integrated HRA | 13 |
| 3.1 General..... | 13 |
| 3.2 Overall evaluation issues..... | 14 |
| 3.3 HRA process..... | 15 |
| 4. Details of the HRA process..... | 17 |
| 4.1 General | 17 |
| 4.2 Steps in the human reliability analysis (HRA) process | 17 |
| 5. Documentation..... | 26 |
| 5.1 Purpose..... | 26 |
| 5.2 Structure | 26 |
| Annex A (informative) An example for documenting HRA data | 28 |
| Annex B (informative) Bibliography | 32 |
| Annex C (informative) IEEE list of participants | 34 |

Guide for Incorporating Human Reliability Analysis into Probabilistic Risk Assessments for Nuclear Power Generating Stations and Other Nuclear Facilities

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation.

IEEE Standards documents are developed within IEEE Societies and Standards Coordinating Committees of the IEEE Standards Association (IEEE-SA) Standards Board. IEEE develops its standards through a consensus development process, which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of IEEE and serve without compensation. While IEEE administers the process and establishes rules to promote fairness in the consensus development process, IEEE does not independently evaluate, test, or verify the accuracy of any of the information contained in its standards. Use of IEEE Standards documents is wholly voluntary. IEEE documents are made available for use subject to important notices and legal disclaimers (see <http://standards.ieee.org/IPR/disclaimers.html> for more information).

IEC collaborates closely with IEEE in accordance with conditions determined by agreement between the two organizations.

- 2) The formal decisions of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees. The formal decisions of IEEE on technical matters, once consensus within IEEE Societies and Standards Coordinating Committees has been reached, is determined by a balanced ballot of materially interested parties who indicate interest in reviewing the proposed standard. Final approval of the IEEE standards document is given by the IEEE Standards Association (IEEE-SA) Standards Board.
- 3) IEC/IEEE Publications have the form of recommendations for international use and are accepted by IEC National Committees/IEEE Societies in that sense. While all reasonable efforts are made to ensure that the technical content of IEC/IEEE Publications is accurate, IEC or IEEE cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications (including IEC/IEEE Publications) transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC/IEEE Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC and IEEE do not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC and IEEE are not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or IEEE or their directors, employees, servants or agents including individual experts and members of technical committees and IEC National Committees, or volunteers of IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE-SA) Standards Board, for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC/IEEE Publication or any other IEC or IEEE Publications.
- 8) Attention is drawn to the normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that implementation of this IEC/IEEE Publication may require use of material covered by patent rights. By publication of this standard, no position is taken with respect to the existence or validity of any patent rights in connection therewith. IEC or IEEE shall not be held responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity or scope of Patent Claims or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this standard are expressly advised that determination of the validity of any patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

International Standard IEC 63260/IEEE Std 1082 has been processed through IEC technical committee 45A: Instrumentation, control and electrical power systems of nuclear facilities, under the IEC/IEEE Dual Logo Agreement.

The text of this standard is based on the following documents:

| IEEE Std | FDIS | Report on voting |
|--------------------|---------------|------------------|
| IEEE Std 1082-2017 | 45A/1285/FDIS | 45A/1293/RVD |

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

The IEC Technical Committee and IEEE Technical Committee have decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IEEE Guide for Incorporating Human Reliability Analysis into Probabilistic Risk Assessments for Nuclear Power Generating Stations and Other Nuclear Facilities

Sponsor

Nuclear Power Engineering Committee
of the
IEEE Power and Energy Society

Approved 6 December 2017

IEEE-SA Standards Board

Abstract: A structured framework for the incorporation of human reliability analysis (HRA) into probabilistic risk assessments (PRAs) is provided in this guide. To enhance the analysis of human/system interactions in PRAs, to help ensure reproducible conclusions, and to standardize the documentation of such assessments are the purposes of this guide. To do this, a specific HRA framework is developed from standard practices. The HRA framework is neutral with respect to specific HRA methods.

Keywords: HRA, human reliability analysis, IEEE 1082™, PRA, probabilistic risk assessment

999 Introduction

This introduction is not part of IEEE Std 1082-2017, Guide for Incorporating Human Reliability Analysis into Probabilistic Risk Assessments for Nuclear Power Generating Stations and Other Nuclear Facilities.

Any process that requires manual control to minimize public risk will require a high level of human reliability. This reliability can be evaluated through the systematic application of a probabilistic risk assessment (PRA). However, such an assessment requires a detailed understanding of human performance and human reliability methods to form a reasonable reliability estimate.

The initial risk assessment made in the nuclear power plant industry, WASH-1400 [B17], recognized the need for a discipline of human reliability analysis (HRA) to be systematically incorporated within the PRA enterprise.¹ But the methodology—both analyzing human failure events and identifying and incorporating them appropriately in the PRA—was new, incomplete, and in several ways inadequate.

The limitations of the understanding of human reliability in the mid-1970s were vividly demonstrated by the accident at Three Mile Island (TMI). Following TMI, the United States Nuclear Regulatory Commission (NRC), in conjunction with The Institute of Electrical and Electronics Engineers (IEEE), immediately called for a conference on the human factor issues raised by TMI.² This conference has subsequently become a series. Parallel to the initiation of the conference, Subcommittee 7, Human Factors and Control Facilities of the IEEE Nuclear Power Engineering Committee began discussing the standardization of HRA technology. The PRA/HRA interface of incorporating and performing an HRA in the context of a PRA was recognized as the most mature of the efforts of HRA. A guide, the least mandating of the IEEE standards documents, was approved as an IEEE standards project in 1984. The guide was revised in 1997.

This guide outlines the steps necessary to include human reliability in risk assessments. The intent of the guide is not to discuss the details of specific HRA methods, but rather to affirm a method-neutral framework for using a diverse range of HRA methods to support PRA. Since human error has been found to be an important contributor to risk, this guide underscores the systematic integration of the HRA at the earliest stages and throughout the PRA.

Since the 1997 revision of IEEE Std 1082™, there have been significant developments in HRA methods, theories, and practices. A working group (WG) was convened in 2012 to reaffirm the guide. This WG found numerous cases where the 1997 standard contained outdated references or failed to consider now-commonplace aspects of HRA. The WG, however, confirmed the underlying practice of HRA espoused in IEEE Std 1082-1997 is still contemporary and relevant to HRA practice. The WG has updated the guide, to the extent necessary to reflect important advances in HRA. Thus, the framework for conducting HRA found in IEEE Std 1082-1997 remains intact in this revision but has been augmented with references to contemporary issues and practices.

IEEE Std 1082 remains a unique, concise guide for specifying the framework for conducting HRA as part of PRA. Additional standard guidance documents are available beyond IEEE Std 1082. For example, the Electric Power Research Institute (EPRI) released the Systematic Human Action Reliability Procedure (SHARP) and revised SHARP1 approach [B4], which describes a detailed process of integrating quantitative HRA into PRA, mirroring parts of IEEE Std 1082.³ The American Society of Mechanical Engineers (ASME) has created the Standard for Level 1/Large Early Release Frequency Probabilistic Risk Assessment for Nuclear Power Plant Applications [B1], which outlines high level requirements for HRAs to be included in PRAs. The NRC published Good Practices for Implementing Human Reliability Analysis [B13], which serves as a reference for desirable, but not required aspects of HRA. These three guidelines and numerous recommended practices found in specific HRA methods and texts, complement, but do not replace, IEEE Std 1082. For example, SHARP1 [B4] elaborates on quantifying the HRA for inclusion in PRA but does not include the entire HRA

¹The numbers in brackets correspond to those of the bibliography in Annex B.

²NUREG publications are available from the U.S. Nuclear Regulatory Commission (<http://www.nrc.gov>).

³EPRI publications are available from the Electric Power Research Institute (<http://epri.com>).

process of IEEE Std 1082. The ASME PRA standard [B1] articulates quality requirements for HRA but does not specify how the HRA should be conducted.⁴ NRC's good practices [B13] parallel many aspects of IEEE Std 1082 but does not provide an overall process flow for conducting HRA. IEEE Std 1082 remains relevant as an overarching standard framework for conducting HRA.

IEEE Std 1082 is a method-neutral approach. It is beyond the scope of this guide to enumerate how the guidance can be tied into different HRA methods. Recent reviews of HRA methods may be found in [B1], [B3], [B14], [B15], and [B16]. HRA method development has been extensive, with new approaches that address cognition, context, errors of commission, as well as approaches that span simplified HRA quantification, to dynamic models of human performance. The framework for integrating HRA into PRA as outlined in this guide should apply across HRA methods, although some adaptations may be necessary to meet the unique requirements of specific methods. Such adaptations, especially when using simplified HRA methods, should not come as efficiencies at the expense of performing an integrated and complete HRA process.

⁴ASME publications are available from the American Society of Mechanical Engineers (<http://www.asme.org/>).

IEEE Guide for Incorporating Human Reliability Analysis into Probabilistic Risk Assessments for Nuclear Power Generating Stations and Other Nuclear Facilities

1. Overview

1.1 Scope

This guide provides a structured framework for the incorporation of human reliability analysis (HRA) into probabilistic risk assessments (PRAs).

1.2 Purpose

The purpose of this guide is to enhance the analysis of human-system interactions in PRAs, to help ensure reproducible conclusions, and to standardize the documentation of such assessments. To do this, a specific HRA framework is developed from standard practices to serve as a benchmark to assess alternative ways of incorporating HRA into PRA.