



IEC TR 60919-2

Edition 2.2 2020-04
CONSOLIDATED VERSION

TECHNICAL REPORT



**Performance of high-voltage direct current (HVDC) systems with line-commutated converters –
Part 2: Faults and switching**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.200; 29.240.99

ISBN 978-2-8322-8263-2

Warning! Make sure that you obtained this publication from an authorized distributor.

REDLINE VERSION



Performance of high-voltage direct current (HVDC) systems with line-commutated converters – Part 2: Faults and switching



CONTENTS

FOREWORD.....	6
1 Scope.....	8
2 Normative references	9
3 Outline of HVDC transient performance specifications.....	9
3.1 Transient performance specifications	9
3.2 General comment.....	10
4 Switching transients without faults.....	10
4.1 General.....	10
4.2 Energization and de-energization of a.c. side equipment.....	10
4.3 Load rejection	12
4.4 Start-up and shut-down of converter units	13
4.5 Operation of d.c. breakers and d.c. switches	13
5 AC system faults	16
5.1 General.....	16
5.2 Fault categories	16
5.3 Specification matters affecting transient performance.....	16
5.3.1 Effective a.c. system impedance.....	16
5.3.2 Power transfer during faults.....	17
5.3.3 Recovery following fault clearing	17
5.3.4 Reactive power consumption during fault and post-fault recovery periods	18
5.3.5 Load rejection due to a.c. faults.....	18
5.3.6 Switching of reactive power equipment.....	19
5.3.7 Effects of harmonic voltages and current during faults.....	19
5.3.8 Shift in control modes of operation	20
5.3.9 Power modulation on the HVDC system.....	20
5.3.10 Emergency power reductions.....	20
5.4 Specification impact on control strategy	20
6 AC filters, reactive power equipment and a.c. bus faults	22
6.1 General.....	22
6.2 Transient overvoltages in filter banks	22
6.3 Transient overcurrents in filter and capacitor banks.....	23
6.4 Capacitor unbalance protection	23
6.5 Examples of protection of filters and capacitor banks	24
6.6 Shunt reactor protection	25
6.7 AC bus protection.....	25
7 Converter unit faults	27
7.1 General.....	27
7.2 Short circuits	27
7.3 Failure of converter unit to perform its intended function	29
7.3.1 General	29
7.3.2 Rectifier operation	29
7.3.3 Inverter operation	29
7.4 Converter unit protection	30
7.4.1 Converter differential protection.....	30
7.4.2 Overcurrent protection.....	30

7.4.3	AC overvoltage protection	30
7.4.4	Protection against large delay angle operation	30
7.4.5	Commutation failure protection	30
7.4.6	Thyristor valve protections.....	30
7.4.7	Transformer protection	30
7.4.8	Transformer tap-changer unbalance protection.....	31
7.4.9	AC connection earth fault protection	31
7.5	Additional protection aspects of series connected converter units	31
7.6	Additional protection aspects of parallel connected converter units	31
8	DC reactor, d.c. filter and other d.c. equipment faults	34
8.1	General	34
8.2	Fault types	34
8.3	Protection zones	34
8.4	Neutral protection.....	35
8.4.1	General	35
8.4.2	Neutral fault detection	35
8.4.3	Neutral bus fault isolation	35
8.4.4	Bipolar neutral bus faults	35
8.5	DC reactor protection	36
8.6	DC harmonic filter protection	36
8.6.1	General	36
8.6.2	Filter bank fault protection	36
8.6.3	DC filter capacitor unit protection.....	37
8.7	DC harmonic protection	37
8.8	DC overvoltage protection	37
8.9	DC side switching protection	37
9	DC line faults.....	40
9.1	Overhead line faults	40
9.2	Cable faults	41
9.3	DC fault characteristics	41
9.4	Functional d.c. fault detection requirements	41
9.5	Protective sequence	42
9.5.1	Overhead line faults	42
9.5.2	Faults in cable systems	42
9.5.3	Faults in an overhead line/cable system	42
9.5.4	Faults in one of a system of parallel-connected cables	42
9.5.5	Fault in a system of parallel overhead lines	43
9.6	Fault protection schemes	43
9.7	Open circuit on the d.c. side	43
9.8	Power line cross protection	44
10	Earth electrode line faults.....	44
10.1	General	44
10.2	Specific requirements – Earth electrode line.....	44
10.3	Electrode line supervision	45
11	Metallic return conductor faults.....	45
11.1	Conductor for the return circuit.....	45
11.2	Metallic return faults.....	45
11.3	Fault detection – Metallic return	46

11.4	Metallic return fault protection systems.....	46
12	Insulation co-ordination – HVDC systems	49
12.1	General	49
12.2	Protection schemes using surge arresters	49
12.3	Switching overvoltages and temporary overvoltages on the a.c. side.....	50
12.4	Switching overvoltages and temporary overvoltages on the d.c. side.....	50
12.5	Lightning and steep fronted surges.....	50
12.6	Protective margins	51
12.7	Arrester duties.....	52
12.7.1	AC bus arresters (A_1 , A_2 and A_3).....	52
12.7.2	Arrester across filter reactors (FA).....	52
12.7.3	Valve arresters (V)	53
12.7.4	Mid-point d.c. bus arrester (M).....	53
12.7.5	Converter unit d.c. bus arresters (CB) and converter unit arresters.....	53
12.7.6	DC bus and d.c. line arresters (DB and DL)	53
12.7.7	Neutral bus arresters (E_1 and E_2)	54
12.7.8	DC reactor arrester (R).....	54
12.7.9	DC filter arresters (FD).....	54
12.8	Prevention of protective relay action due to arrester currents	54
12.9	Insulation clearances.....	54
12.10	Creepage distances for the insulation.....	54
12.10.1	Outdoor insulation	54
12.10.2	Indoor insulation	55
13	Telecommunication requirements	59
13.1	General	59
13.2	Specific requirements - Telecommunication systems	59
13.3	Consequence of telecommunication system outages	60
13.4	Special considerations for power line carrier (PLC) systems.....	60
14	Auxiliary systems.....	61
14.1	General	61
14.2	Electrical auxiliary systems	61
14.2.1	General requirements	61
14.2.2	Specific requirements	62
14.3	Mechanical auxiliary systems	63
	Bibliography.....	65

Figure 1	– DC-side switches for an HVDC substation with series-connected converter unit.....	15
Figure 2	– Example of voltage dependent control characteristics	21
Figure 3	– Example of arrangement of a.c. filters and capacitor and reactor banks for large bipolar HVDC	25
Figure 4	– Example of current transformer arrangements for a.c. filters and a.c. bus differential protections	26
Figure 5	– Example of restricted ground fault protection of filter.....	26
Figure 6	– Example of current transformers arrangement for capacitor bank unbalance protection and overload protection of double tuned filter arm	27
Figure 7	– Examples of a.c. phase short circuits, pole short circuits and faults in a twelve-pulse converter unit	33

Figure 8 – Protection zones in series-connected converter units	33
Figure 9 – Protection zones in parallel-connected converter units	34
Figure 10 – Example of d.c. protection zones for series-connected converter units	38
Figure 11 – Example of d.c. protection zones for parallel-connected converter pole	40
Figure 12 – Monopolar metallic return system showing metallic return transfer breaker (MRTB)	47
Figure 13 – Monopolar operation of a bipolar system during converter pole outages	47
Figure 14 – DC current flowing into an a.c. system during a fault on a metallic return conductor when the HVDC substation mat is used for grounding of the d.c. circuit	47
Figure 15 – Earth current flowing during line faults	48
Figure 16 – Example of metallic return fault detection system by means of auxiliary a.c. signal	48
Figure 17 – Example of use of MRTB to quench fault to earth on metallic return conductor	49
Figure 18 – Example of an arrester protection scheme for an HVDC substation	56
Figure 19 – Example of a d.c. arrester protection scheme for a back to back HVDC substation	57
Figure 20 – Example of an arrester protection arrangement for a capacitor commutated converter HVDC substation	58
Figure 21 – Example of an a.c. arrester protection arrangement for an HVDC substation	58
Figure 22 – Example of an arrester protection scheme in a HVDC substation with series-connected converters	59

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**PERFORMANCE OF HIGH-VOLTAGE DIRECT CURRENT
(HVDC) SYSTEMS WITH LINE-COMMUTATED CONVERTERS –****Part 2: Faults and switching**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendments has been prepared for user convenience.

IEC TR 60919-2 edition 2.2 contains the second edition (2008-11) [documents 22F/160/DTR and 22F/165/RVC], its amendment 1 (2015-06) [documents 22F/344/DTR and 22F/345A/RVC] and its amendment 2 (2020-04) [documents 22F/561/DTR and 22F/575/RVDTR].

In this Redline version, a vertical line in the margin shows where the technical content is modified by amendments 1 and 2. Additions are in green text, deletions are in strikethrough red text. A separate Final version with all changes accepted is available in this publication.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC 60919-2, which is a technical report, has been prepared by subcommittee 22F: Power electronics for electrical transmission and distribution systems, of IEC technical committee 22: Power electronic systems and equipment.

This edition includes the following main changes with respect to the previous edition:

- a) this report concerns only line-commutated converters;
- b) significant changes have been made to the control system technology;
- c) some environmental constraints, for example audible noise limits, have been added;
- d) the capacitor coupled converters (CCC) and controlled series capacitor converters (CSCC) have been included.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 60919 series, under the general title: *Performance of high-voltage direct current (HVDC) systems with line-commutated converters*, can be found on the IEC website.

The committee has decided that the contents of the base publication and its amendments will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

PERFORMANCE OF HIGH-VOLTAGE DIRECT CURRENT (HVDC) SYSTEMS WITH LINE-COMMUTATED CONVERTERS –

Part 2: Faults and switching

1 Scope

This part of IEC 60919 which is a technical report provides guidance on the transient performance and fault protection requirements of high voltage direct current (HVDC) systems. It concerns the transient performance related to faults and switching for two-terminal HVDC systems utilizing 12-pulse converter units comprised of three-phase bridge (double way) connections but it does not cover multi-terminal HVDC transmission systems. However, certain aspects of parallel converters and parallel lines, if part of a two-terminal system, are discussed. The converters are assumed to use thyristor valves as the bridge arms, with gapless metal oxide arresters for insulation co-ordination and to have power flow capability in both directions. Diode valves are not considered in this report.

Only line-commutated converters are covered in this report, which includes capacitor commutated converter circuit configurations. General requirements for semiconductor line-commutated converters are given in IEC 60146-1-1, IEC 60146-1-2 and IEC 60146-1-3. Voltage-sourced converters are not considered.

The report is comprised of three parts. IEC 60919-2, which covers transient performance, will be accompanied by companion documents, IEC 60919-1 for steady-state performance and IEC 60919-3 for dynamic performance. An effort has been made to avoid duplication in the three parts. Consequently users of this report are urged to consider all three parts when preparing a specification for purchase of a two-terminal HVDC system.

Readers are cautioned to be aware of the difference between system performance specifications and equipment design specifications for individual components of a system. While equipment specifications and testing requirements are not defined herein, attention is drawn to those which could affect performance specifications for a system. Note that detailed seismic performance requirements are excluded from this technical report. In addition, because of the many possible variations between different HVDC systems, these are not considered in detail. Consequently this report should not be used directly as a specification for a specific project, but rather to provide the basis for an appropriate specification tailored to fit actual system requirements for a particular electric power transmission scheme. This report does not intend to discriminate the responsibility of users and manufacturers for the work specified.

Terms and definitions for high-voltage direct current (HVDC) transmission used in this report are given in IEC 60633.

Since the equipment items are usually separately specified and purchased, the HVDC transmission line, earth electrode line and earth electrode are included only because of their influence on the HVDC system performance.

For the purpose of this report, an HVDC substation is assumed to consist of one or more converter units installed in a single location together with buildings, reactors, filters, reactive power supply, control, monitoring, protective, measuring and auxiliary equipment. While there is no discussion of a.c. switching substations in this report, a.c. filters and reactive power sources are included, although they may be connected to an a.c. bus separate from the HVDC substation.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60146-1-1, *Semiconductor converters – General requirements and line commutated converters – Part 1-1: Specifications of basic requirements*
Amendment 1 (1996)

IEC 60146-1-2, *Semiconductor converters – General requirements and line commutated converters – Part 1-2: Application guide*

IEC 60146-1-3, *Semiconductor converters – General requirements and line commutated converters – Part 1-3: Transformers and reactors*

IEC 60633, *Terminology for high-voltage direct current (HVDC) transmission*

IEC 60071-1, *Insulation co-ordination – Part 1: Terms, definitions, principles and rules*

IEC 60700-1, *Thyristor valves for high-voltage direct current (HVDC) power transmission – Part 1: Electrical testing*

IEC TR 60919-1:20052010, *Performance of high-voltage direct current (HVDC) systems with line-commutated converters – Part 1: Steady-state conditions*
Amendment 1:2013

IEC TR 60919-3:2009, *Performance of high-voltage direct current (HVDC) systems with line-commutated converters – Part 3: Dynamic conditions*

FINAL VERSION



Performance of high-voltage direct current (HVDC) systems with line-commutated converters – Part 2: Faults and switching



CONTENTS

FOREWORD.....	6
1 Scope.....	8
2 Normative references	9
3 Outline of HVDC transient performance specifications.....	9
3.1 Transient performance specifications	9
3.2 General comment.....	10
4 Switching transients without faults.....	10
4.1 General.....	10
4.2 Energization and de-energization of a.c. side equipment.....	10
4.3 Load rejection	12
4.4 Start-up and shut-down of converter units	13
4.5 Operation of d.c. breakers and d.c. switches	13
5 AC system faults	15
5.1 General.....	15
5.2 Fault categories	16
5.3 Specification matters affecting transient performance.....	16
5.3.1 Effective a.c. system impedance.....	16
5.3.2 Power transfer during faults.....	16
5.3.3 Recovery following fault clearing	17
5.3.4 Reactive power consumption during fault and post-fault recovery periods	18
5.3.5 Load rejection due to a.c. faults.....	18
5.3.6 Switching of reactive power equipment.....	19
5.3.7 Effects of harmonic voltages and current during faults.....	19
5.3.8 Shift in control modes of operation	19
5.3.9 Power modulation on the HVDC system.....	20
5.3.10 Emergency power reductions.....	20
5.4 Specification impact on control strategy	20
6 AC filters, reactive power equipment and a.c. bus faults.....	21
6.1 General.....	21
6.2 Transient overvoltages in filter banks	21
6.3 Transient overcurrents in filter and capacitor banks.....	22
6.4 Capacitor unbalance protection	22
6.5 Examples of protection of filters and capacitor banks	23
6.6 Shunt reactor protection	24
6.7 AC bus protection.....	24
7 Converter unit faults	26
7.1 General.....	26
7.2 Short circuits	27
7.3 Failure of converter unit to perform its intended function	28
7.3.1 General	28
7.3.2 Rectifier operation	28
7.3.3 Inverter operation	29
7.4 Converter unit protection	29
7.4.1 Converter differential protection.....	29
7.4.2 Overcurrent protection.....	29

7.4.3	AC overvoltage protection	29
7.4.4	Protection against large delay angle operation	29
7.4.5	Commutation failure protection	29
7.4.6	Thyristor valve protections.....	30
7.4.7	Transformer protection	30
7.4.8	Transformer tap-changer unbalance protection.....	30
7.4.9	AC connection earth fault protection	30
7.5	Additional protection aspects of series connected converter units	30
7.6	Additional protection aspects of parallel connected converter units	31
8	DC reactor, d.c. filter and other d.c. equipment faults	33
8.1	General	33
8.2	Fault types	34
8.3	Protection zones	34
8.4	Neutral protection.....	34
8.4.1	General	34
8.4.2	Neutral fault detection	34
8.4.3	Neutral bus fault isolation	35
8.4.4	Bipolar neutral bus faults	35
8.5	DC reactor protection	35
8.6	DC harmonic filter protection	35
8.6.1	General	35
8.6.2	Filter bank fault protection	36
8.6.3	DC filter capacitor unit protection.....	36
8.7	DC harmonic protection	36
8.8	DC overvoltage protection	36
8.9	DC side switching protection	37
9	DC line faults.....	38
9.1	Overhead line faults	38
9.2	Cable faults	39
9.3	DC fault characteristics	39
9.4	Functional d.c. fault detection requirements	39
9.5	Protective sequence	40
9.5.1	Overhead line faults	40
9.5.2	Faults in cable systems	40
9.5.3	Faults in an overhead line/cable system	40
9.5.4	Faults in one of a system of parallel-connected cables	40
9.5.5	Fault in a system of parallel overhead lines	41
9.6	Fault protection schemes	41
9.7	Open circuit on the d.c. side	41
9.8	Power line cross protection	42
10	Earth electrode line faults.....	42
10.1	General	42
10.2	Specific requirements – Earth electrode line.....	42
10.3	Electrode line supervision	43
11	Metallic return conductor faults.....	43
11.1	Conductor for the return circuit.....	43
11.2	Metallic return faults.....	43
11.3	Fault detection – Metallic return	44

11.4	Metallic return fault protection systems.....	44
12	Insulation co-ordination – HVDC systems	47
12.1	General	47
12.2	Protection schemes using surge arresters	47
12.3	Switching overvoltages and temporary overvoltages on the a.c. side.....	48
12.4	Switching overvoltages and temporary overvoltages on the d.c. side.....	48
12.5	Lightning and steep fronted surges.....	48
12.6	Protective margins	49
12.7	Arrester duties.....	50
12.7.1	AC bus arresters (A_1 , A_2 and A_3).....	50
12.7.2	Arrester across filter reactors (FA).....	50
12.7.3	Valve arresters (V)	51
12.7.4	Mid-point d.c. bus arrester (M).....	51
12.7.5	Converter unit d.c. bus arresters (CB) and converter unit arresters.....	51
12.7.6	DC bus and d.c. line arresters (DB and DL)	51
12.7.7	Neutral bus arresters (E_1 and E_2)	52
12.7.8	DC reactor arrester (R).....	52
12.7.9	DC filter arresters (FD).....	52
12.8	Prevention of protective relay action due to arrester currents	52
12.9	Insulation clearances.....	52
12.10	Creepage distances for the insulation.....	52
12.10.1	Outdoor insulation	52
12.10.2	Indoor insulation	53
13	Telecommunication requirements	57
13.1	General	57
13.2	Specific requirements - Telecommunication systems	57
13.3	Consequence of telecommunication system outages	58
13.4	Special considerations for power line carrier (PLC) systems.....	58
14	Auxiliary systems.....	59
14.1	General	59
14.2	Electrical auxiliary systems	59
14.2.1	General requirements	59
14.2.2	Specific requirements	60
14.3	Mechanical auxiliary systems	61
	Bibliography.....	63
	Figure 1 – DC-side switches for an HVDC substation with series-connected converter unit.....	15
	Figure 2 – Example of voltage dependent control characteristics	21
	Figure 3 – Example of arrangement of a.c. filters and capacitor and reactor banks for large bipolar HVDC	25
	Figure 4 – Example of current transformer arrangements for a.c. filters and a.c. bus differential protections	25
	Figure 5 – Example of restricted ground fault protection of filter.....	26
	Figure 6 – Example of current transformers arrangement for capacitor bank unbalance protection and overload protection of double tuned filter arm	26
	Figure 7 – Examples of a.c. phase short circuits, pole short circuits and faults in a twelve-pulse converter unit	32

Figure 8 – Protection zones in series-connected converter units	33
Figure 9 – Protection zones in parallel-connected converter units	33
Figure 10 – Example of d.c. protection zones for series-connected converter units	37
Figure 11 – Example of d.c. protection zones for parallel-connected converter pole	38
Figure 12 – Monopolar metallic return system showing metallic return transfer breaker (MRTB)	45
Figure 13 – Monopolar operation of a bipolar system during converter pole outages	45
Figure 14 – DC current flowing into an a.c. system during a fault on a metallic return conductor when the HVDC substation mat is used for grounding of the d.c. circuit	45
Figure 15 – Earth current flowing during line faults	46
Figure 16 – Example of metallic return fault detection system by means of auxiliary a.c. signal	46
Figure 17 – Example of use of MRTB to quench fault to earth on metallic return conductor	47
Figure 18 – Example of an arrester protection scheme for an HVDC substation	54
Figure 19 – Example of a d.c. arrester protection scheme for a back to back HVDC substation	55
Figure 20 – Example of an arrester protection arrangement for a capacitor commutated converter HVDC substation	56
Figure 21 – Example of an a.c. arrester protection arrangement for an HVDC substation	56
Figure 22 – Example of an arrester protection scheme in a HVDC substation with series-connected converters	57

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**PERFORMANCE OF HIGH-VOLTAGE DIRECT CURRENT
(HVDC) SYSTEMS WITH LINE-COMMUTATED CONVERTERS –****Part 2: Faults and switching**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendments has been prepared for user convenience.

IEC TR 60919-2 edition 2.2 contains the second edition (2008-11) [documents 22F/160/DTR and 22F/165/RVC], its amendment 1 (2015-06) [documents 22F/344/DTR and 22F/345A/RVC] and its amendment 2 (2020-04) [documents 22F/561/DTR and 22F/575/RVDTR].

This Final version does not show where the technical content is modified by amendments 1 and 2. A separate Redline version with all changes highlighted is available in this publication.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC 60919-2, which is a technical report, has been prepared by subcommittee 22F: Power electronics for electrical transmission and distribution systems, of IEC technical committee 22: Power electronic systems and equipment.

This edition includes the following main changes with respect to the previous edition:

- a) this report concerns only line-commutated converters;
- b) significant changes have been made to the control system technology;
- c) some environmental constraints, for example audible noise limits, have been added;
- d) the capacitor coupled converters (CCC) and controlled series capacitor converters (CSCC) have been included.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 60919 series, under the general title: *Performance of high-voltage direct current (HVDC) systems with line-commutated converters*, can be found on the IEC website.

The committee has decided that the contents of the base publication and its amendments will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

PERFORMANCE OF HIGH-VOLTAGE DIRECT CURRENT (HVDC) SYSTEMS WITH LINE-COMMUTATED CONVERTERS –

Part 2: Faults and switching

1 Scope

This part of IEC 60919 which is a technical report provides guidance on the transient performance and fault protection requirements of high voltage direct current (HVDC) systems. It concerns the transient performance related to faults and switching for two-terminal HVDC systems utilizing 12-pulse converter units comprised of three-phase bridge (double way) connections but it does not cover multi-terminal HVDC transmission systems. However, certain aspects of parallel converters and parallel lines, if part of a two-terminal system, are discussed. The converters are assumed to use thyristor valves as the bridge arms, with gapless metal oxide arresters for insulation co-ordination and to have power flow capability in both directions. Diode valves are not considered in this report.

Only line-commutated converters are covered in this report, which includes capacitor commutated converter circuit configurations. General requirements for semiconductor line-commutated converters are given in IEC 60146-1-1, IEC 60146-1-2 and IEC 60146-1-3. Voltage-sourced converters are not considered.

The report is comprised of three parts. IEC 60919-2, which covers transient performance, will be accompanied by companion documents, IEC 60919-1 for steady-state performance and IEC 60919-3 for dynamic performance. An effort has been made to avoid duplication in the three parts. Consequently users of this report are urged to consider all three parts when preparing a specification for purchase of a two-terminal HVDC system.

Readers are cautioned to be aware of the difference between system performance specifications and equipment design specifications for individual components of a system. While equipment specifications and testing requirements are not defined herein, attention is drawn to those which could affect performance specifications for a system. Note that detailed seismic performance requirements are excluded from this technical report. In addition, because of the many possible variations between different HVDC systems, these are not considered in detail. Consequently this report should not be used directly as a specification for a specific project, but rather to provide the basis for an appropriate specification tailored to fit actual system requirements for a particular electric power transmission scheme. This report does not intend to discriminate the responsibility of users and manufacturers for the work specified.

Terms and definitions for high-voltage direct current (HVDC) transmission used in this report are given in IEC 60633.

Since the equipment items are usually separately specified and purchased, the HVDC transmission line, earth electrode line and earth electrode are included only because of their influence on the HVDC system performance.

For the purpose of this report, an HVDC substation is assumed to consist of one or more converter units installed in a single location together with buildings, reactors, filters, reactive power supply, control, monitoring, protective, measuring and auxiliary equipment. While there is no discussion of a.c. switching substations in this report, a.c. filters and reactive power sources are included, although they may be connected to an a.c. bus separate from the HVDC substation.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60146-1-1, *Semiconductor converters – General requirements and line commutated converters – Part 1-1: Specifications of basic requirements*
Amendment 1 (1996)

IEC 60146-1-2, *Semiconductor converters – General requirements and line commutated converters – Part 1-2: Application guide*

IEC 60146-1-3, *Semiconductor converters – General requirements and line commutated converters – Part 1-3: Transformers and reactors*

IEC 60633, *Terminology for high-voltage direct current (HVDC) transmission*

IEC 60071-1, *Insulation co-ordination – Part 1: Terms, definitions, principles and rules*

IEC 60700-1, *Thyristor valves for high-voltage direct current (HVDC) power transmission – Part 1: Electrical testing*

IEC TR 60919-1:2010, *Performance of high-voltage direct current (HVDC) systems with line-commutated converters – Part 1: Steady-state conditions*
Amendment 1:2013

IEC TR 60919-3:2009, *Performance of high-voltage direct current (HVDC) systems with line-commutated converters – Part 3: Dynamic conditions*