



IEC TR 61850-90-7

Edition 2.0 2023-08
REDLINE VERSION

TECHNICAL REPORT



**Communication networks and systems for power utility automation –
Part 90-7: Object models for power converters in distributed energy resources
(DER) systems**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 33.200

ISBN 978-2-8322-7452-1

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	7
1 Scope.....	9
2 Normative references	9
3 Terms, definitions, acronyms and abbreviated terms	10
3.1 Terms and definitions.....	10
3.2 Acronyms.....	10
3.3 Abbreviated terms.....	15
4 Overview of power converter-based DER functions.....	15
4.1 General.....	16
4.2 Power converter configurations and interactions	17
4.3 Power converter methods	19
4.4 Power converter functions.....	20
4.5 Differing DER architectures.....	21
4.5.1 Conceptual architecture: electrical coupling point (ECP).....	21
4.5.2 Conceptual architecture: point of common coupling (PCC).....	21
4.5.3 Utility interactions directly with power converters or indirectly via a customer EMS	22
4.5.4 Communication profiles	22
4.6 General sequence of information exchange interactions.....	23
5 Concepts and constructs for managing power converter functions	24
5.1 Basic settings of power converters.....	24
5.1.1 Nameplate values versus basic settings	24
5.1.2 Power factor and power converter quadrants	24
5.1.3 Maximum watts, vars, and volt-amp settings	26
5.1.4 Active power ramp rate settings.....	28
5.1.5 Voltage phase and correction settings	28
5.1.6 Charging settings.....	28
5.1.7 Example of basic settings	29
5.1.8 Basic setting process.....	29
5.2 Modes for managing autonomous behaviour	29
5.2.1 Benefits of modes to manage DER at ECPs.....	29
5.2.2 Modes using curves to describe behaviour	30
5.2.3 Paired arrays to describe mode curves	31
5.2.4 Percentages as size-neutral parameters: voltage and var calculations.....	32
5.2.5 Hysteresis as values cycle within mode curves	33
5.2.6 Low pass exponential time rate.....	34
5.2.7 Ramp rates.....	35
5.2.8 Randomized response times.....	35
5.2.9 Timeout period	35
5.2.10 Multiple curves for a mode.....	35
5.2.11 Multiple modes	35
5.2.12 Use of modes for loosely coupled, autonomous actions	36
5.3 Schedules for establishing time-based behaviour.....	36
5.3.1 Purpose of schedules	36
5.3.2 Schedule components	36
6 DER management functions for power converters.....	38
6.1 Immediate control functions for power converters	38

6.1.1	General	38
6.1.2	Function INV1: connect / disconnect from grid	38
6.1.3	Function INV2: adjust maximum generation level up/down	39
6.1.4	Function INV3: adjust power factor	39
6.1.5	Function INV4: request active power (charge or discharge storage).....	40
6.1.6	Function INV5: pricing signal for charge/discharge action	41
6.2	Modes for volt-var management	41
6.2.1	VAr management modes using volt-var arrays	41
6.2.2	Example setting volt-var mode VV11: available var support mode with no impact on watts.....	42
6.2.3	Example setting volt-var mode VV12: maximum var support mode based on WMax.....	44
6.2.4	Example setting volt-var mode VV13: static power converter mode based on settings	45
6.2.5	Example setting volt-var mode VV14: passive mode with no var support.....	46
6.3	Modes for frequency-related behaviours	47
6.3.1	Frequency management modes	47
6.3.2	Frequency-watt mode FW21: high frequency reduces active power	48
6.3.3	Frequency-watt mode FW22: constraining generating/charging by frequency	50
6.4	Dynamic reactive current support during abnormally high or low voltage levels	53
6.4.1	Purpose of dynamic reactive current support	53
6.4.2	Dynamic reactive current support mode TV31: support during abnormally high or low voltage levels	53
6.5	Low/high voltage ride-through curves for “must disconnect” and “must remain connected” zones	57
6.5.1	Purpose of L/HVRT.....	57
6.5.2	“Must disconnect” (MD) and “must remain connected” (MRC) curves	57
6.6	Modes for watt-triggered behaviours	59
6.6.1	Watt-power factor mode WP41: feed-in power controls power factor	59
6.6.2	Alternative watt-power factor mode WP42: feed-in power controls power factor	59
6.7	Modes for voltage-watt management.....	60
6.7.1	Voltage-watt mode VW51: voltage-watt management: generating by voltage	60
6.7.2	Voltage-watt mode VW52: voltage-watt management: charging by voltage	60
6.8	Modes for behaviours triggered by non-power parameters	61
6.8.1	Temperature mode TMP	61
6.8.2	Pricing signal mode PS.....	61
6.9	Setting and reporting functions	62
6.9.1	Purpose of setting and reporting functions	62
6.9.2	Establishing settings DS91: modify power converter-based DER settings.....	62
6.9.3	Event logging DS92: log alarms and events, retrieve logs.....	62
6.9.4	Reporting status DS93: selecting status points, establishing reporting mechanisms	66
7.9.5	Time synchronization DS94: time synchronization requirements
8	IEC 61850 information models for power converter-based functions
8.1	Overall structure of IEC 61850

8.2 IEC 61850 system logical nodes

8.3 Key components of IEC 61850 information modelling of power converter-based functions.....

 8.3.1 Subsets of 61850 models for power converter-based DER functions.....

 8.3.2 Types of interactions for settings, functions, and modes

 8.3.3 Key common data classes (CDCs).....

 8.3.4 Messaging services

 8.3.5 Message errors.....

8.4 Basic settings in IEC 61850

 8.4.1 Logical nodes for basic settings.....

 8.4.2 IEC 61850 models for basic settings.....

8.5 Mode settings in IEC 61850

 8.5.1 Logical nodes for establishing and managing modes

 8.5.2 IEC 61850 models for modes.....

8.6 Schedules in IEC 61850.....

 8.6.1 Scheduling structures

 8.6.2 IEC 61850 models for schedules

8.7 Immediate control functions in IEC 61850

 8.7.1 IEC 61850 models for INV1: connect/disconnect.....

 8.7.2 IEC 61850 models for INV2: adjust maximum generation level up/down.....

 8.7.3 IEC 61850 models for INV3: adjust power factor.....

 8.7.4 IEC 61850 models for INV4: charge/discharge storage.....

 8.7.5 IEC 61850 models for INV5: pricing signal for charge/discharge of storage.....

8.8 Volt var management modes in IEC 61850

 8.8.1 IEC 61850 models for VV11 – VV12: volt var curve settings

 8.8.2 IEC 61850 models for VV13 – VV14: volt var parameter settings.....

8.9 Frequency-related modes in IEC 61850

 8.9.1 IEC 61850 for FW21: frequency-driven active power modification.....

 8.9.2 IEC 61850 for FW22: Frequency watt mode FW22: generating/charging by frequency.....

8.10 Voltage management modes in IEC 61850.....

 8.10.1 IEC 61850 for TV31: dynamic reactive current support

 8.10.2 IEC 61850 for “must disconnect”.....

 8.10.3 IEC 61850 for “must remain connected”.....

8.11 Watt triggered behaviour modes in IEC 61850

 8.11.1 IEC 61850 for WP41 and WP42: feed-in watts control of power factor

8.12 Voltage-watt management modes in IEC 61850

 8.12.1 IEC 61850 for VW51: voltage-watt management in generation and charging

8.13 Non-power mode behaviours in IEC 61850

 8.13.1 IEC 61850 models for temperature mode TMP.....

 8.13.2 IEC 61850 models for pricing signal mode PS

8.14 IEC 61850 reporting commands.....

 8.14.1 IEC 61850 models for DS91: modify DER settings.....

 8.14.2 IEC 61850 models for DS92: event/history logging

 8.14.3 IEC 61850 models for DS93: status reporting

Figure 1 – DER management hierarchical interactions: autonomous, loosely-coupled, broadcast/multicast..... 19

Figure 2 – Electrical Connection Points (ECP) and Point of Common Coupling (PCC) 22

Figure 3 – Producer and Consumer Reference Frame conventions 25

Figure 4 – EEI power factor sign convention 26

Figure 5 – Working areas for different modes..... 27

Figure 6 – Example of voltage offsets (V_{RefOfs}) with respect to the reference voltage (V_{Ref})..... 28

Figure 7 – Example of modes associated with different ECPs 30

Figure 8 – Example of a volt-var mode curve 31

Figure 9 – Example of hysteresis in volt-var curves..... 33

Figure 10 – Example of deadband in volt-var curves 34

Figure 11 – Local function block diagram 34

Figure 12 – Time domain response of first order low pass filter 35

Figure 13 – Interrelationships of schedule controllers, schedules, and schedule references 37

Figure 14 – Volt-var mode VV11 – available vars mode 43

Figure 15 – Power converter mode VV12 – Maximum var support mode based on W_{Max} 44

Figure 16 – Power converter mode VV13 – Example: static var support mode based on V_{ArMax} 46

Figure 17 – Frequency-watt mode curves..... 48

Figure 18 – Frequency-based active power reduction 49

Figure 19 – Frequency-based active power modification with the use of an array..... 50

Figure 20 – Example of a basic frequency-watt mode configuration 51

Figure 21 – Example array settings with hysteresis 52

Figure 22 – Example of an asymmetrical hysteresis configuration 52

Figure 23 – Example array configuration for absorbed watts vs. frequency 53

Figure 24 – Basic concepts of the dynamic reactive current support function 54

Figure 25 – Calculation of delta voltage over the filter time window..... 54

Figure 26 – Activation zones for dynamic reactive current support 55

Figure 27 – Alternative gradient behaviour, selected by $ArGraMod$ 56

Figure 28 – Settings to define a blocking zone 56

Figure 29 – Must disconnect and must remain connected zones 58

Figure 30 – Examples of “must remain connected” requirements for different regions 58

Figure 31 – Power factor controlled by feed-in power..... 59

Figure 32 – Example configuration curve for maximum watts vs. voltage 60

Figure 33 – Example configuration curve for maximum watts absorbed vs. voltage 61

~~Figure 34 – Structure of the IEC 61850 Parts.....~~

~~Figure 35 – Interrelationships of schedule controllers, schedules, and schedule references.....~~

Table 1 – Producer Reference Frame (PRF) conventions..... 25

Table 2 – Example basic settings for a storage DER unit 29

Table 3 – Events..... 64

Table 4 – Examples of status points.....	66
Table 5 – Interpretation of logical node tables.....
Table 6 – LPHD class.....
Table 7 – Common LN class.....
Table 8 – LLN0 class.....
Table 9 – CDC SPS.....
Table 10 – CDC SPC.....
Table 11 – CDC DPC.....
Table 12 – CDC INC.....
Table 13 – CDC ING.....
Table 14 – CDC ASG.....
Table 15 – CDC ORG.....
Table 16 – CDC CSG.....
Table 17 – Schedule (SCR) common data class specification.....
Table 18 – Service error type definitions.....
Table 19 – LN DRCT – DER controller characteristics.....
Table 20 – LN FMAR – set mode array.....
Table 21 – LN DGSM – issue mode command.....
Table 22 – LN DOPM – operations.....
Table 23 – INV1 – LN CSWI – issue and respond to control.....
Table 24 – LN FWHZ – set power levels by frequency for FW21.....
Table 25 – LN RDGS – dynamic reactive current support for TV31.....
Table 26 – LN FPFW – set power factor by feed-in power for WP41.....
Table 27 – DS92 – IEC 61850 log structure.....
Table 28 – LN DRCS – DER state for DS93.....
Table 29 – DS93 – Status, settings, and measurement points.....

INTERNATIONAL ELECTROTECHNICAL COMMISSION

COMMUNICATION NETWORKS AND SYSTEMS FOR POWER UTILITY AUTOMATION –

Part 90-7: Object models for power converters in distributed energy resources (DER) systems

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This redline version of the official IEC Standard allows the user to identify the changes made to the previous edition IEC TR 61850-90-7:2013. A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text.

IEC TR 61850-90-7 has been prepared by IEC technical committee 57: Power systems management and associated information exchange. It is a Technical Report.

This second edition cancels and replaces the first edition published in 2013. This edition is primarily an editorial revision in order to be consistent with the publication of Edition 2 of IEC 61850-7-420:2021.

This edition includes the following significant changes with respect to the previous edition:

- a) Clause 3 has been updated.
- b) Clause 8 (IEC 61850 information models for power converter-based functions) has been deleted. This clause defined data models with the transitional namespace “(Tr) IEC 61850-90-7:2012”. The data models are now defined in IEC 61850-7-420.

The text of this Technical Report is based on the following documents:

Draft	Report on voting
57/2558/DTR	57/2610/RVDTR

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Technical Report is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts of the IEC 61850 series, under the general title *Communication networks and systems for power utility automation*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

COMMUNICATION NETWORKS AND SYSTEMS FOR POWER UTILITY AUTOMATION –

Part 90-7: Object models for power converters in distributed energy resources (DER) systems

1 Scope

This part of IEC 61850, which is a Technical Report, describes functions for power converter-based distributed energy resources (DER) systems, focused on DC-to-AC and AC-to-AC conversions and including photovoltaic systems (PV), battery storage systems, electric vehicle (EV) charging systems, and any other DER systems with a controllable power converter.

The functions defined in this document were used to help define the ~~IEC 61850~~ information models ~~to described in IEC 61850-7-420 and which can~~ be used in the exchange of information between these power converter-based DER systems and the utilities, energy service providers (ESPs), or other entities which are tasked with managing the volt, var, and watt capabilities of these power converter-based systems.

These power converter-based DER systems can range from very small grid-connected systems at residential customer sites, to medium-sized systems configured as microgrids on campuses or communities, to very large systems in utility-operated power plants, and to many other configurations and ownership models. They may or may not combine different types of DER systems behind the power converter, such as a power converter-based DER system and a battery that are connected at the DC level.

~~The namespace of this document is:~~

~~“(Tr) IEC 61850-90-7:2012”~~

~~The namespace “IEC 61850-90-7” is considered as “transitional” since the models are expected to be included in IEC 61850-7-420. Potential extensions/modifications may happen if/when the models are moved to International Standard status.~~

~~Only the new data objects and CDCs which are represented in **bold-italic font** will be tagged with this namespace name. The others should still refer to the namespace where they are primarily defined.~~

NOTE The term power converter is being used in place of “inverter” since it covers more types of conversion from input to output power:

- AC to DC (rectifier)
- DC to AC (inverter)
- DC to DC (DC-to-DC converter)
- AC to AC (AC-to-AC converter)

2 Normative references

~~The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.~~

~~IEC 61850-7-2, Communication networks and systems for power utility automation—Part 7-2: Basic communication structure—Abstract communication service interface (ACSI)~~

~~IEC 61850-7-3, Communication networks and systems for power utility automation—Part 7-3: Basic communication structure—Common data classes~~

~~IEC 61850-7-4, Communication networks and systems for power utility automation—Part 7-4: Basic communication structure—Compatible logical node classes and data object classes~~

~~IEC 61850-7-410, Communication networks and systems for power utility automation—Part 7-410: Hydroelectric power plants—Communication for monitoring and control~~

~~IEC 61850-7-420, Communication networks and systems for power utility automation—Part 7-420: Basic communication structure—Distributed energy resources logical nodes~~

~~IEC 61850-8-1, Communication networks and systems for power utility automation—Part 8-1: Specific communication service mapping (SCSM)—Mappings to MMS (ISO 9506-1 and ISO 9506-2) and to ISO/IEC 8802-3~~

~~ISO 4217, Codes for the representation of currencies and funds~~

~~EI Handbook for Electricity Metering, 10th Edition (2002), Edison Electric Institute, Washington, D.C.~~

There are no normative references in this document.

TECHNICAL REPORT



**Communication networks and systems for power utility automation –
Part 90-7: Object models for power converters in distributed energy resources
(DER) systems**



CONTENTS

FOREWORD.....	5
1 Scope.....	7
2 Normative references	7
3 Terms, definitions, acronyms and abbreviated terms	7
3.1 Terms and definitions.....	8
3.2 Acronyms.....	10
3.3 Abbreviated terms.....	10
4 Overview of power converter-based DER functions.....	11
4.1 General.....	11
4.2 Power converter configurations and interactions	12
4.3 Power converter methods	14
4.4 Power converter functions.....	15
4.5 Differing DER architectures.....	16
4.5.1 Conceptual architecture: electrical coupling point (ECP).....	16
4.5.2 Conceptual architecture: point of common coupling (PCC).....	16
4.5.3 Utility interactions directly with power converters or indirectly via a customer EMS	17
4.5.4 Communication profiles	17
4.6 General sequence of information exchange interactions.....	18
5 Concepts and constructs for managing power converter functions	19
5.1 Basic settings of power converters.....	19
5.1.1 Nameplate values versus basic settings	19
5.1.2 Power factor and power converter quadrants	19
5.1.3 Maximum watts, vars, and volt-amp settings	21
5.1.4 Active power ramp rate settings	22
5.1.5 Voltage phase and correction settings	23
5.1.6 Charging settings.....	23
5.1.7 Example of basic settings	23
5.1.8 Basic setting process.....	24
5.2 Modes for managing autonomous behaviour	24
5.2.1 Benefits of modes to manage DER at ECPs.....	24
5.2.2 Modes using curves to describe behaviour	25
5.2.3 Paired arrays to describe mode curves	26
5.2.4 Percentages as size-neutral parameters: voltage and var calculations.....	27
5.2.5 Hysteresis as values cycle within mode curves	27
5.2.6 Low pass exponential time rate.....	28
5.2.7 Ramp rates.....	29
5.2.8 Randomized response times.....	29
5.2.9 Timeout period	30
5.2.10 Multiple curves for a mode.....	30
5.2.11 Multiple modes	30
5.2.12 Use of modes for loosely coupled, autonomous actions	30
5.3 Schedules for establishing time-based behaviour.....	30
5.3.1 Purpose of schedules	30
5.3.2 Schedule components	31
6 DER management functions for power converters.....	32
6.1 Immediate control functions for power converters	32

6.1.1	General	32
6.1.2	Function INV1: connect / disconnect from grid	33
6.1.3	Function INV2: adjust maximum generation level up/down	33
6.1.4	Function INV3: adjust power factor	34
6.1.5	Function INV4: request active power (charge or discharge storage).....	34
6.1.6	Function INV5: pricing signal for charge/discharge action	35
6.2	Modes for volt-var management	36
6.2.1	VAr management modes using volt-var arrays	36
6.2.2	Example setting volt-var mode VV11: available var support mode with no impact on watts.....	37
6.2.3	Example setting volt-var mode VV12: maximum var support mode based on WMax.....	38
6.2.4	Example setting volt-var mode VV13: static power converter mode based on settings	40
6.2.5	Example setting volt-var mode VV14: passive mode with no var support.....	41
6.3	Modes for frequency-related behaviours	41
6.3.1	Frequency management modes	41
6.3.2	Frequency-watt mode FW21: high frequency reduces active power	42
6.3.3	Frequency-watt mode FW22: constraining generating/charging by frequency	44
6.4	Dynamic reactive current support during abnormally high or low voltage levels	47
6.4.1	Purpose of dynamic reactive current support	47
6.4.2	Dynamic reactive current support mode TV31: support during abnormally high or low voltage levels	47
6.5	Low/high voltage ride-through curves for “must disconnect” and “must remain connected” zones	51
6.5.1	Purpose of L/HVRT	51
6.5.2	“Must disconnect” (MD) and “must remain connected” (MRC) curves	51
6.6	Modes for watt-triggered behaviours	53
6.6.1	Watt-power factor mode WP41: feed-in power controls power factor	53
6.6.2	Alternative watt-power factor mode WP42: feed-in power controls power factor	53
6.7	Modes for voltage-watt management.....	54
6.7.1	Voltage-watt mode VW51: voltage-watt management: generating by voltage	54
6.7.2	Voltage-watt mode VW52: voltage-watt management: charging by voltage	54
6.8	Modes for behaviours triggered by non-power parameters	55
6.8.1	Temperature mode TMP	55
6.8.2	Pricing signal mode PS.....	55
6.9	Setting and reporting functions	56
6.9.1	Purpose of setting and reporting functions	56
6.9.2	Establishing settings DS91: modify power converter-based DER settings.....	56
6.9.3	Event logging DS92: log alarms and events, retrieve logs.....	56
6.9.4	Reporting status DS93: selecting status points, establishing reporting mechanisms	60
	Bibliography.....	62

Figure 1 – DER management hierarchical interactions: autonomous, loosely-coupled, broadcast/multicast.....	14
Figure 2 – Electrical Connection Points (ECP) and Point of Common Coupling (PCC)	17
Figure 3 – Producer and Consumer Reference Frame conventions	20
Figure 4 – EEI power factor sign convention	21
Figure 5 – Working areas for different modes.....	22
Figure 6 – Example of voltage offsets (V_{RefOfs}) with respect to the reference voltage (V_{Ref}).....	23
Figure 7 – Example of modes associated with different ECPs	25
Figure 8 – Example of a volt-var mode curve	26
Figure 9 – Example of hysteresis in volt-var curves.....	28
Figure 10 – Example of deadband in volt-var curves	28
Figure 11 – Local function block diagram	29
Figure 12 – Time domain response of first order low pass filter.....	29
Figure 13 – Interrelationships of schedule controllers, schedules, and schedule references	32
Figure 14 – Volt-var mode VV11 – available vars mode	37
Figure 15 – Power converter mode VV12 – Maximum var support mode based on W_{Max}	39
Figure 16 – Power converter mode VV13 – Example: static var support mode based on V_{ArMax}	40
Figure 17 – Frequency-watt mode curves.....	42
Figure 18 – Frequency-based active power reduction	43
Figure 19 – Frequency-based active power modification with the use of an array.....	44
Figure 20 – Example of a basic frequency-watt mode configuration	45
Figure 21 – Example array settings with hysteresis	46
Figure 22 – Example of an asymmetrical hysteresis configuration	46
Figure 23 – Example array configuration for absorbed watts vs. frequency	47
Figure 24 – Basic concepts of the dynamic reactive current support function	48
Figure 25 – Calculation of delta voltage over the filter time window.....	48
Figure 26 – Activation zones for dynamic reactive current support	49
Figure 27 – Alternative gradient behaviour, selected by $ArGraMod$	50
Figure 28 – Settings to define a blocking zone	50
Figure 29 – Must disconnect and must remain connected zones	52
Figure 30 – Examples of “must remain connected” requirements for different regions	52
Figure 31 – Power factor controlled by feed-in power.....	53
Figure 32 – Example configuration curve for maximum watts vs. voltage	54
Figure 33 – Example configuration curve for maximum watts absorbed vs. voltage	55
Table 1 – Producer Reference Frame (PRF) conventions.....	19
Table 2 – Example basic settings for a storage DER unit	24
Table 3 – Events.....	58
Table 4 – Examples of status points.....	60

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**COMMUNICATION NETWORKS AND SYSTEMS
FOR POWER UTILITY AUTOMATION –****Part 90-7: Object models for power converters
in distributed energy resources (DER) systems**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC TR 61850-90-7 has been prepared by IEC technical committee 57: Power systems management and associated information exchange. It is a Technical Report.

This second edition cancels and replaces the first edition published in 2013. This edition is primarily an editorial revision in order to be consistent with the publication of Edition 2 of IEC 61850-7-420:2021.

This edition includes the following significant changes with respect to the previous edition:

- a) Clause 3 has been updated.
- b) Clause 8 (IEC 61850 information models for power converter-based functions) has been deleted. This clause defined data models with the transitional namespace “(Tr) IEC 61850-90-7:2012”. The data models are now defined in IEC 61850-7-420.

The text of this Technical Report is based on the following documents:

Draft	Report on voting
57/2558/DTR	57/2610/RVDTR

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Technical Report is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts of the IEC 61850 series, under the general title *Communication networks and systems for power utility automation*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

COMMUNICATION NETWORKS AND SYSTEMS FOR POWER UTILITY AUTOMATION –

Part 90-7: Object models for power converters in distributed energy resources (DER) systems

1 Scope

This part of IEC 61850, which is a Technical Report, describes functions for power converter-based distributed energy resources (DER) systems, focused on DC-to-AC and AC-to-AC conversions and including photovoltaic systems (PV), battery storage systems, electric vehicle (EV) charging systems, and any other DER systems with a controllable power converter.

The functions defined in this document were used to help define the information models described in IEC 61850-7-420 and which can be used in the exchange of information between these power converter-based DER systems and the utilities, energy service providers (ESPs), or other entities which are tasked with managing the volt, var, and watt capabilities of these power converter-based systems.

These power converter-based DER systems can range from very small grid-connected systems at residential customer sites, to medium-sized systems configured as microgrids on campuses or communities, to very large systems in utility-operated power plants, and to many other configurations and ownership models. They may or may not combine different types of DER systems behind the power converter, such as a power converter-based DER system and a battery that are connected at the DC level.

NOTE The term power converter is being used in place of “inverter” since it covers more types of conversion from input to output power:

- AC to DC (rectifier)
- DC to AC (inverter)
- DC to DC (DC-to-DC converter)
- AC to AC (AC-to-AC converter)

2 Normative references

There are no normative references in this document.