

# TECHNICAL REPORT



---

**High-voltage direct current (HVDC) systems – Guidance to the specification and design evaluation of AC filters –  
Part 1: Overview**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

---

ICS 29.200

ISBN 978-2-8322-9986-9

**Warning! Make sure that you obtained this publication from an authorized distributor.**

## CONTENTS

|   |    |
|---|----|
| FOREWORD.....   | 7  |
| INTRODUCTION.....   | 9  |
| 1 Scope.....  | 10 |
| 2 Normative references .....  | 10 |
| 3 Terms and definitions .....   | 10 |
| 4 Outline of specifications of AC filters for HVDC systems.....             | 11 |
| 4.1 General.....  | 11 |
| 4.2 Boundaries of responsibility .....                                      | 12 |
| 4.3 Scope of studies .....  | 14 |
| 4.4 Scope of supply .....   | 14 |
| 4.5 Technical data to be supplied by contractor .....                       | 15 |
| 4.6 Alternative proposals by bidders .....                                  | 15 |
| 5 Permissible distortion limits .....                                       | 16 |
| 5.1 General.....  | 16 |
| 5.2 Voltage distortion.....   | 17 |
| 5.2.1 General .....   | 17 |
| 5.2.2 Definitions of performance criteria .....                             | 17 |
| 5.2.3 Discussion and recommendations.....                                   | 18 |
| 5.2.4 Determination of limits .....   | 18 |
| 5.2.5 Pre-existing harmonic levels.....                                     | 21 |
| 5.2.6 Relaxed limits for short term and infrequent conditions.....          | 22 |
| 5.2.7 Treatment of interharmonic frequencies.....                           | 22 |
| 5.3 Distortion limits pertaining to the HV and EHV network equipment.....   | 23 |
| 5.3.1 HVAC transmission system equipment.....                               | 23 |
| 5.3.2 Harmonic currents in synchronous machines .....                       | 23 |
| 5.3.3 Nearby HVDC installations .....                                       | 24 |
| 5.4 Telephone interference .....  | 24 |
| 5.4.1 General .....   | 24 |
| 5.4.2 Causes of telephone interference .....                                | 24 |
| 5.4.3 Definitions of performance criteria .....                             | 24 |
| 5.4.4 Discussion.....   | 25 |
| 5.4.5 Determination of limits .....   | 25 |
| 5.4.6 Pre-existing harmonic levels .....                                    | 27 |
| 5.4.7 Limits for temporary conditions .....                                 | 27 |
| 5.5 Special criteria.....   | 28 |
| 6 Harmonic generation .....   | 28 |
| 6.1 General.....  | 28 |
| 6.2 Converter harmonic generation .....                                     | 28 |
| 6.2.1 Idealized conditions .....  | 28 |
| 6.2.2 Realistic conditions.....   | 30 |
| 6.3 Calculation methodology.....  | 32 |
| 6.3.1 General .....   | 32 |
| 6.3.2 Harmonic currents for performance, rating and other calculations..... | 32 |
| 6.3.3 Combining harmonics from different converter bridges.....             | 33 |
| 6.3.4 Consistent sets.....  | 33 |
| 6.3.5 Harmonic generation for different DC power ranges.....                | 34 |

|       |   |    |
|-------|---|----|
| 6.4   | Sensitivity of harmonic generation to various factors.....          | 35 |
| 6.4.1 | Direct current, control angle and commutation overlap.....          | 35 |
| 6.4.2 | Effect of asymmetries on characteristic harmonics.....              | 35 |
| 6.4.3 | Converter equipment parameter tolerances .....                      | 35 |
| 6.4.4 | Tap steps .....   | 36 |
| 6.4.5 | Theoretically cancelled harmonics .....                             | 36 |
| 6.4.6 | Negative and zero sequence voltages .....                           | 36 |
| 6.4.7 | Converter transformer saturation .....                              | 37 |
| 6.4.8 | Harmonic interaction across the converter .....                     | 37 |
| 6.4.9 | Back-to-back systems.....   | 38 |
| 6.5   | Externally generated harmonics .....                                | 38 |
| 7     | Filter arrangements .....   | 38 |
| 7.1   | Overview .....  | 38 |
| 7.2   | Advantages and disadvantages of typical filters .....               | 39 |
| 7.3   | Classification of filter types .....                                | 40 |
| 7.4   | Tuned filters.....  | 40 |
| 7.4.1 | Single tuned filters.....   | 40 |
| 7.4.2 | Double tuned filters .....  | 42 |
| 7.4.3 | Triple tuned filters.....   | 44 |
| 7.5   | Damped filters .....  | 45 |
| 7.5.1 | Single tuned damped filters .....                                   | 45 |
| 7.5.2 | Double tuned damped filters .....                                   | 48 |
| 7.6   | Choice of filters.....  | 49 |
| 8     | Filter performance calculation.....                                 | 50 |
| 8.1   | Calculation procedure .....   | 50 |
| 8.1.1 | General .....   | 50 |
| 8.1.2 | Input data .....  | 50 |
| 8.1.3 | Methodology .....   | 50 |
| 8.1.4 | Calculation of converter harmonic currents .....                    | 51 |
| 8.1.5 | Selection of filter types and calculation of their impedances ..... | 52 |
| 8.1.6 | Calculation of performance .....                                    | 52 |
| 8.2   | Detuning and tolerances .....                                       | 53 |
| 8.2.1 | General .....   | 53 |
| 8.2.2 | Detuning factors .....  | 54 |
| 8.2.3 | Resistance variations .....   | 55 |
| 8.2.4 | Modelling.....  | 55 |
| 8.3   | Network impedance for performance calculations .....                | 55 |
| 8.3.1 | General .....   | 55 |
| 8.3.2 | Network modelling using impedance envelopes .....                   | 56 |
| 8.3.3 | Sector diagram .....  | 57 |
| 8.3.4 | Circle diagram .....  | 58 |
| 8.3.5 | Discrete polygons .....   | 59 |
| 8.3.6 | Zero-sequence impedance modelling.....                              | 61 |
| 8.3.7 | Detailed modelling of AC network for performance calculation .....  | 61 |
| 8.4   | Outages of filter banks and sub-banks .....                         | 62 |
| 8.5   | Considerations of probability.....                                  | 63 |
| 8.6   | Flexibility regarding compliance .....                              | 65 |
| 8.7   | Ratings of the harmonic filter equipment .....                      | 65 |
| 9     | Filter switching and reactive power management.....                 | 66 |

|         |   |    |
|---------|---|----|
| 9.1     | General.....  | 66 |
| 9.2     | Reactive power interchange with AC network.....           | 66 |
| 9.2.1   | General .....   | 66 |
| 9.2.2   | Impact on reactive compensation and filter equipment..... | 66 |
| 9.2.3   | Evaluation of reactive power interchange.....             | 67 |
| 9.3     | HVDC converter reactive power capability .....            | 68 |
| 9.4     | Bank/sub-bank definitions and sizing .....                | 68 |
| 9.4.1   | General .....   | 68 |
| 9.4.2   | Sizing .....  | 69 |
| 9.5     | Hysteresis in switching points .....                      | 71 |
| 9.6     | Converter Q-V control near switching points .....         | 72 |
| 9.7     | Operation at increased converter control angles .....     | 72 |
| 9.8     | Filter switching sequence and harmonic performance .....  | 72 |
| 9.9     | Demarcation of responsibilities .....                     | 73 |
| 9.9.1   | General .....   | 73 |
| 9.9.2   | Customer.....   | 73 |
| 9.9.3   | Contractor .....  | 74 |
| 10      | Customer specified parameters and requirements .....      | 74 |
| 10.1    | General.....  | 74 |
| 10.2    | AC system parameters.....                                 | 74 |
| 10.2.1  | Voltage.....  | 74 |
| 10.2.2  | Voltage unbalance .....                                   | 75 |
| 10.2.3  | Frequency .....   | 75 |
| 10.2.4  | Short circuit level.....                                  | 75 |
| 10.2.5  | Filter switching .....                                    | 75 |
| 10.2.6  | Reactive power interchange.....                           | 76 |
| 10.2.7  | System harmonic impedance .....                           | 76 |
| 10.2.8  | Zero sequence data.....                                   | 76 |
| 10.2.9  | System earthing.....                                      | 76 |
| 10.2.10 | Insulation level .....                                    | 76 |
| 10.2.11 | Creepage distances.....                                   | 76 |
| 10.2.12 | Pre-existing voltage distortion.....                      | 76 |
| 10.3    | Harmonic distortion requirements.....                     | 77 |
| 10.3.1  | General .....   | 77 |
| 10.3.2  | Redundancy requirements .....                             | 77 |
| 10.4    | Environmental conditions .....                            | 77 |
| 10.4.1  | Temperature.....  | 77 |
| 10.4.2  | Pollution .....   | 77 |
| 10.4.3  | Wind.....   | 77 |
| 10.4.4  | Ice and snow loading (if applicable).....                 | 78 |
| 10.4.5  | Solar radiation .....                                     | 78 |
| 10.4.6  | Isokeraunic levels.....                                   | 78 |
| 10.4.7  | Seismic requirements .....                                | 78 |
| 10.4.8  | Audible noise.....  | 78 |
| 10.5    | Electrical environment.....                               | 78 |
| 10.6    | Requirements for filter arrangements and components.....  | 79 |
| 10.6.1  | Filter arrangements .....                                 | 79 |
| 10.6.2  | Filter capacitors.....                                    | 79 |
| 10.6.3  | Test requirements.....                                    | 79 |

|                       |   |     |
|-----------------------|---|-----|
| 10.7                  | Protection of filters.....  | 79  |
| 10.8                  | Loss evaluation.....  | 79  |
| 10.9                  | Field measurements and verifications .....  | 79  |
| 10.10                 | General requirements .....  | 79  |
| 11                    | Future developments .....   | 80  |
| 11.1                  | General.....  | 80  |
| 11.2                  | Non-standard filter technology .....  | 80  |
| 11.2.1                | General .....   | 80  |
| 11.2.2                | Automatically tuned reactors.....   | 80  |
| 11.2.3                | Single-phase redundancy .....   | 83  |
| 11.2.4                | Stand-alone active filters .....  | 84  |
| 11.2.5                | Compact design.....   | 86  |
| 11.3                  | Other LCC converter technology .....  | 86  |
| 11.3.1                | General .....   | 86  |
| 11.3.2                | Series commutated converters.....   | 86  |
| 11.3.3                | Transformerless converters .....  | 89  |
| 11.3.4                | Unit connection.....  | 89  |
| 11.4                  | Changing external environment.....  | 90  |
| 11.4.1                | Increased pre-existing levels of harmonic distortion .....  | 90  |
| 11.4.2                | Developments in communication technology .....  | 90  |
| 11.4.3                | Changes in structure of the power supply industry .....   | 91  |
| 11.4.4                | Focus on power quality .....  | 91  |
| 11.4.5                | Fewer large synchronous generators and more renewable and distributed generation .....                        | 91  |
| Annex A (informative) | Alternative type of procurement procedure .....   | 92  |
| Annex B (informative) | Formulae for calculating the characteristic harmonics of a bridge converter .....                             | 93  |
| Annex C (informative) | Definition of telephone interference parameters .....   | 95  |
| C.1                   | General.....  | 95  |
| C.2                   | Criteria according to European practice .....   | 95  |
| C.3                   | Criteria according to North American practice .....   | 96  |
| C.4                   | Discussion .....  | 98  |
| Annex D (informative) | Equivalent frequency deviation.....   | 99  |
| Annex E (informative) | Reactive power management .....   | 100 |
| E.1                   | HVDC converter reactive power capability .....  | 100 |
| E.1.1                 | Steady-state capability .....   | 100 |
| E.1.2                 | Temporary capability .....  | 102 |
| E.2                   | Converter Q-V control near switching points .....   | 103 |
| E.3                   | Step change in voltage on switching a filter .....  | 104 |
| Bibliography          | .....   | 106 |
| Figure 1              | – Idealized current waveforms on the AC side of converter transformer .....                                   | 29  |
| Figure 2              | – Realistic current waveforms on the AC side of converter transformer including effect of non-idealities..... | 30  |
| Figure 3              | – Comparison of harmonic content of current waveform under idealized and realistic conditions .....           | 31  |
| Figure 4              | – Typical variation of characteristic harmonic magnitude with direct current .....                            | 34  |
| Figure 5              | – Single tuned filter and frequency response.....   | 41  |

|  |     |
|--|-----|
| Figure 6 – Double tuned filter and frequency response .....  | 42  |
| Figure 7 – Triple tuned filter and frequency response .....  | 44  |
| Figure 8 – 2 <sup>nd</sup> order damped filter and frequency response .....  | 46  |
| Figure 9 – 3 <sup>rd</sup> order damped filter and frequency response .....  | 46  |
| Figure 10 – C-type filter and frequency response .....   | 47  |
| Figure 11 – Double tuned damped filter and frequency response .....  | 48  |
| Figure 12 – Circuit model for filter calculations .....  | 51  |
| Figure 13 – AC system impedance general sector diagram, with minimum impedance .....   | 58  |
| Figure 14 – AC system impedance general sector diagram, with minimum resistance .....  | 58  |
| Figure 15 – AC system impedance general circle diagram, with minimum resistance .....  | 59  |
| Figure 16 – Example of harmonic impedances for harmonics of order 2 to 4 .....   | 60  |
| Figure 17 – Example of harmonic impedances for harmonics of order 5 to 8 .....   | 60  |
| Figure 18 – Example of harmonic impedances for harmonics of order 9 to 13 .....  | 61  |
| Figure 19 – Example of harmonic impedances for harmonics of order 14 to 49 .....   | 61  |
| Figure 20 – Illustration of basic voltage quality concepts with time/location statistics covering the whole system (adapted from IEC TR 61000-3-6:2008) .....  | 64  |
| Figure 21 – Example of range of operation where specifications on harmonic levels are not met for a filter scheme solution .....   | 65  |
| Figure 22 – Branch, sub-bank and bank definition .....   | 69  |
| Figure 23 – Typical switching sequence .....   | 73  |
| Figure 24 – Reactive power components .....  | 74  |
| Figure 25 – Design principle of a self-tuned reactor using DC control current in an orthogonal winding .....   | 82  |
| Figure 26 – Control principle for self-tuned filter .....  | 82  |
| Figure 27 – One method of switching a redundant single phase filter .....  | 84  |
| Figure 28 – Various possible configurations of series compensated HVDC converters .....  | 88  |
| Figure E.1 – Capability diagram of a converter under different control strategies .....  | 100 |
| Figure E.2 – Converter capability with $\gamma_{\min} = 17^\circ$ , $\gamma_{\max} = 40^\circ$ , $\alpha_{\min} = 5^\circ$ , $\alpha_{\max} = 35^\circ$ and $U_{\text{diomax}} = 1,2U_{\text{dioN}}$ ..... | 101 |
| Figure E.3 – Reactive power absorption of a rectifier as a function of $\alpha$ with $U_{\text{dio}} = U_{\text{dioN}}$ , $d_x = 9,4 \%$ and $d_r = 0,2 \%$ .....  | 103 |
| Figure E.4 – Reactive power absorption of a inverter as a function of $\gamma$ with $U_{\text{dio}} = U_{\text{dioN}}$ , $d_x = 9,4 \%$ and $d_r = 0,2 \%$ .....   | 103 |

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

---

**HIGH-VOLTAGE DIRECT CURRENT (HVDC) SYSTEMS –  
GUIDANCE TO THE SPECIFICATION AND DESIGN  
EVALUATION OF AC FILTERS –****Part 1: Overview****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC TR 62001-1 has been prepared by subcommittee 22F: Power electronics for electrical transmission and distribution systems, of IEC technical committee 22: Power electronic systems and equipment. It is a Technical Report.

This second edition cancels and replaces the first edition published in 2016. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) general updating of the document to reflect changes in practice;
- b) 10.2.4 on fuseless capacitors has been transferred to IEC TR 62001-4;
- c) Clause 11 on future developments has been expanded;
- d) 10.3.3 and Annex F on voltage sourced converters have been deleted as their content is covered by IEC TR 62543.

The text of this Technical Report is based on the following documents:

|             |                  |
|-------------|------------------|
| DTR         | Report on voting |
| 22F/614/DTR | 22F/623A/RVDTR   |

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Technical Report is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at [www.iec.ch/members\\_experts/refdocs](http://www.iec.ch/members_experts/refdocs). The main document types developed by IEC are described in greater detail at [www.iec.ch/standardsdev/publications](http://www.iec.ch/standardsdev/publications).

A list of all parts in the IEC TR 62001 series, published under the general title *High-voltage direct current (HVDC) systems – Guidance to the specification and design evaluation of AC filters*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under [webstore.iec.ch](http://webstore.iec.ch) in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

**IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.**



## INTRODUCTION

The IEC TR 62001 series is structured in five parts:

### IEC TR 62001-1 – Overview

This part concerns specifications of AC filters for high-voltage direct current (HVDC) systems with line-commutated converters, permissible distortion limits, harmonic generation, filter arrangements, filter performance calculation, filter switching and reactive power management and customer specified parameters and requirements.

### IEC TR 62001-2 – Performance

This part deals with current-based interference criteria, field measurements and verification.

### IEC TR 62001-3 – Modelling

This part addresses the harmonic interaction across converters, pre-existing harmonics, AC network impedance modelling, simulation of AC filter performance.

### IEC TR 62001-4 – Equipment

This part concerns steady-state and transient ratings of AC filters and their components, power losses, audible noise, design issues and special applications, filter protection, seismic requirements, equipment design and test parameters.

### IEC TR 62001-5<sup>1</sup> – AC side harmonics and appropriate harmonic limits for high-voltage direct current (HVDC) systems with voltage sourced converters (VSC)

This document concerns specific issues of AC filter design related to VSC HVDC systems.

Parts 1 to 4 are written with focus on line commutated converters.

---

<sup>1</sup> Under preparation. Stage at the time of publication: IEC/RPUB 62001-5:2021.

# HIGH-VOLTAGE DIRECT CURRENT (HVDC) SYSTEMS – GUIDANCE TO THE SPECIFICATION AND DESIGN EVALUATION OF AC FILTERS –

## Part 1: Overview

### 1 Scope

This part of IEC 62001, which is a Technical Report, deals with the specification and design evaluation of AC side harmonic performance and AC side filters for HVDC schemes. It is intended to be primarily for the use of the utilities and consultants who are responsible for issuing the specifications for new HVDC projects and evaluating designs proposed by prospective suppliers.

This document provides guidance on the specifications of AC filters for high-voltage direct current (HVDC) systems with line-commutated converters and filter performance calculation.

The scope of this document covers AC side filtering for the frequency range of interest in terms of harmonic distortion and audible frequency disturbances. Where the term "HVDC converter" or "HVDC station" is referred to without qualification, in this document, it is understood to refer to LCC technology. It excludes filters designed to be effective in the power line carrier (PLC) and radio interference spectra.

The bulk of this document concentrates on the "conventional" AC filter technology and LCC (line-commutated converter) HVDC. Voltage sourced converter (VSC) specific issues are discussed in CIGRE Technical Brochure 754 [1]<sup>2</sup> and in IEC TR 62001-5 [2].

### 2 Normative references

There are no normative references in this document.

---

<sup>2</sup> Numbers in square brackets refer to the Bibliography.