

Edition 1.0 2013-09

TECHNICAL REPORT



Measurement of internal electric field in insulating materials – Pressure wave propagation method



INTERNATIONAL ELECTROTECHNICAL COMMISSION

PRICE CODE

M

ICS 17.220.99; 29.035.01

ISBN 978-2-8322-1102-1

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

INTRODUCTION 5 1 Scope 6 2 Terms, definitions and abbreviations 6 2.1 Terms and definitions 6 2.2 Abbreviations 6 3 Principle of the method 6 4 Sample conditions 8 5 Electrode materials 8 6 Pressure pulse wave generation 8 7 Set-up of the measurement 8 8 Calibrating the electric field 9 9 Measurement procedure 9 10 Data processing for the experimental measurement 9 11 Measurement examples 10 11.1 Samples 10 11.2 Pressure pulse generation 10 11.3 Calibrating of sample and signal 10 11.4 Testing sample and experimental results 11 11.5 The internal electric field distribution 12
Terms, definitions and abbreviations 2.1 Terms and definitions 2.2 Abbreviations 3 Principle of the method 4 Sample conditions 5 Electrode materials 6 Pressure pulse wave generation 7 Set-up of the measurement 8 Calibrating the electric field 9 Measurement procedure 10 Data processing for the experimental measurement 11 Samples 11.1 Samples 11.2 Pressure pulse generation 11.3 Calibrating of sample and signal 11.4 Testing sample and experimental results 11
2.1 Terms and definitions 2.2 Abbreviations 3 Principle of the method 4 Sample conditions 5 Electrode materials 6 Pressure pulse wave generation 7 Set-up of the measurement 8 Calibrating the electric field 9 Measurement procedure 10 Data processing for the experimental measurement 11 Measurement examples 11.1 Samples 11.2 Pressure pulse generation 11.3 Calibrating of sample and signal 11.4 Testing sample and experimental results 11
2.2 Abbreviations 6 3 Principle of the method 6 4 Sample conditions 8 5 Electrode materials 8 6 Pressure pulse wave generation 8 7 Set-up of the measurement 8 8 Calibrating the electric field 9 9 Measurement procedure 9 10 Data processing for the experimental measurement 9 11 Measurement examples 10 11.1 Samples 10 11.2 Pressure pulse generation 10 11.3 Calibrating of sample and signal 11.4 Testing sample and experimental results 11
3 Principle of the method 6 4 Sample conditions 8 5 Electrode materials 8 6 Pressure pulse wave generation 8 7 Set-up of the measurement 8 8 Calibrating the electric field 9 9 Measurement procedure 9 10 Data processing for the experimental measurement 9 11 Measurement examples 10 11.1 Samples 10 11.2 Pressure pulse generation 10 11.3 Calibrating of sample and signal 11.4 Testing sample and experimental results 11
4 Sample conditions 5 Electrode materials 6 Pressure pulse wave generation 7 Set-up of the measurement 8 Calibrating the electric field 9 Measurement procedure 10 Data processing for the experimental measurement 11 Measurement examples 11 Measurement examples 11 Samples 11.1 Samples 11.2 Pressure pulse generation 11.3 Calibrating of sample and signal 11.4 Testing sample and experimental results 11
5 Electrode materials 8 6 Pressure pulse wave generation 8 7 Set-up of the measurement 8 8 Calibrating the electric field 9 9 Measurement procedure 9 10 Data processing for the experimental measurement 9 11 Measurement examples 10 11.1 Samples 10 11.2 Pressure pulse generation 10 11.3 Calibrating of sample and signal 10 11.4 Testing sample and experimental results 11
6 Pressure pulse wave generation 8 7 Set-up of the measurement 8 8 Calibrating the electric field 9 9 Measurement procedure 9 10 Data processing for the experimental measurement 9 11 Measurement examples 10 11.1 Samples 10 11.2 Pressure pulse generation 10 11.3 Calibrating of sample and signal 10 11.4 Testing sample and experimental results 11
6 Pressure pulse wave generation 8 7 Set-up of the measurement 8 8 Calibrating the electric field 9 9 Measurement procedure 9 10 Data processing for the experimental measurement 9 11 Measurement examples 10 11.1 Samples 10 11.2 Pressure pulse generation 10 11.3 Calibrating of sample and signal 10 11.4 Testing sample and experimental results 11
7 Set-up of the measurement. 8 8 Calibrating the electric field 9 9 Measurement procedure 9 10 Data processing for the experimental measurement 9 11 Measurement examples 10 11.1 Samples 10 11.2 Pressure pulse generation 10 11.3 Calibrating of sample and signal 10 11.4 Testing sample and experimental results 11
8 Calibrating the electric field 9 Measurement procedure 9 10 Data processing for the experimental measurement 9 11 Measurement examples 10 11.1 Samples 10 11.2 Pressure pulse generation 10 11.3 Calibrating of sample and signal 10 11.4 Testing sample and experimental results 11
10 Data processing for the experimental measurement 9 11 Measurement examples 10 11.1 Samples 10 11.2 Pressure pulse generation 10 11.3 Calibrating of sample and signal 10 11.4 Testing sample and experimental results 11
11 Measurement examples 10 11.1 Samples 10 11.2 Pressure pulse generation 10 11.3 Calibrating of sample and signal 10 11.4 Testing sample and experimental results 11
11.1Samples1011.2Pressure pulse generation1011.3Calibrating of sample and signal1011.4Testing sample and experimental results11
11.1Samples1011.2Pressure pulse generation1011.3Calibrating of sample and signal1011.4Testing sample and experimental results11
11.2 Pressure pulse generation
11.4 Testing sample and experimental results11
11.5 The internal electric field distribution
Figure 1 – Principle of the PWP method
Figure 2 – Set-up of measurement of the PWP method
Figure 3 – Sample of protecting circuit9
Figure 4 – Current signal under –5,8 kV
Figure 5 – First measured current signal (<1 min)11
Figure 6 – Signal under –46,4 kV, 1,5 h
Figure 7 - Measured signal without applied voltage, after 1,5 h under high voltage12
Figure 8 – Internal electric field distribution under –5,8 kV
Figure 9 – Internal electric field distribution under –46,4 kV, at the initial state12
Figure 10 – Internal electric field distribution under –46,4 kV, after 1,5 h under high
voltage12
Figure 11 – Internal electric field distribution without applied voltage after 1,5 h under high voltage

INTERNATIONAL ELECTROTECHNICAL COMMISSION

MEASUREMENT OF INTERNAL ELECTRIC FIELD IN INSULATING MATERIALS – PRESSURE WAVE PROPAGATION METHOD

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, [Fechnical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC/TR 63836, which is a technical report, has been prepared by IEC technical committee 112: Evaluation and qualification of electrical insulating materials and systems.

The text of this technical report is based on the following documents:


Enquiry draft	Report on voting
112/258/DTR	112/263/RVC

Full information on the voting for the approval of this technical report can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- · reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.



INTRODUCTION

High-voltage insulating cables, especially high-voltage d.c. cables, are subject to charge accumulation and thus to electrical breakdown if the electric field produced by the charges exceeds the electrical breakdown threshold. With the trend to multiply power plants, especially green power plants such as wind or solar generators, more cables will be used for connecting these power plants to the grid and share the electric energy between countries. Therefore the materials for the cables, and even the structure of these cables when considering electrodes or the junction between cables, need a standardized procedure for testing how the internal electric field can be characterized. The measurement of the internal electric field would give a tool for comparing materials and help to establish thresholds on the internal electric field for high voltage applications in order to limit as much as possible breakdown risks. The pressure wave propagation (PWP) method has been used by several researchers to measure the space charge distribution and the internal electric field distribution in insulators. However, since experimental equipment, with slight differences, is developed independently by researchers over the world, it is difficult to compare the measuring results between the different researchers.

The procedure outlined in this technical report would give a reliable point of comparison between different test results carried out by different laboratories and avoid interpretation errors. The IEC has established a project team to develop a procedure to evaluate PWP measurement. The method will be verified in a Round Robin test. Once, having received reliable experience, this report is intended later to be upgraded to a technical specification in order to establish a specified way to estimate fairly the performance of a PWP measurement.



MEASUREMENT OF INTERNAL ELECTRIC FIELD IN INSULATING MATERIALS – PRESSURE WAVE PROPAGATION METHOD

1 Scope

IEC/TR 62836, which is a technical report, contains an efficient and reliable procedure to test the internal electric field in the insulating materials used for high-voltage applications using the pressure wave propagation (PWP) method. It is suitable for a sample with homogeneous insulating materials and an electric field higher than 1 kV/mm, but it is also depended on the thickness of sample and the pressure wave generator.

