



Edition 1.1 2019-05 CONSOLIDATED VERSION

# TECHNICAL SPECIFICATION



High voltage direct current (HVDC) substation audible noise

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ICS 29.240.10; 29.240.99

ISBN 978-2-8322-6930-5

Warning! Make sure that you obtained this publication from an authorized distributor.





Edition 1.1 2019-05 CONSOLIDATED VERSION

# **REDLINE VERSION**



High voltage direct current (HVDC) substation audible noise



### CONTENTS

FO	REWO	DRD		7
1	Scope			
2	Norm	native re	ferences	9
3	Terms and definitions			
	3.1	Sound	and noise terms	10
	3.2	Sound	radiation terms	14
	3.3	Acoust	tic fields	16
4	Envir	onment	al influences	16
	4.1	Genera	al	16
	4.2	Directi	vity of sound radiation	16
	4.3	Backgı	round noise	18
	4.4	Topog	raphy	20
	4.5	Meteo	ological conditions	20
5	Noise	e level l	imits	22
	5.1	Genera	al	22
	5.2	Regula	ations	22
		5.2.1	Noise level limits	22
		5.2.2	Noise level measurement	23
	5.3	Land-ս	se classifications	23
	5.4	Location	on of required performance limits	23
		5.4.1	General	23
		5.4.2	At the fence surrounding the HVDC substation or at the border of the substation owner's property	24
		5.4.3	At the given contour away from the HVDC substation (e.g. on a circle perimeter or beyond a property border line)	
		5.4.4	At the border of a nearby property	
	5.5		onship of performance limits to time duration	
	5.6	• •	I noise performance limits	
		5.6.1	General	
		5.6.2	Specific A-weighted sound pressure levels	
_	_	5.6.3	Maximum allowable increase over background noise levels	
6			ng sources	
	6.1		al	
	6.2		rter transformer	
		6.2.1	Noise sources in a converter transformer	
		6.2.2	Comparison with a.c. power transformers	
		6.2.3	Special features of HVDC converter transformers	
	0.0	6.2.4	Transformer winding noise	
	6.3		ors	
		6.3.1	Type and design of HVDC reactors	
		6.3.2 6.3.3	Mechanism of sound generation	
		6.3.4		
		6.3.5	HVDC smoothing reactors  Self-tuned filter reactors	
	6.4		itors	
	∪.→	6.4.1	Type and design of capacitors	
		J.7. I	Type and design of dapacitors	51

		6.4.2	Mechanism of sound generation	37
	6.5	Coolin	g fans	40
	6.6	Other	sound-emitting sources	41
		6.6.1	Switching devices	41
		6.6.2	Synchronous compensators	42
		6.6.3	Diesel generators	42
		6.6.4	Air conditioning plant	42
		6.6.5	Cooling circuit pumps	42
		6.6.6	Converter valves	42
		6.6.7	Air compressors	43
		6.6.8	Corona sources	43
	6.7	Typica	Il sound power levels of sound emitting sources	43
7	Sound reduction measures			
	7.1	Genera	al	43
	7.2	Substa	ation layout	44
		7.2.1	General	44
		7.2.2	Transformers and tanked reactors	44
		7.2.3	Air-cored reactors	45
		7.2.4	Capacitors	45
		7.2.5	Cooling fans	45
		7.2.6	Diesel generators	45
		7.2.7	Switching devices	45
		7.2.8	Air conditioning plant	45
		7.2.9	Corona sources	45
		7.2.10	Synchronous compensators	46
	7.3	Compo	onent design	46
		7.3.1	General	46
		7.3.2	Transformers and tanked reactors	46
		7.3.3	Air-cored reactors	46
		7.3.4	Capacitors	46
		7.3.5	Cooling fans	47
		7.3.6	Pumps and diesel generators	47
		7.3.7	Switching devices	47
		7.3.8	Air-conditioning plant	47
		7.3.9	High voltage connections	47
	7.4	Sound	enclosures	47
		7.4.1	General	47
		7.4.2	Transformers and tanked-reactors	48
		7.4.3	Air-cored reactors	48
		7.4.4	Capacitors	48
	7.5	Retrofi	itable techniques	49
		7.5.1	Enclosures	49
		7.5.2	Damping	49
		7.5.3	Active noise and vibration mitigation	49
8	Ope	Operating conditions		
	8.1	1 General		
	8.2	2 Normal operating conditions		
	8.3	3 Exceptional operating conditions		
	8.4	Opera	ting conditions specified for verification	52

9	Sound level prediction			
	9.1	.1 General		
	9.2	Modelling of plant	53	
		9.2.1 General	53	
		9.2.2 Layout	53	
		9.2.3 Source	53	
		9.2.4 Transmission path	53	
	9.3	Calculation procedure	54	
		9.3.1 Sequence of calculation	54	
		9.3.2 Calculation of attenuation terms	56	
		9.3.3 Results presentation	60	
10	Verif	cation of component sound power	62	
	10.1	General	62	
	10.2	Calculation	62	
		10.2.1 General	62	
		10.2.2 Calculation of force spectrum		
		10.2.3 Transfer function calculation		
		10.2.4 Sound power calculation	64	
	10.3	Measurement	65	
		10.3.1 General aspects on sound power determination		
		10.3.2 Sound pressure measurement	67	
		10.3.3 Corrections for background noise		
		10.3.4 Sound intensity measurement	68	
	10.4	Combination of calculation and measurement		
		10.4.1 General	70	
		10.4.2 Verification of key components	70	
		10.4.3 Verification of key components at site	70	
11	Verif	cation of sound levels from the HVDC substation	71	
	11.1	General	71	
	11.2	Acoustic environment	72	
	11.3	Conditions for verification	72	
	11.4	Calculation	72	
	11.5	Measurement	73	
	11.6	Combination of calculation and measurement	73	
12	Para	neters to be specified	75	
	12.1	General	75	
		Noise level measurement		
		Data to be presented by customers, or to be investigated by contractors		
		12.3.1 Land-use classification, noise regulation and limits		
		12.3.2 Environmental condition		
		12.3.3 Operation condition of HVDC substation		
	12.4	Data to be clarified by contractors		
		12.4.1 Noise of components		
		12.4.2 Noise prediction of the HVDC substation		
		12.4.3 Noise measurement on the site		
Anr	nex A	(normative) Procedure to correct for background noise in HVDC and SVC		
			80	
		(informative) Typical twelve-pulse and dual twelve-pulse HVDC substation		
lay	outs		83	

Figure B.2 – Example of dual twelve-pulse HVDC substation layout.......84

Table 1 – Examples of component sound power level	43
Table 2 – Normal operating conditions	51
Table 3 – Exceptional operating conditions	52
Table 4 – Examples of atmospheric attenuation coefficients	57
Table 5 – Examples of attenuation coefficient values for octave bands	60
Table 6 – Groups of noise sources	61
Table 7 – Ranking of noise sources	62
Table 8 – Vibration force frequency spectrum resulting from the electrical fundamental frequency 50 Hz and its 11 <sup>th</sup> harmonic	63
Table 9 – Summary of different methods for sound power determination	70
Table 10 – Land use classification	76
Table 11 – Existence different noise limits at different times	76
Table 12 – Existence of noise limits due to further regulation	76
Table 13 – Definition of noise limits at different locations	76
Table 14 – Existence of background noise limits at different locations and different times	77
Table 15 – Compilation of relevant topographical features	77
Table 16 – Compilation of relevant meteorological conditions	77
Table 17 – Compilation of further noise related weather conditions	77
Table 18 – Existence of additional locations with relevant noise limits	77
Table 19 – Possibility of future development	78
Table 20 – Other sources of audible noise	78
Table 21 – Definition of operating condition during audible noise measurement	78
Table 22 – Further conditions relevant for audible noise measurement	78
Table 23 – List of audible noise sources to be installed	79
Table 24 – Contents of an audible noise prediction report	79
Table 25 – Contents of an audible noise measurement report	79
Table A 1 – Total sound level for the SVC example	82

### INTERNATIONAL ELECTROTECHNICAL COMMISSION

# HIGH VOLTAGE DIRECT CURRENT (HVDC) SUBSTATION AUDIBLE NOISE

### **FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendment has been prepared for user convenience.

IEC TS 61973 edition 1.1 contains the first edition (2012-04) [documents 22F/243/DTS and 22F/260/RVC] and its amendment 1 (2019-05) [documents 115/197/DTS and 115/207/RVDTS].

In this Redline version, a vertical line in the margin shows where the technical content is modified by amendment 1. Additions are in green text, deletions are in strikethrough red text. A separate Final version with all changes accepted is available in this publication.

- 8 -

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical specification when

- the required support cannot be obtained for the publication of an International Standard, despite repeated efforts, or
- the subject is still under technical development or where, for any other reason, there is the future but no immediate possibility of an agreement on an International Standard.

Technical specifications are subject to review within three years of publication to decide whether they can be transformed into International Standards.

IEC 61973, which is a technical specification, has been prepared by subcommittee 22F: Power electronics for electrical transmission and distribution systems, of IEC technical committee 22: Power electronic systems and equipment, with the participation of IEC technical committee 115: High voltage direct current (HVDC) transmission for DC voltages above 100 kV.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of the base publication and its amendment will remain unchanged until the stability date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- · replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

### HIGH VOLTAGE DIRECT CURRENT (HVDC) SUBSTATION AUDIBLE NOISE

### 1 Scope

This technical specification applies to the specification and evaluation of outdoor audible noise from high voltage direct current (HVDC) substations. It is intended to be primarily for the use of the utilities and consultants who are responsible for issuing technical specifications for new HVDC projects with and evaluating designs proposed by prospective contractors. It is primarily intended for HVDC projects with line-commutated converters. Part of this technical specification can also be used for the same purpose for HVDC projects using voltage sourced converters, and for flexible a.c. transmission systems (FACTS) devices such as static Var compensators (SVCs) and static synchronous compensators (STATCOMs).

### 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60076-10, Power transformers - Part 10: Determination of sound levels

IEC 60076-10-1, Power transformers – Part-10-1: Determination of sound levels – Application guide

IEC 61672-1, Electroacoustics – Sound level meters – Part 1: Specifications

IEC 61672-2, Electroacoustics - Sound level meters - Part 2: Pattern evaluation tests

ISO 1996-2, Acoustics – Description, assessment and measurement of environmental noise – Part 2: Determination of environmental noise levels

ISO 266:1997, Acoustics - Preferred frequencies

ISO 3740, Acoustics – Determination of sound power levels of noise sources – Guidelines for the use of basic standards

ISO 3743-2, Acoustics – Determination of sound power levels of noise sources; engineering methods for small, movable sources in reverberant fields – Part 2: Methods for special reverberation test rooms

ISO 3744, Acoustics – Determination of sound power levels and sound energy levels of noise sources using sound pressure – Engineering methods for an essentially free field over a reflecting plane

ISO 3745, Acoustics – Determination of sound power levels of noise sources using sound pressure – Precision methods for anechoic and hemi-anechoic rooms

ISO 3746, Acoustics – Determination of sound power levels and sound energy levels of noise sources using sound pressure – Survey method using an enveloping measurement surface over a reflecting plane

ISO 8297, Acoustics – Determination of sound power levels of multisource industrial plants for evaluation of sound pressure levels in the environment – Engineering method

ISO 9613-1, Acoustics – Attenuation of sound during propagation outdoors – Part 1: Calculation of the absorption of sound by the atmosphere

ISO 9613-2, Acoustics – Attenuation of sound during propagation outdoors – Part 2: General method of calculation

ISO 9614-1, Acoustics – Determination of sound power levels of noise sources using sound intensity – Part 1: Measurement at discrete points

ISO 9614-2, Acoustics – Determination of sound power levels of noise sources using sound intensity – Part 2: Measurement by scanning





Edition 1.1 2019-05 CONSOLIDATED VERSION

# **FINAL VERSION**



High voltage direct current (HVDC) substation audible noise



### CONTENTS

FO	REWC	)RD		7
1	Scope			
2	Norm	ative re	ferences	9
3	Terms and definitions			
	3.1	Sound	and noise terms	10
	3.2	Sound	radiation terms	14
	3.3 Acoustic fields			16
4	Envir	onment	al influences	16
	4.1	Genera	al	16
	4.2	Directi	vity of sound radiation	16
	4.3 Background noise			
	4.4 Topography			20
	4.5		ological conditions	
5	Noise	e level li	mits	22
	5.1		al	
	5.2	Regula	tions	
		5.2.1	Noise level limits	
		5.2.2	Noise level measurement	
	5.3		se classifications	
	5.4		on of required performance limits	
		5.4.1	General	23
		5.4.2	At the fence surrounding the HVDC substation or at the border of the substation owner's property	24
		5.4.3	At the given contour away from the HVDC substation (e.g. on a circle perimeter or beyond a property border line)	24
		5.4.4	At the border of a nearby property	24
	5.5		nship of performance limits to time duration	
	5.6	• •	I noise performance limits	
		5.6.1	General	
		5.6.2	Specific A-weighted sound pressure levels	
	_	5.6.3	Maximum allowable increase over background noise levels	
6	Sound emitting sources			
	6.1		al	
	6.2		rter transformer	
		6.2.1	Noise sources in a converter transformer	
		6.2.2	Comparison with a.c. power transformers	
		6.2.3	Special features of HVDC converter transformers	
	0.0	6.2.4	Transformer winding noise	
	6.3		ors	
		6.3.1	Type and design of HVDC reactors	
		6.3.2	Mechanism of sound generation	
		6.3.3	AC filter reactors	
		6.3.4	HVDC smoothing reactors	
	6.4	6.3.5		
	6.4		Type and design of capacitors	
		6.4.1	Type and design of capacitors	31

9	Sound level prediction				
	9.1	0.1 General			
	9.2	Modelli	ing of plant	53	
		9.2.1	General		
		9.2.2	Layout	53	
		9.2.3	Source	53	
		9.2.4	Transmission path	53	
	9.3	Calcula	ation procedure	54	
		9.3.1	Sequence of calculation	54	
		9.3.2	Calculation of attenuation terms	56	
		9.3.3	Results presentation	60	
10	Verification of component sound power				
	10.1 General			62	
	10.2	Calcula	ation	62	
		10.2.1	General	62	
		10.2.2	Calculation of force spectrum	63	
		10.2.3	Transfer function calculation	63	
		10.2.4	Sound power calculation	64	
	10.3	Measu	rement	65	
		10.3.1	General aspects on sound power determination	65	
		10.3.2	Sound pressure measurement	67	
		10.3.3	Corrections for background noise	68	
		10.3.4	Sound intensity measurement	68	
	10.4	Combin	nation of calculation and measurement	69	
		10.4.1	General	69	
		10.4.2	Verification of key components	70	
		10.4.3	Verification of key components at site	70	
11	Verification of sound levels from the HVDC substation				
	11.1	.1 General			
	11.2	Acoustic environment			
	11.3	Conditions for verification			
	11.4	11.4 Calculation		72	
	11.5			72	
	11.6	Combin	nation of calculation and measurement	73	
12	Parameters to be specified				
	12.1	.1 General			
	12.2	Noise I	evel measurement	75	
	12.3	Data to	be presented by customers, or to be investigated by contractors	75	
		12.3.1	Land-use classification, noise regulation and limits	75	
		12.3.2	Environmental condition	76	
		12.3.3	Operation condition of HVDC substation	77	
	12.4	Data to	be clarified by contractors	78	
		12.4.1	Noise of components	78	
		12.4.2	Noise prediction of the HVDC substation	78	
		12.4.3	Noise measurement on the site	79	
			ive) Procedure to correct for background noise in HVDC and SVC	80	
Anr	nex B	(informa	ative) Typical twelve-pulse and dual twelve-pulse HVDC substation		
				83	

Bibliography	85
Figure 1 – Spherical spreading in a free-field from a point source	17
Figure 2 – Hemispherical spreading from a point source	18
Figure 3 – Quarter-spherical spreading from a point source	19
Figure 4 – Explanation of specific and background noise	19
Figure 5 – Example of reflecting hill and low ground	20
Figure 6 – Example of sound refraction with the shown wind gradient	21
Figure 7 – Sound travels faster near the ground	21
Figure 8 – Sound travels slower near the ground	21
Figure 9 – Dry-type air-core reactor	30
Figure 10 – Magnetic field of an air-core reactor winding	31
Figure 11 – Simplified shape of the symmetrical breathing mode of a reactor winding	32
Figure 12 – Example of flexural modes (bending modes) for a simply supported winding layer without axial constraint	33
Figure 13 – Example of spectrum of currents through a.c. filter reactor	34
Figure 14 – Example of spectrum of forces acting on the reactor winding	35
Figure 15 – Example of a spectrum of currents through an HVDC smoothing reactor	35
Figure 16 – Example of spectrum of forces acting on the reactor winding	36
Figure 17 – Reactor for self-tuned filter applications	36
Figure 18 – Capacitor element package with capacitor elements	37
Figure 19 – Forces in a capacitor element	38
Figure 20 – Example of spectrum of voltages across the capacitor	39
Figure 21 – Example of spectrum of electrostatic forces in a capacitor	40
Figure 22 – Explanation of a.c. network harmonics and converter harmonics	
Figure 23 – Examples of transmission paths from source to receiver	54
Figure 24 – Grouping of point sources to one equivalent source if the measurement distance $(r)$ is larger than $2a$	55
Figure 25 – Definition of the geometrical parameters used for calculation of screening	57
Figure 26 – Reflecting obstacles are treated by mirror sources	58
Figure 27 – Definition of parts for calculation of ground attenuation	58
Figure 28 – Definition of parameters used in Equation 22	60
Figure 29 – Example of graphical presentation of sound pressure level calculation	61
Figure 30 – Three steps to determine the sound power of HVDC components	63
Figure 31 – Linear transfer function between e.g. force and vibration velocity for a 1-DOF system with the resonance frequency 500 Hz	64
Figure 32 – Definitions of the parameters used in Equation (26)	68
Figure 33 – Combination of calculation and measurement in determining the sound pressure level	73
Figure 34 – Example of layout of noise sources of an HVDC substation	74
Figure 35 – HVDC substation and example of microphone positions for determination of sound power levels	74
Figure A.1 – Example of a background correction at 1/24 octave band resolution	81
Figure B.1 – Example of typical twelve-pulse HVDC substation layout	83
Figure B.2. Example of dual twelve nulse HVDC substation layout	8/

Table 1 – Examples of component sound power level	43
Table 2 – Normal operating conditions	51
Table 3 – Exceptional operating conditions	52
Table 4 – Examples of atmospheric attenuation coefficients	57
Table 5 – Examples of attenuation coefficient values for octave bands	60
Table 6 – Groups of noise sources	61
Table 7 – Ranking of noise sources	62
Table 8 – Vibration force frequency spectrum resulting from the electrical fundamental frequency 50 Hz and its 11 <sup>th</sup> harmonic	63
Table 9 – Summary of different methods for sound power determination	70
Table 10 – Land use classification	75
Table 11 – Existence different noise limits at different times	75
Table 12 – Existence of noise limits due to further regulation	76
Table 13 – Definition of noise limits at different locations	76
Table 14 – Existence of background noise limits at different locations and different times	76
Table 15 – Compilation of relevant topographical features	76
Table 16 – Compilation of relevant meteorological conditions	77
Table 17 – Compilation of further noise related weather conditions	77
Table 18 – Existence of additional locations with relevant noise limits	77
Table 19 – Possibility of future development	77
Table 20 – Other sources of audible noise	77
Table 21 – Definition of operating condition during audible noise measurement	78
Table 22 – Further conditions relevant for audible noise measurement	78
Table 23 – List of audible noise sources to be installed	78
Table 24 – Contents of an audible noise prediction report	78
Table 25 – Contents of an audible noise measurement report	79
Table A 1 – Total sound level for the SVC example	82

### INTERNATIONAL ELECTROTECHNICAL COMMISSION

# HIGH VOLTAGE DIRECT CURRENT (HVDC) SUBSTATION AUDIBLE NOISE

### **FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendment has been prepared for user convenience.

IEC TS 61973 edition 1.1 contains the first edition (2012-04) [documents 22F/243/DTS and 22F/260/RVC] and its amendment 1 (2019-05) [documents 115/197/DTS and 115/207/RVDTS].

This Final version does not show where the technical content is modified by amendment 1. A separate Redline version with all changes highlighted is available in this publication.

- 8 -

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical specification when

- the required support cannot be obtained for the publication of an International Standard, despite repeated efforts, or
- the subject is still under technical development or where, for any other reason, there is the future but no immediate possibility of an agreement on an International Standard.

Technical specifications are subject to review within three years of publication to decide whether they can be transformed into International Standards.

IEC 61973, which is a technical specification, has been prepared by subcommittee 22F: Power electronics for electrical transmission and distribution systems, of IEC technical committee 22: Power electronic systems and equipment, with the participation of IEC technical committee 115: High voltage direct current (HVDC) transmission for DC voltages above 100 kV.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of the base publication and its amendment will remain unchanged until the stability date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- · replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

### HIGH VOLTAGE DIRECT CURRENT (HVDC) SUBSTATION AUDIBLE NOISE

### 1 Scope

This technical specification applies to the specification and evaluation of outdoor audible noise from high voltage direct current (HVDC) substations. It is intended to be primarily for the use of the utilities and consultants who are responsible for issuing technical specifications for new HVDC projects with and evaluating designs proposed by prospective contractors. It is primarily intended for HVDC projects with line-commutated converters. Part of this technical specification can also be used for the same purpose for HVDC projects using voltage sourced converters, and for flexible a.c. transmission systems (FACTS) devices such as static Var compensators (SVCs) and static synchronous compensators (STATCOMs).

#### 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60076-10, Power transformers - Part 10: Determination of sound levels

IEC 60076-10-1, Power transformers – Part-10-1: Determination of sound levels – Application guide

IEC 61672-1, Electroacoustics – Sound level meters – Part 1: Specifications

IEC 61672-2, Electroacoustics - Sound level meters - Part 2: Pattern evaluation tests

ISO 1996-2, Acoustics – Description, assessment and measurement of environmental noise – Part 2: Determination of environmental noise levels

ISO 266:1997, Acoustics – Preferred frequencies

ISO 3740, Acoustics – Determination of sound power levels of noise sources – Guidelines for the use of basic standards

ISO 3743-2, Acoustics – Determination of sound power levels of noise sources; engineering methods for small, movable sources in reverberant fields – Part 2: Methods for special reverberation test rooms

ISO 3744, Acoustics – Determination of sound power levels and sound energy levels of noise sources using sound pressure – Engineering methods for an essentially free field over a reflecting plane

ISO 3745, Acoustics – Determination of sound power levels of noise sources using sound pressure – Precision methods for anechoic and hemi-anechoic rooms

ISO 3746, Acoustics – Determination of sound power levels and sound energy levels of noise sources using sound pressure – Survey method using an enveloping measurement surface over a reflecting plane

ISO 8297, Acoustics – Determination of sound power levels of multisource industrial plants for evaluation of sound pressure levels in the environment – Engineering method

ISO 9613-1, Acoustics – Attenuation of sound during propagation outdoors – Part 1: Calculation of the absorption of sound by the atmosphere

ISO 9613-2, Acoustics – Attenuation of sound during propagation outdoors – Part 2: General method of calculation

ISO 9614-1, Acoustics – Determination of sound power levels of noise sources using sound intensity – Part 1: Measurement at discrete points

ISO 9614-2, Acoustics – Determination of sound power levels of noise sources using sound intensity – Part 2: Measurement by scanning