



TECHNICAL SPECIFICATION

This full version of IEC TS 62271-315:2025 includes the content of the references made to IEC TS 62271-5:2024

High-voltage switchgear and controlgear – Part 315: Direct current (DC) transfer switches

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.130.10

ISBN 978-2-8327-0307-6

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	8
INTRODUCTION to IEC TS 62271-5:2024	10
1 Scope.....	11
2 Normative references	11
3 Terms and definitions	14
3.1 General terms and definitions	14
3.2 Assemblies of switchgear and controlgear	19
3.3 Parts of assemblies	19
3.4 Switching devices	19
3.5 Parts of switchgear and controlgear	22
3.6 Operational characteristics of switchgear and controlgear.....	27
3.7 Characteristic quantities	31
3.8 Index of definitions.....	33
4 Normal and special service conditions	36
4.1 Normal service conditions	36
4.2 Special service conditions.....	38
5 Ratings.....	39
5.1 General.....	39
5.2 Rated direct voltage (U_{rd}).....	40
5.3 Rated insulation level (U_{dd} , U_p , U_s).....	40
5.4 Rated continuous current (I_{rd})	44
5.5 Rated values of short-time withstand current.....	44
5.6 Rated supply voltage of auxiliary and control circuits (U_a)	46
5.7 Rated supply frequency of auxiliary and control circuits	47
5.101 Rated direct voltage of transfer switch (U_{rts})	48
5.102 Rated transfer current (I_t)	48
5.103 Rated commutation voltage (U_c)	48
5.104 Rated dissipated energy during transfer operation (E_{rd}).....	48
5.105 Rated operating sequence	48
5.106 Rated open-close time	49
6 Design and construction	49
6.1 Requirements for liquids in switchgear and controlgear.....	49
6.2 Requirements for gases in switchgear and controlgear	49
6.3 Earthing of switchgear and controlgear	49
6.4 Auxiliary and control equipment and circuits	50
6.5 Dependent power operation	54
6.6 Stored energy operation.....	54
6.7 Independent unlatched operation (independent manual or power operation)	55
6.8 Manually operated actuators	56
6.9 Operation of releases.....	56
6.10 Pressure/level indication	57
6.11 Nameplates.....	57
6.12 Locking devices	60
6.13 Position indication.....	60
6.14 Degrees of protection provided by enclosures.....	60

6.15	Creepage distances for outdoor insulators	61
6.16	Gas and vacuum tightness	61
6.17	Tightness for liquid systems	62
6.18	Fire hazard (flammability)	62
6.19	Electromagnetic compatibility (EMC)	62
6.20	X-ray emission	62
6.21	Corrosion	63
6.22	Filling levels for insulation, switching and/or operation	63
6.101	Seismic requirement for operation	63
6.102	Commutation switch	63
6.103	Insulated platform	65
6.104	Commutation capacitor	65
6.105	Energy dissipation device	66
6.106	Reactor	66
6.107	Making switch (if applicable)	66
6.108	Charging device (if applicable)	66
7	Type tests	66
7.1	General	66
7.2	Dielectric tests	69
7.3	Resistance measurement	76
7.4	Continuous current tests	78
7.5	Short-time withstand current and peak withstand current tests	85
7.6	Verification of the protection	87
7.7	Tightness tests	87
7.8	Electromagnetic compatibility tests (EMC)	90
7.9	Additional tests on auxiliary and control circuits	95
7.10	X-radiation test for vacuum interrupters	97
7.101	Mechanical and environmental tests	100
7.102	Seismic tests	111
7.103	Direct current commutation tests	111
7.104	Direct arc withstand tests	115
8	Routine tests	118
8.1	General	118
8.2	Dielectric test on the main circuit	118
8.3	Tests on auxiliary and control circuits	119
8.4	Measurement of the resistance of the main circuit	120
8.5	Tightness test	120
8.6	Design and visual checks	121
8.101	Mechanical operating tests	121
9	Guide to the selection of switchgear and controlgear (informative)	122
9.1	General	122
9.2	Selection of rated values	123
9.3	Cable-interface considerations	124
9.4	Continuous or temporary overload due to changed service conditions	124
9.5	Environmental aspects	124
9.101	Selection of the application	125
10	Information to be given with enquiries, tenders and orders (informative)	127
10.1	General	127

10.2	Information with enquiries and orders	127
10.3	Information with tenders.....	129
11	Transport, storage, installation, operating instructions and maintenance.....	131
11.1	General.....	131
11.2	Conditions during transport, storage and installation	131
11.3	Installation	131
11.4	Operating instructions	134
11.5	Maintenance	134
12	Safety.....	137
12.1	General.....	137
12.2	Precautions by manufacturers.....	138
12.3	Precautions by users	138
13	Influence of the product on the environment	139
Annex A (informative) Examples of HVDC side switchgear arrangement for one pole in an HVDC substation		140
Annex B (informative) Exposure to pollution.....		142
B.1	General.....	142
B.2	Minimum requirements for switchgear in normal service condition.....	142
B.3	Minimum requirements for switchgear in special service condition	142
Annex C (informative) Preferred insulation levels for rated voltages lower than 105 kV		143
Annex D (informative) Short-circuit current in HVDC systems		144
D.1	VSC HVDC	144
D.2	LCC HVDC	145
D.3	Special case of LCC HVDC DC faults – LCC as diode bridge.....	145
D.4	HVDC systems with DC circuit-breakers.....	147
D.5	Calculation of the rated short-time withstand direct current	148
D.6	Calculation of Joule integral value (E_j)	149
Annex E (informative) References for auxiliary and control circuit components		150
Annex F (informative) List of symbols		152
Annex G (normative) Method for the weatherproofing test for outdoor switchgear and controlgear		154
Annex H (normative) Tolerances on test quantities during tests		157
Annex I (informative) Extension of validity of type tests.....		160
I.1	General.....	160
I.2	Dielectric tests	160
I.3	Short-time withstand current and peak withstand current tests	160
I.4	Electromagnetic immunity test on auxiliary and control circuits	160
I.5	Environmental tests on auxiliary and control circuits	160
Annex J (normative) Identification of test objects		162
J.1	General.....	162
J.2	Data.....	162
J.3	Drawings.....	162
Annex K (informative) Test circuit for superimposed impulse voltage tests		164
K.1	General.....	164
K.2	Test circuit using blocking capacitor.....	164
K.3	Test circuit using sphere gap	164

Annex L (informative) Information and technical requirements to be given with enquiries, tenders and orders	166
L.1 General.....	166
L.2 Normal and special service conditions (refer to Clause 4)	166
L.3 Ratings (refer to Clause 5)	167
L.4 Design and construction (refer to Clause 6)	167
L.5 System information	168
L.6 Documentation for enquiries and tenders	168
Annex M (informative) Electromagnetic compatibility on site	169
Annex N (informative) Standardization activities of HVDC	170
Annex A (normative) Test requirements for components of DC transfer switches	171
A.1 Commutation switch.....	171
A.2 Making switch	171
A.3 Commutation capacitor	171
A.4 Energy dissipation device	172
A.5 Reactor.....	172
A.6 Charging device.....	172
Annex B (informative) Additional information about test circuit and measured signals for DC transfer switches having an oscillation branch	174
B.1 Test circuits for direct current transfer test.....	174
B.2 Test circuits for direct arc withstand test	176
Annex C (normative) Tolerances on test quantities during tests	178
Annex D (normative) Records and reports of type tests.....	181
D.1 Information and results to be recorded	181
D.2 Information to be included in type test reports.....	181
Annex E (informative) Extension of validity of type tests	184
E.1 General.....	184
E.2 Dielectric tests	184
E.3 Continuous current test.....	184
E.4 Electromagnetic immunity test on auxiliary and control circuits	184
E.5 Environmental tests on auxiliary and control circuits	185
E.6 DC transfer current test.....	185
Bibliography.....	186
Figure 1 – Schematic representation of superimposed impulse voltage tests	43
Figure 2 – Typical waveform of a short-circuit current in an HVDC system	45
Figure 3 – Examples of classes of contacts.....	54
Figure 4 – Diagram of connections of a switching device	72
Figure 5 – Test sequence for polarity reversal tests	75
Figure 7 – Test location of radiation survey instrument	99
Figure 1 – Test sequence for low temperature test.....	106
Figure 2 – Test sequence for high temperature test	108
Figure 3 – Humidity test.....	110
Figure 4 – General layout of test circuit for direct current commutation test	113
Figure 5 – Current commutation test with low-frequency alternating current.....	114
Figure 6 – General layout of test circuit for direct arc withstand test.....	116

Figure 7 – Equivalent transfer circuit of MRTS and ERTS	125
Figure 8 – Equivalent transfer circuit of NBS.....	126
Figure 9 – Equivalent transfer circuit of NBES	127
Figure A.1 – Example of HVDC side switchgear arrangement for one pole in an HVDC substation	141
Figure D.1 – VSC HVDC under worst-case, pole-pole DC fault	144
Figure D.2 – LCC HVDC under worst-case, pole-pole DC fault.....	145
Figure D.3 – Special case LCC HVDC under worst-case, pole-pole DC fault.....	146
Figure D.4 – HVDC system with DC circuit-breaker under worst-case, pole-pole DC fault	147
Figure D.5 – DC circuit-breaker simple model.....	147
Figure D.6 – Equivalent fault current for calculation of rated short time withstand direct current.....	148
Figure G.1 – Arrangement for weatherproofing test.....	155
Figure G.2 – Nozzle for weatherproofing test	156
Figure K.1 – Test circuit for superimposed impulse tests using blocking capacitor	164
Figure K.2 – Test circuit for superimposed impulse tests using sphere gap	165
Figure B.1 – Test circuit with measuring points	174
Figure B.2 – Measured signals during test (overview)	175
Figure B.3 – Measured signals during test (expanded in time)	176
Figure B.4 – Test circuit of direct arc withstand tests	177
Table 1 – Preferred rated insulation levels	41
Table 1 – Rated insulation levels for transfer switches	44
Table 2 – Direct voltage of auxiliary and control circuits.....	47
Table 3 – Alternating voltage of auxiliary and control circuits	47
Table 4 – Auxiliary contact classes	53
Table 2 – Nameplate information	57
Table 5 – Nameplate information	59
Table 3 – Classification of commutation switches and making switches	65
Table 4 – Type tests	67
Table 6 – Test conditions in general case	72
Table 7 – Test conditions in case of impulse voltage tests across the isolating distance (or open switching device)	72
Table 8 – Test conditions in case of superimposed impulse voltage tests	73
Table 9 – Test conditions for polarity reversal tests	75
Table 10 – Limits of temperature and temperature rise for various parts, materials and dielectrics of high-voltage switchgear and controlgear	81
Table 11 – Permissible leakage rates for gas systems	88
Table 12 – Application of voltages at the fast transient/burst test.....	92
Table 13 – Application of voltage at the damped oscillatory wave test.....	93
Table 14 – Assessment criteria for transient disturbance immunity.....	94
Table 5 – Number of operating sequences for commutation switches.....	103
Table 6 – Number of operating sequences for making switches	103
Table C.1 – Preferred insulation levels for rated voltages lower than 105 kV.....	143

Table E.1 – List of reference documents for auxiliary and control circuit components.....	150
Table H.1 – Tolerances on test quantities for type test.....	157
Table J.1 Drawing list and contents	162
Table B.1 – Legend of measuring points	177
Table C.1 – Tolerances on test quantities for type test.....	178

INTERNATIONAL ELECTROTECHNICAL COMMISSION

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 315: Direct current (DC) transfer switches

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

This extended version (EXV) of the official IEC Standard provides the user with the full content of the Standard.

IEC TS 62271-315 EXV includes the content of IEC TS 62271-315:2025, and the references made to IEC TS 62271-5:2024.

The specific content of IEC TS 62271-315:2025 is displayed on a blue background.

IEC TS 62271-315 has been prepared by subcommittee 17A: Switching devices, of IEC technical committee 17: High-voltage switchgear and controlgear. It is a Technical Specification.

The text of this Technical Specification is based on the following documents:

Draft	Report on voting
17A/1412/DTS	17A/1417/RVDTS

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Technical Specification is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

This document is to be read in conjunction with IEC TS 62271-5:2024, to which it refers and which is applicable unless otherwise specified. In order to simplify the indication of corresponding requirements, the same numbering of clauses and subclauses is used as in IEC TS 62271-5. Amendments to these clauses and subclauses are given under the same references whilst additional subclauses are numbered from 101.

A list of all parts of IEC 62271 series, under the general title *High-voltage switchgear and controlgear* can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

INTRODUCTION to IEC TS 62271-5:2024

This Technical Specification has been prepared by TC 17 and it defines common specifications for high-voltage direct current (HVDC) switchgear and controlgear covering both types of air insulated (AIS) and gas insulated (GIS) equipment of HVDC substations. This document includes rules for service conditions, ratings, design and construction requirements. Test requirements and criteria to proof for passing type and routine tests are defined in this document for development and manufacturing of HVDC switchgear.

This specification is applicable for both LCC and VSC HVDC technology.

SC 17A is in the process of preparing documents for the following HVDC switching devices:

- circuit-breakers (IEC TS 62271-313 [1])¹;
- disconnectors and earthing switches (IEC TS 62271-314 [2]);
- transfer switches (IEC TS 62271-315 [3]);
- by-pass switches and paralleling switches (IEC TS 62271-316 [4]).

SC 17C is in the process of preparing a document for DC gas insulated switchgears (IEC TS 62271-318 [5]).

Standardization of direct voltages is the responsibility of TC 8 (System aspects of electrical energy supply).

TC 99 (Insulation co-ordination and system engineering of high voltage electrical power installations above 1,0 kV AC and 1,5 kV DC) defines requirements of DC substations for safety of insulation, equipment, installation and earthing (IEC 61936-2).

TC 115 (High Voltage Direct Current (HVDC) transmission for DC voltages above 100 kV) is responsible for DC transmission system aspects. It is the responsibility of TC 115 to define requirements for different equipment (e. g. switching devices) from system point of view. These definitions are implemented in documents from other TCs. Several Working Groups and Maintenance Teams are preparing documents on reliability, EMC, asset management, system design, DC harmonics, testing, HVDC grids, VSC and LCC converter and insulation coordination for HVDC systems.

¹ Numbers in square brackets refer to the Bibliography.

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 315: Direct current (DC) transfer switches

1 Scope

This part of IEC 62271 is applicable to direct current (DC) transfer switches designed for indoor or outdoor installation and for operation on HVDC transmission systems having direct voltages of 100 kV and above.

DC transfer switches normally include metallic return transfer switches (MRTS), earth return transfer switches (ERTS), neutral bus switches (NBS) and neutral bus earthing switches (NBES).

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038:2009, *IEC standard voltages*

IEC 60050-614:2016, *International Electrotechnical Vocabulary (IEV) – Part 614: Generation, transmission and distribution of electricity – Operation*

IEC 60050-811, *International Electrotechnical Vocabulary (IEV) – Part 811: Electric traction*

IEC 60050-826:2022, *International Electrotechnical Vocabulary (IEV) – Part 826: Electrical installations*

IEC 60060-1:2010, *High-voltage test techniques – Part 1: General definitions and test requirements*

IEC 60068-2-1:2007, *Environmental testing – Part 2-1: Tests – Test A: Cold*

IEC 60068-2-2:2007, *Environmental testing – Part 2-2: Tests – Test B: Dry heat*

IEC 60068-2-17:1994, *Basic environmental testing procedures – Part 2-17: Tests – Test Q: Sealing*

IEC 60068-2-30:2005, *Environmental testing – Part 2-30: Tests – Test Db: Damp heat, cyclic (12 h + 12 h cycle)*

IEC 60071-1:2019, *Insulation co-ordination – Part 1: Definitions, principles and rules*

IEC 60071-2:2018, *Insulation co-ordination – Part 2: Application guidelines*

IEC 60071-11:2022, *Insulation co-ordination – Part 11: Definitions, principles and rules for HVDC system*

IEC 60076-6, *Power transformers– Part 6: Reactors*

IEC 60085:2007, *Electrical insulation – Thermal evaluation and designation*

IEC 60099-9, *Surge arresters – Part 9: Metal-oxide surge arresters without gaps for HVDC converter stations*

IEC 60255-21-1:1988, *Electrical relays – Part 21: Vibration, shock, bump and seismic tests on measuring relays and protection equipment – Section One: Vibration tests (sinusoidal)*

IEC 60270:2000, *High-voltage test techniques – Partial discharge measurements*

IEC 60296, *Fluids for electrotechnical applications – Mineral insulating oils for electrical equipment*

IEC 60376, *Specification of technical grade sulphur hexafluoride (SF₆) and complementary gases to be used in its mixtures for use in electrical equipment*

IEC 60417:2006, *Graphical symbols for use on equipment (available at <http://www.graphical-symbols.info/equipment>)*

IEC 60437, *Radio interference test on high-voltage insulators*

IEC 60480, *Specifications for the re-use of sulphur hexafluoride (SF₆) and its mixtures in electrical equipment*

IEC 60512-2-2, *Connectors for electronic equipment – Tests and measurements – Part 2-2: Electrical continuity and contact resistance tests – Test 2b: Contact resistance – Specified test current method*

IEC 60529:1989, *Degrees of protection provided by enclosures (IP Code)*

IEC 60529:1989/AMD1:1999

IEC 60529:1989/AMD2:2013

IEC 60633, *High-voltage direct current (HVDC) transmission – Vocabulary*

IEC TS 60815-4:2016, *Selection and dimensioning of high-voltage insulators intended for use in polluted conditions – Part 4: Insulators for DC systems*

IEC 60871-1, *Shunt capacitors for a.c. power systems having a rated voltage above 1 000 V – Part 1: General*

IEC 61000-4-4, *Electromagnetic compatibility (EMC) – Part 4-4: Testing and measurement techniques – Electrical fast transient/burst immunity test*

IEC 61000-4-11, *Electromagnetic compatibility (EMC) – Part 4-11: Testing and measurement techniques – Voltage dips, short interruptions and voltage variations immunity tests for equipment with input current up to 16 A per phase*

IEC 61000-4-17:1999, *Electromagnetic compatibility (EMC) – Part 4-17: Testing and measurement techniques – Ripple on d.c. input power port immunity test*

IEC 61000-4-18:2019, *Electromagnetic compatibility (EMC) – Part 4-18: Testing and measurement techniques – Damped oscillatory wave immunity test*

IEC 61000-4-29, *Electromagnetic compatibility (EMC) – Part 4-29: Testing and measurement techniques – Voltage dips, short interruptions and voltage variations on DC input power port immunity tests*

IEC 61000-6-2, *Electromagnetic compatibility (EMC) – Part 6-2: Generic standards – Immunity standard for industrial environments*

IEC 61000-6-5, *Electromagnetic compatibility (EMC) – Part 6-5: Generic standards – Immunity for equipment used in power station and substation environment*

IEC 61180, *High-voltage test techniques for low-voltage equipment – Definitions, test and procedure requirements, test equipment*

IEC TS 61245, *Artificial pollution tests on high-voltage ceramic and glass insulators to be used on DC systems*

IEC 61810-7:2006, *Electromechanical elementary relays – Part 7: Test and measurement procedures*

IEC 62262:2002, *Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts (IK code)*

IEC 62271-1:2017, *High-voltage switchgear and controlgear – Part 1: Common specifications for alternating current switchgear and controlgear*

IEC 62271-1:2017/AMD1:2021

IEC 62271-4, *High-voltage switchgear and controlgear – Part 4: Handling procedures for gases for insulation and/or switching*

IEC TS 62271-5:2024, *High-voltage switchgear and controlgear – Part 5: Common specifications for direct current switchgear and controlgear*

IEC 62271-100:2021, *High-voltage switchgear and controlgear – Part 100: Alternating-current circuit-breakers*

IEC 62271-102:2018, *High-voltage switchgear and controlgear – Part 102: Alternating-current disconnectors and earthing switches*

IEC 62271-207, *High-voltage switchgear and controlgear – Part 207: Seismic qualification for gas-insulated switchgear assemblies for rated voltages above 52 kV*

IEC TS 63014-1, *High-voltage direct current (HVDC) power transmission – System requirements for DC-side equipment Part 1: Using line-commutated converters*

CISPR 11:2015, *Industrial, scientific and medical equipment – Radio-frequency disturbance characteristics – Limits and methods of measurement*

CISPR 16-1 (all parts), *Specification for radio disturbance and immunity measuring apparatus and methods – Part 1: Radio disturbance and immunity measuring apparatus*

CISPR TR 18-2, *Radio interference characteristics of overhead power lines and high-voltage equipment – Part 2: Methods of measurement and procedure for determining limits*

TECHNICAL SPECIFICATION

**High-voltage switchgear and controlgear –
Part 315: Direct current (DC) transfer switches**

CONTENTS

FOREWORD	7
1 Scope	9
2 Normative references	9
3 Terms and definitions	10
3.1 General terms and definitions	10
3.2 Assemblies of switchgear and controlgear	10
3.3 Parts of assemblies	10
3.4 Switching devices	10
3.5 Parts of switchgear and controlgear	12
3.6 Operational characteristics of DC transfer switches	13
3.7 Characteristic quantities	13
3.8 Index of definitions.....	14
4 Normal and special service conditions	15
5 Ratings.....	16
5.1 General.....	16
5.2 Rated direct voltage (U_{rd}).....	16
5.3 Rated insulation level (U_{dd} , U_p , U_s)	16
5.4 Rated continuous current (I_{rd})	17
5.5 Rated values of short-time withstand current.....	17
5.5.1 Typical waveform of short-circuit current.....	17
5.5.2 Rated short-time withstand direct current (I_{kd})	17
5.5.3 Rated peak withstand current (I_{pd}).....	17
5.5.4 Rated duration of short circuit (t_{kd}).....	17
5.6 Rated supply voltage of auxiliary and control circuits (U_a)	17
5.6.1 General	17
5.6.2 Rated supply voltage (U_a)	17
5.7 Rated supply frequency of auxiliary and control circuits	17
5.8 Rated pressure of compressed gas supply for controlled pressure systems	18
5.101 Rated direct voltage of transfer switch (U_{rts})	18
5.102 Rated transfer current (I_t)	18
5.103 Rated commutation voltage (U_c)	18
5.104 Rated dissipated energy during transfer operation (E_{rd}).....	18
5.105 Rated operating sequence	19
5.106 Rated open-close time	19
6 Design and construction	19
6.1 Requirements for liquids in switchgear and controlgear.....	19
6.2 Requirements for gases in switchgear and controlgear	19
6.3 Earthing of switchgear and controlgear	19
6.4 Auxiliary and control equipment and circuits	19
6.5 Dependent power operation	20
6.6 Stored energy operation.....	20
6.7 Independent unlatched operation (independent manual or power operation)	20
6.8 Manually operated actuators	20
6.9 Operation of releases.....	20

6.10	Pressure/level indication	20
6.11	Nameplates.....	20
6.12	Locking devices	22
6.13	Position indication.....	22
6.14	Degrees of protection by enclosures	22
6.15	Creepage distances for outdoor insulators	22
6.16	Gas and vacuum tightness	22
6.17	Tightness for liquid system	22
6.18	Fire hazard (flammability)	22
6.19	Electromagnetic compatibility (EMC).....	22
6.20	X-ray emission	22
6.21	Corrosion	22
6.22	Filling levels for insulation, switching and operation	22
6.101	Seismic requirement for operation.....	22
6.102	Commutation switch.....	22
6.102.1	General requirement for operation	22
6.102.2	Pressure limits of fluids for operation.....	23
6.102.3	Vent outlets	23
6.102.4	Time quantities	23
6.102.5	Static mechanical loads	23
6.102.6	Classification	24
6.102.7	Arcing withstand capability	24
6.103	Insulated platform	25
6.104	Commutation capacitor	25
6.105	Energy dissipation device	25
6.106	Reactor.....	25
6.107	Making switch (if applicable)	25
6.108	Charging device (if applicable).....	25
7	Type tests	25
7.1	General.....	25
7.1.1	Basics	25
7.1.2	Information for identification of test objects.....	27
7.1.3	Information to be included in type-test reports	27
7.2	Dielectric tests	27
7.2.1	General	27
7.2.2	Ambient air conditions during tests	27
7.2.3	Wet test procedure	27
7.2.4	Arrangement of the equipment.....	27
7.2.5	Criteria to pass the test	27
7.2.6	Application of the test voltage and test conditions.....	27
7.2.7	Tests of switchgear and controlgear	28
7.2.8	Artificial pollution tests for outdoor insulators.....	29
7.2.9	Partial discharge tests	29
7.2.10	Dielectric tests on auxiliary and control circuits.....	29
7.2.11	Voltage test as condition check	29
7.3	Resistance measurement.....	29
7.3.1	Measurement of the resistance of auxiliary contacts class 1 and class 2.....	29
7.3.2	Measurement of the resistance of auxiliary contacts class 3	29
7.3.3	Electrical continuity of earthed metallic parts test	29

7.3.4	Resistance measurement of contacts and connections in the main circuit as a condition check	29
7.4	Continuous current tests	30
7.4.1	Condition of the test object	30
7.5	Short-time withstand current and peak withstand current tests	30
7.5.1	General	30
7.5.2	Arrangement of the equipment and of the test circuit	30
7.5.3	Test current and duration	30
7.5.4	Conditions of the test object after test	30
7.6	Verification of the protection	30
7.7	Tightness tests	30
7.8	Electromagnetic compatibility tests (EMC)	31
7.9	Additional tests on auxiliary and control circuits	31
7.10	X-radiation test for vacuum interrupters	31
7.101	Mechanical and environmental tests	31
7.101.1	Miscellaneous provisions for mechanical and environmental tests	31
7.101.2	Mechanical operation tests at ambient air temperature	33
7.101.3	Low and high temperature tests	35
7.101.4	Humidity test	40
7.101.5	Test to prove the operation under severe ice conditions	42
7.102	Seismic tests	42
7.103	Direct current commutation tests	42
7.103.1	General	42
7.103.2	Arrangement of the transfer switch during test	43
7.103.3	Test circuit	44
7.103.4	Test procedure	45
7.103.5	Behaviour of DC transfer switch during test	46
7.103.6	Criteria to pass the test	46
7.104	Direct arc withstand tests	46
7.104.1	General	46
7.104.2	Arrangement of the transfer switch during test	47
7.104.3	Test circuit	47
7.104.4	Test procedure	48
7.104.5	Behaviour of DC transfer switch during test	48
7.104.6	Criteria to pass the test	48
8	Routine tests	49
8.1	General	49
8.2	Dielectric test on the main circuit	49
8.3	Tests on auxiliary and control circuits	49
8.4	Measurement of the resistance of the main circuit	49
8.5	Tightness test	49
8.6	Design and visual checks	49
8.101	Mechanical operating tests	49
9	Guide to the selection of DC transfer switches (informative)	51
9.1	General	51
9.2	Selection of rated values	51
9.2.101	General	51
9.2.102	Selection of rated direct voltage of transfer switch and rated insulation level	51

9.2.103	Selection of rated operating sequence	51
9.2.104	Selection of rated continuous current	52
9.2.105	Selection of rated values of short time withstand current	52
9.2.106	Selection of rated transfer current	52
9.2.107	Selection of rated commutation voltage	52
9.3	Cable-interface considerations	52
9.4	Continuous or temporary overload due to changed service conditions	52
9.5	Environmental aspects	52
9.101	Selection of the application	52
9.101.1	MRTS	52
9.101.2	ERTS	53
9.101.3	NBS	53
9.101.4	NBES	54
10	Information to be given with enquiries, tenders and orders (informative)	55
10.1	General	55
10.2	Information with enquiries and orders	55
10.3	Information with tenders	56
11	Transport, storage, installation, operating instructions and maintenance	58
12	Safety	58
13	Influence of the product on the environment	58
Annex A	(normative) Test requirements for component of DC transfer switches	59
A.1	Commutation switch	59
A.2	Making switch	59
A.3	Commutation capacitor	59
A.4	Energy dissipation device	60
A.5	Reactor	60
A.6	Charging device	60
A.6.1	Type tests for charging device	60
A.6.2	Routine test for charging device	61
Annex B	(informative) Additional information about test circuit and measured signals for DC transfer switches having an oscillation branch	62
B.1	Test circuits for direct current transfer test	62
B.2	Test circuits for direct arc withstand test	64
Annex C	(normative) Tolerances on test quantities during tests	66
Annex D	(normative) Records and reports of type tests	69
D.1	Information and results to be recorded	69
D.2	Information to be included in type test reports	69
D.2.1	General	69
D.2.2	Apparatus tested	69
D.2.3	Rated characteristics of DC transfer switch, including its operating devices and auxiliary equipment	69
D.2.4	Test conditions (for each series of tests)	70
D.2.5	Direct current commutation tests	70
D.2.6	Direct arc withstand tests	70
D.2.7	Short-time withstand current test	70
D.2.8	No-load operation	71
D.2.9	Oscillographic and other records	71
Annex E	(informative) Extension of validity of type tests	72

E.1	General.....	72
E.2	Dielectric tests	72
E.3	Continuous current test.....	72
E.4	Electromagnetic immunity test on auxiliary and control circuits	72
E.5	Environmental tests on auxiliary and control circuits	73
E.6	DC transfer current test.....	73
	Bibliography.....	74
	Figure 1 – Test sequence for low temperature test.....	37
	Figure 2 – Test sequence for high temperature test	39
	Figure 3 – Humidity test.....	41
	Figure 4 – General layout of test circuit for direct current commutation test	44
	Figure 5 – Current commutation test with low-frequency alternating current.....	45
	Figure 6 – General layout of test circuit for direct arc withstand test.....	47
	Figure 7 – Equivalent transfer circuit of MRTS and ERTS	53
	Figure 8 – Equivalent transfer circuit of NBS.....	54
	Figure 9 – Equivalent transfer circuit of NBES	55
	Figure B.1 – Test circuit with measuring points	62
	Figure B.2 – Measured signals during test (overview)	63
	Figure B.3 – Measured signals during test (expanded in time)	64
	Figure B.4 – Test circuit of direct arc withstand tests	65
	Table 1 – Rated insulation levels for transfer switches	17
	Table 2 – Nameplate information	21
	Table 3 – Classification of commutation switches and making switches	24
	Table 4 – Type tests	26
	Table 5 – Number of operating sequences for commutation switches.....	34
	Table 6 – Number of operating sequences for making switches	35
	Table B.1 – Legend of measuring points	65
	Table C.1 – Tolerances on test quantities for type test.....	66

INTERNATIONAL ELECTROTECHNICAL COMMISSION

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 315: Direct current (DC) transfer switches

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

IEC TS 62271-315 has been prepared by subcommittee 17A: Switching devices, of IEC technical committee 17: High-voltage switchgear and controlgear. It is a Technical Specification.

The text of this Technical Specification is based on the following documents:

Draft	Report on voting
17A/1412/DTS	17A/1417/RVDTS

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Technical Specification is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

This document is to be read in conjunction with IEC TS 62271-5:2024, to which it refers and which is applicable unless otherwise specified. In order to simplify the indication of corresponding requirements, the same numbering of clauses and subclauses is used as in IEC TS 62271-5. Amendments to these clauses and subclauses are given under the same references whilst additional subclauses are numbered from 101.

A list of all parts of IEC 62271 series, under the general title *High-voltage switchgear and controlgear* can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 315: Direct current (DC) transfer switches

1 Scope

This part of IEC 62271 is applicable to direct current (DC) transfer switches designed for indoor or outdoor installation and for operation on HVDC transmission systems having direct voltages of 100 kV and above.

DC transfer switches normally include metallic return transfer switches (MRTS), earth return transfer switches (ERTS), neutral bus switches (NBS) and neutral bus earthing switches (NBES).

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60060-1:2010, *High-voltage test techniques – Part 1: General definitions and test requirements*

IEC 60068-2-1:2007, *Environmental testing – Part 2-1: Tests – Test A: Cold*

IEC 60068-2-2:2007, *Environmental testing – Part 2-2: Tests – Test B: Dry heat*

IEC 60068-2-30:2005, *Environmental testing – Part 2-30: Tests – Test Db: Damp heat, cyclic (12 h + 12 h cycle)*

IEC 60071-11:2022, *Insulation co-ordination – Part 11: Definitions, principles and rules for HVDC system*

IEC 60076-6, *Power transformers– Part 6: Reactors*

IEC 60099-9, *Surge arresters – Part 9: Metal-oxide surge arresters without gaps for HVDC converter stations*

IEC 60255-21-1:1988, *Electrical relays – Part 21: Vibration, shock, bump and seismic tests on measuring relays and protection equipment – Section One: Vibration tests (sinusoidal)*

IEC 60270:2000, *High-voltage test techniques – Partial discharge measurements*

IEC 60633, *High-voltage direct current (HVDC) transmission – Vocabulary*

IEC 60871-1, *Shunt capacitors for a.c. power systems having a rated voltage above 1 000 V – Part 1: General*

IEC 61000-4-18:2019, *Electromagnetic compatibility (EMC) – Part 4-18: Testing and measurement techniques – Damped oscillatory wave immunity test*

IEC TS 62271-5:2024, *High-voltage switchgear and controlgear – Part 5: Common specifications for direct current switchgear and controlgear*

IEC 62271-100:2021, *High-voltage switchgear and controlgear – Part 100: Alternating-current circuit-breakers*

IEC 62271-102:2018, *High-voltage switchgear and controlgear – Part 102: Alternating-current disconnectors and earthing switches*

IEC 62271-207, *High-voltage switchgear and controlgear – Part 207: Seismic qualification for gas-insulated switchgear assemblies for rated voltages above 52 kV*

IEC TS 63014-1, *High-voltage direct current (HVDC) power transmission – System requirements for DC-side equipment Part 1: Using line-commutated converters*