



Edition 1.0 2025-08

TECHNICAL SPECIFICATION

Power quality measurement in power supply systems -

Part 3: Maintenance tests, calibration

ICS 17.220.20 ISBN 978-2-8327-0613-8



THIS PUBLICATION IS COPYRIGHT PROTECTED Copyright © 2025 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat Tel.: +41 22 919 02 11

3, rue de Varembé info@iec.ch CH-1211 Geneva 20 www.iec.ch

Switzerland

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search -

webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublishedStay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews, graphical symbols and the glossary. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 500 terminological entries in English and French, with equivalent terms in 25 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

CONTENTS

FOREWO)RD	3	
1 Scop	oe	5	
2 Norn	native references	5	
3 Term	ns and definitions	6	
	itenance test		
4.1	Need		
4.1	Decision rule		
4.3	General		
4.4	Applicability of type test		
4.5	Clock		
4.6	Analogue front-end for voltage		
4.7	Analogue front-end for current		
	pration of artifact reference		
5.1	Need		
5.2	Uncertainty	_	
5.3	General		
5.4	Calibration programme		
5.5	Clock		
5.6	Analogue front-end for voltage		
5.6.1	•		
5.6.2			
5.6.3	B Flicker	17	
5.6.4	Harmonics	17	
5.7	Analogue front-end for current	17	
5.7.1	Magnitude of current	17	
5.7.2	2 Unbalance	18	
5.7.3	B Harmonics	18	
5.8	Example of a calibration programme for voltage	18	
	(informative) Example: Guidelines for additional integrity verification of the bower analyzer, if necessary, before performing a harmonic voltage study	19	
A.1	General	19	
A.2	Integrity test for the instrument		
A.3	Phase angle of current and voltage channels		
A.4	Influence factor study		
A.5	Influence of the anti-aliasing filter		
A.6	PLL error	24	
A.7	Duty factor	24	
A.8	Amplitude flatness (tilt)	25	
Bibliograp	phy	26	
	Block diagram showing parts whose metrological properties are subject to nd other parts	9	
-	1 – Filtered 60 Hz square waveform with 10 th order Butterworth filter tuned to		
	2,85 kHz22		
	2 – 10 V (20 V peak-to-peak) square-wave waveform processed by a 4 th order		
	ing Butterworth filter tuned at 10 kHz	23	
Figure A.3 – Example of the square waveform with an error of 2,5 % on the duty cycle24			

Figure A.4 – Example of the tilt of 25 %, which is the reduction of the amplitude by 25 % at each half cycle	25
Figure A.5 – Square waveform with a tilt of 1,225 %	25
Table 1 – Test: Applicability of type test (Classes A and S)	11
Table 2 – Test: Clock (Class A)	11
Table 3 – Test: Clock (Class S)	12
Table 4 – Test: Analogue front-end for voltage (Class A)	12
Table 5 – Test: Analogue front-end for voltage (Class S)	13
Table 6 – Test: Analogue front-end for current (Class A)	14
Table 7 – Test: Analogue front-end for current (Class S)	15
Table 8 – Example: calibration programme for magnitude of supply voltage	18
Table A.1 – Level of harmonic voltage produced by a 20 V peak-to-peak square waveform in relation to the 230 V power system	20
Table A.2 – Error in amplitude and angle due to the 10 th order anti-aliasing Butterworth filter tuned at 2,85 kHz	21
Table A.3 – Error of the phase angle due to the group delay of the anti-aliasing filter	23

INTERNATIONAL ELECTROTECHNICAL COMMISSION

Power quality measurement in power supply systems - Part 3: Maintenance tests, calibration

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at https://patents.iec.ch. IEC shall not be held responsible for identifying any or all such patent rights.

IEC TS 62586-3 has been prepared by IEC technical committee 85: Measuring equipment for electrical and electromagnetic quantities. It is a Technical Specification.

The text of this Technical Specification is based on the following documents:

Draft	Report on voting
85/948/DTS	85/962/RVDTS

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Technical Specification is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts in the IEC 62586 series, published under the general title *Power quality measurement in power supply systems*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- · reconfirmed,
- withdrawn, or
- revised.

1 Scope

This part of IEC 62586, which is a Technical Specification, describes a procedure used for maintenance tests of individual power quality instruments. Users of these instruments need to ensure the conformity of the individual power quality instrument for stationary use with the requirements of IEC 62586-1. This is achieved by periodic maintenance tests as defined in this document.

Reference instruments used for these tests need to be calibrated periodically to maintain traceability as required by ISO/IEC 17025. This document describes a calibration programme matching the needs of users carrying out maintenance tests.

The procedure for maintenance tests described here is a suggestion intended to be sufficient in most practical cases for the common principles of implementation of power quality instruments. This document is informative and does not limit the freedom of users with advanced knowledge of their instruments or with special needs to implement specific programmes in any way.

This document is applicable to power quality instruments complying with IEC 62586-1 and whose compliance with IEC 61000-4-30 has been certified based on a type test according to IEC 62586-2.

Adjustment, type test, routine test and field test are out of scope of this document.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61000-4-7:2002, Electromagnetic compatibility (EMC) - Part 4-7: Testing and measurement techniques - General guide on harmonics and telharmonic measurements and instrumentation, for power supply systems and equipment connected thereto

IEC 61000-4-30, Electromagnetic compatibility (EMC) - Part 4-30: Testing and measurement techniques - Power quality measurement methods

IEC 62586-2, Power quality measurement in power supply systems - Part 2: Functional tests and uncertainty requirements

ISO/IEC 17025:2017, General requirements for the competence of testing and calibration laboratories

ISO/IEC Guide 98-3, Uncertainty of measurement - Part 3: Guide to the expression of uncertainty in measurement (GUM:1995)

ISO/IEC Guide 98-4, Uncertainty of measurement - Part 4: Role of measurement uncertainty in conformity assessment