



IEC TS 62898-3-1

Edition 1.1 2023-11
CONSOLIDATED VERSION

INTERNATIONAL STANDARD



**Microgrids –
Part 3-1: Technical requirements - Protection and dynamic control**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.240.01

ISBN 978-2-8322-7827-7

Warning! Make sure that you obtained this publication from an authorized distributor.



REDLINE VERSION



Microgrids – Part 3-1: Technical requirements - Protection and dynamic control



CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	8
2 Normative references	8
3 Terms and definitions	8
4 Microgrid protection requirements.....	15
4.1 General.....	15
4.2 Main requirements specific to microgrids	16
4.2.1 General	16
4.2.2 Phase fault protection	16
4.2.3 Earth fault protection	17
4.3 General protection requirements	17
4.3.1 General	17
4.3.2 Dependability of protection	17
4.3.3 Security of protection.....	18
4.3.4 Availability and selectivity of protection.....	18
4.3.5 Operating time (speed) of protection.....	19
4.4 Particular requirements for non-isolated microgrids.....	19
4.5 Particular requirements for isolated microgrids.....	20
5 Protection systems for microgrids	20
5.1 General.....	20
5.2 Short-circuit protection.....	21
5.2.1 Overcurrent protection	21
5.2.2 Directional overcurrent protection	23
5.2.3 Distance protection	24
5.2.4 Directional power protection	24
5.2.5 Differential protection	24
5.3 System protection	25
5.3.1 Under/over voltage protection.....	25
5.3.2 Frequency protection	26
5.4 Centralized protection systems	26
6 Dynamic stability and control	27
6.1 General.....	27
6.2 Dynamic stability in microgrids.....	27
6.2.1 General	27
6.2.2 Disturbances in microgrids.....	28
6.2.3 Voltage and frequency stability	28
6.3 Dynamic control in microgrids	29
6.3.1 General requirements	29
6.3.2 Dynamic control functions.....	29
6.3.3 Control elements in microgrids.....	30
6.3.4 Control systems of microgrids.....	32
6.3.5 Control of microgrids during grid-connected mode	36
6.3.6 Control of microgrids during island mode	37
Annex A (informative) Use cases for dynamic control of microgrids	38
Bibliography.....	43

Figure 1 – Ratio between maximum load current/minimum short-circuit current in the microgrid 22

Figure 2 – Control elements in microgrids 31

~~Figure 3 – Hierarchical control levels of a microgrid 32~~

Figure 3 – Functional mapping for operation and control of microgrids 33

~~Figure 4 – Centralized multilevel control of microgrids 34~~

Figure 4 – Typical multilevel control of microgrids 34

Figure A.1 – Simple microgrid platform for testing transient disturbance during motor start-up 38

Figure A.2 – Transient control strategy based on reactive current compensation control 38

Figure A.3 – Voltage profile during field testing of transient disturbance with and without transient control device 39

Figure A.4 – Current profile during field testing of transient disturbance with and without transient control device 40

Figure A.5 – Microgrid platform with high proportion of RES for testing dynamic disturbance control 41

Figure A.6 – Dynamic control strategy 41

Figure A.7 – The voltage profile of field testing with and without dynamic control device 42

INTERNATIONAL ELECTROTECHNICAL COMMISSION

MICROGRIDS –

Part 3-1: Technical requirements – Protection and dynamic control

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendment has been prepared for user convenience.

IEC TS 62898-3-1 edition 1.1 contains the first edition (2020-09) [documents 8B/53/DTS and 8B/59/RVDTS] and its amendment 1 (2023-11) [documents 8B/174/DTS and 8B/199/RVDTS].

In this Redline version, a vertical line in the margin shows where the technical content is modified by amendment 1. Additions are in green text, deletions are in strikethrough red text. A separate Final version with all changes accepted is available in this publication.

The main task of IEC technical committees is to prepare International Standards. In exceptional circumstances, a technical committee may propose the publication of a Technical Specification when

- the required support cannot be obtained for the publication of an International Standard, despite repeated efforts, or
- the subject is still under technical development or where, for any other reason, there is the future but no immediate possibility of an agreement on an International Standard.

Technical Specifications are subject to review within three years of publication to decide whether they can be transformed into International Standards.

IEC TS 62898-3-1, which is a Technical Specification, has been prepared by IEC subcommittee 8B: Decentralized Electrical Energy Systems of IEC technical committee 8: System aspects of electrical energy supply.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 62898 series, published under the general title *Microgrids*, can be found on the IEC website.

The committee has decided that the contents of this document and its amendment will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The '*colour inside*' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

Microgrids can serve different purposes depending on the primary objectives of their applications. They are usually seen as a means to manage reliability of supply in a grid contingency and to facilitate local optimization of energy supply by controlling distributed energy resources (DER). Microgrids also present a way to provide electricity supply in remote areas, to use renewable energy as a systematic approach for rural electrification and to increase resiliency and security of supply to end users.

Deployment of DER can cause a microgrid or distribution system of a grid to face several challenges, including fault protection and dynamic control issues. There are, however, some issues commonly faced in the protection and control of microgrids which are less prevalent in large grids. These issues include: bidirectional flow of power resulting in voltage excursions outside acceptable limits, fault current being supplied from multiple sources, loss of synchronism between multiple sources when a fault occurs, potentially limited fault current magnitude, lower inertia or lower primary time constant, regular changes in operational configuration due to economic optimization, and intermittency of source-dependent renewable distributed generators. These issues worsen when the microgrid contains several converter-based generators (CBGs) and operates in island mode. As such, conventional protection and control strategies may not be suitable or sufficient for microgrids. Protection systems different from the conventional ones may be required. In some instances, protection systems may need to be adjusted dynamically based on the operating state of the microgrid.

Conventional power systems have predominantly consisted of power sources, such as fossil fuel-fired thermal power plants, hydro power plants and nuclear power plants, which are relatively stable and easy to control. On the other hand, microgrids often contain many different types of sources, many of which are intermittent. Hence, protection and dynamic control in microgrids need to be more sophisticated than in conventional power systems. However, the main grid contributes to the fault currents in the grid-connected mode of operation and hence the fault currents are large enough to actuate conventional protection devices. Though it is possible to employ conventional protection principles and existing standards for the protection of microgrids operating in grid-connected mode, the existing protection settings should be systematically assessed as the existence of DER may compromise the coordination of the protection system.

Due to the specific characteristics of microgrids and their frequent use of converter-based generators, disturbances in microgrids require special consideration. The disturbance problems in microgrids can be addressed by dynamic control. Dynamic control can be classified as transient disturbance control and dynamic disturbance control. Transient disturbance control damps disturbances in microgrids caused by forced or unintended sudden and severe voltage and current changes due to switching of large sources or loads, mode transfer or fault clearance, and characterized by large magnitude and phase change and with a time duration of milliseconds. Dynamic disturbance control regulates disturbances in microgrids caused by forced or unintended voltage and current changes due to generator and load variation, and characterized by magnitude and phase changes beyond the normal operating limits, and continuing for milliseconds to seconds.

The initial characteristics of faults are very similar to initial characteristics of transient and dynamic disturbances. Distinguishing the two types of incidents from each other is critical for the proper operation of microgrids. Thus, protection and dynamic control of microgrids are closely related and need to be coordinated with each other.

This part of IEC 62898 specifies requirements to address the above-mentioned protection and dynamic control issues in microgrids.

IEC TS 62898 (all parts) intends to provide general guidelines and technical requirements for microgrids.

- a) IEC TS 62898-1 mainly covers the following issues:
- determination of microgrid purposes and application;
 - preliminary study necessary for microgrid planning, including resource analysis, load forecast, DER planning and power system planning;
 - principles of microgrid technical requirements that should be specified during planning stage;
 - microgrid evaluation to select an optimal microgrid planning scheme.
- b) IEC TS 62898-2 mainly covers the following issues:
- operation requirements and control targets of microgrids under different operation modes;
 - basic control strategies and methods under different operation modes;
 - requirements of energy storage, monitoring and communication under different operation modes;
 - power quality.
- c) IEC TS 62898-3-1 mainly covers the following issues:
- requirements for microgrid protection;
 - protection systems for microgrids;
 - dynamic control for transient and dynamic disturbances in microgrids;

Microgrids can be stand-alone or a sub-system of an interconnected grid. The technical requirements in this Technical Specification are intended to be consistent with:

- 1) IEC 60364-7 (all parts and amendments related to low-voltage electrical installations);
- 2) IEC TS 62786, requirements for connection of generators intended to be operated in parallel with the grid;
- 3) IEC TS 62257 (all parts) with respect to rural electrification;
- 4) IEC TS 62749 with respect to power quality;
- 5) IEC TS 62898-1;
- 6) IEC TS 62898-2;
- 7) IEC TS 63268;

MICROGRIDS –

Part 3-1: Technical requirements – Protection and dynamic control

1 Scope

The purpose of this part of IEC 62898 is to provide guidelines for the specification of fault protection and dynamic control in microgrids. Protection and dynamic control in a microgrid are intended to ensure safe and stable operation of the microgrid under fault and disturbance conditions.

This document applies to AC microgrids comprising single or three-phase networks or both. It includes both isolated microgrids and non-isolated microgrids with a single point of connection (POC) to the upstream distribution network. It does not apply to microgrids with two or more points of connection to the upstream distribution network, although such systems can follow the guidelines given in this document. This document applies to microgrids operating at LV or MV or both. DC and hybrid AC/DC microgrids are excluded from the scope, due to the particular characteristics of DC systems (extremely large fault currents and the absence of naturally occurring current zero crossings).

This document defines the principles of protection and dynamic control for microgrids, general technical requirements, and specific technical requirements of fault protection and dynamic control. It addresses new challenges in microgrid protection requirements, transient disturbance control and dynamic disturbance control requirements for microgrids. It focuses on the differences between conventional power system protection and new possible solutions for microgrid protection functions.

Depending on specific situations, additional or stricter requirements can be defined by the microgrid operator in coordination with the distribution system operator (DSO).

This document does not cover protection and dynamic control of active distribution systems. This document does not cover product requirements for measuring relays and protection equipment.

This document does not cover safety aspects in low voltage electrical installations, which are covered by IEC 60364 (all parts and amendments related to low-voltage electrical installations). Requirements relating to low voltage microgrids can be found in IEC 60364-8-2.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60364 (all parts), *Low voltage electrical installations*



IEC TS 62898-3-1

Edition 1.1 2023-11
CONSOLIDATED VERSION

FINAL VERSION



**Microgrids –
Part 3-1: Technical requirements - Protection and dynamic control**



CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	8
2 Normative references	8
3 Terms and definitions	8
4 Microgrid protection requirements.....	15
4.1 General.....	15
4.2 Main requirements specific to microgrids	16
4.2.1 General	16
4.2.2 Phase fault protection	16
4.2.3 Earth fault protection	17
4.3 General protection requirements	17
4.3.1 General	17
4.3.2 Dependability of protection	17
4.3.3 Security of protection.....	18
4.3.4 Availability and selectivity of protection.....	18
4.3.5 Operating time (speed) of protection.....	19
4.4 Particular requirements for non-isolated microgrids.....	19
4.5 Particular requirements for isolated microgrids.....	20
5 Protection systems for microgrids	20
5.1 General.....	20
5.2 Short-circuit protection.....	21
5.2.1 Overcurrent protection	21
5.2.2 Directional overcurrent protection	23
5.2.3 Distance protection	24
5.2.4 Directional power protection	24
5.2.5 Differential protection	24
5.3 System protection	25
5.3.1 Under/over voltage protection.....	25
5.3.2 Frequency protection	26
5.4 Centralized protection systems	26
6 Dynamic stability and control	27
6.1 General.....	27
6.2 Dynamic stability in microgrids.....	27
6.2.1 General	27
6.2.2 Disturbances in microgrids.....	28
6.2.3 Voltage and frequency stability	28
6.3 Dynamic control in microgrids	29
6.3.1 General requirements	29
6.3.2 Dynamic control functions.....	29
6.3.3 Control elements in microgrids.....	30
6.3.4 Control systems of microgrids.....	31
6.3.5 Control of microgrids during grid-connected mode	35
6.3.6 Control of microgrids during island mode	35
Annex A (informative) Use cases for dynamic control of microgrids	36
Bibliography.....	40

Figure 1 – Ratio between maximum load current/minimum short-circuit current in the microgrid	22
Figure 2 – Control elements in microgrids	30
Figure 3 – Functional mapping for operation and control of microgrids	32
Figure 4 – Typical multilevel control of microgrids	32
Figure A.1 – Simple microgrid platform for testing transient disturbance during motor start-up	36
Figure A.2 – Transient control strategy based on reactive current compensation control	36
Figure A.3 – Voltage profile during field testing of transient disturbance with and without transient control device	37
Figure A.4 – Current profile during field testing of transient disturbance with and without transient control device	37
Figure A.5 – Microgrid platform with high proportion of RES for testing dynamic disturbance control	38
Figure A.6 – Dynamic control strategy	38
Figure A.7 – The voltage profile of field testing with and without dynamic control device	39

INTERNATIONAL ELECTROTECHNICAL COMMISSION

MICROGRIDS –

Part 3-1: Technical requirements – Protection and dynamic control

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendment has been prepared for user convenience.

IEC TS 62898-3-1 edition 1.1 contains the first edition (2020-09) [documents 8B/53/DTS and 8B/59/RVDTS] and its amendment 1 (2023-11) [documents 8B/174/DTS and 8B/199/RVDTS].

This Final version does not show where the technical content is modified by amendment 1. A separate Redline version with all changes highlighted is available in this publication.

The main task of IEC technical committees is to prepare International Standards. In exceptional circumstances, a technical committee may propose the publication of a Technical Specification when

- the required support cannot be obtained for the publication of an International Standard, despite repeated efforts, or
- the subject is still under technical development or where, for any other reason, there is the future but no immediate possibility of an agreement on an International Standard.

Technical Specifications are subject to review within three years of publication to decide whether they can be transformed into International Standards.

IEC TS 62898-3-1, which is a Technical Specification, has been prepared by IEC subcommittee 8B: Decentralized Electrical Energy Systems of IEC technical committee 8: System aspects of electrical energy supply.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 62898 series, published under the general title *Microgrids*, can be found on the IEC website.

The committee has decided that the contents of this document and its amendment will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The '*colour inside*' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

Microgrids can serve different purposes depending on the primary objectives of their applications. They are usually seen as a means to manage reliability of supply in a grid contingency and to facilitate local optimization of energy supply by controlling distributed energy resources (DER). Microgrids also present a way to provide electricity supply in remote areas, to use renewable energy as a systematic approach for rural electrification and to increase resiliency and security of supply to end users.

Deployment of DER can cause a microgrid or distribution system of a grid to face several challenges, including fault protection and dynamic control issues. There are, however, some issues commonly faced in the protection and control of microgrids which are less prevalent in large grids. These issues include: bidirectional flow of power resulting in voltage excursions outside acceptable limits, fault current being supplied from multiple sources, loss of synchronism between multiple sources when a fault occurs, potentially limited fault current magnitude, lower inertia or lower primary time constant, regular changes in operational configuration due to economic optimization, and intermittency of source-dependent renewable distributed generators. These issues worsen when the microgrid contains several converter-based generators (CBGs) and operates in island mode. As such, conventional protection and control strategies may not be suitable or sufficient for microgrids. Protection systems different from the conventional ones may be required. In some instances, protection systems may need to be adjusted dynamically based on the operating state of the microgrid.

Conventional power systems have predominantly consisted of power sources, such as fossil fuel-fired thermal power plants, hydro power plants and nuclear power plants, which are relatively stable and easy to control. On the other hand, microgrids often contain many different types of sources, many of which are intermittent. Hence, protection and dynamic control in microgrids need to be more sophisticated than in conventional power systems. However, the main grid contributes to the fault currents in the grid-connected mode of operation and hence the fault currents are large enough to actuate conventional protection devices. Though it is possible to employ conventional protection principles and existing standards for the protection of microgrids operating in grid-connected mode, the existing protection settings should be systematically assessed as the existence of DER may compromise the coordination of the protection system.

Due to the specific characteristics of microgrids and their frequent use of converter-based generators, disturbances in microgrids require special consideration. The disturbance problems in microgrids can be addressed by dynamic control. Dynamic control can be classified as transient disturbance control and dynamic disturbance control. Transient disturbance control damps disturbances in microgrids caused by forced or unintended sudden and severe voltage and current changes due to switching of large sources or loads, mode transfer or fault clearance, and characterized by large magnitude and phase change and with a time duration of milliseconds. Dynamic disturbance control regulates disturbances in microgrids caused by forced or unintended voltage and current changes due to generator and load variation, and characterized by magnitude and phase changes beyond the normal operating limits, and continuing for milliseconds to seconds.

The initial characteristics of faults are very similar to initial characteristics of transient and dynamic disturbances. Distinguishing the two types of incidents from each other is critical for the proper operation of microgrids. Thus, protection and dynamic control of microgrids are closely related and need to be coordinated with each other.

This part of IEC 62898 specifies requirements to address the above-mentioned protection and dynamic control issues in microgrids.

IEC TS 62898 (all parts) intends to provide general guidelines and technical requirements for microgrids.

- a) IEC TS 62898-1 mainly covers the following issues:
- determination of microgrid purposes and application;
 - preliminary study necessary for microgrid planning, including resource analysis, load forecast, DER planning and power system planning;
 - principles of microgrid technical requirements that should be specified during planning stage;
 - microgrid evaluation to select an optimal microgrid planning scheme.
- b) IEC TS 62898-2 mainly covers the following issues:
- operation requirements and control targets of microgrids under different operation modes;
 - basic control strategies and methods under different operation modes;
 - requirements of energy storage, monitoring and communication under different operation modes;
 - power quality.
- c) IEC TS 62898-3-1 mainly covers the following issues:
- requirements for microgrid protection;
 - protection systems for microgrids;
 - dynamic control for transient and dynamic disturbances in microgrids;

Microgrids can be stand-alone or a sub-system of an interconnected grid. The technical requirements in this Technical Specification are intended to be consistent with:

- 1) IEC 60364-7 (all parts and amendments related to low-voltage electrical installations);
- 2) IEC TS 62786, requirements for connection of generators intended to be operated in parallel with the grid;
- 3) IEC TS 62257 (all parts) with respect to rural electrification;
- 4) IEC TS 62749 with respect to power quality;
- 5) IEC TS 62898-1;
- 6) IEC TS 62898-2;
- 7) IEC TS 63268;

MICROGRIDS –

Part 3-1: Technical requirements – Protection and dynamic control

1 Scope

The purpose of this part of IEC 62898 is to provide guidelines for the specification of fault protection and dynamic control in microgrids. Protection and dynamic control in a microgrid are intended to ensure safe and stable operation of the microgrid under fault and disturbance conditions.

This document applies to AC microgrids comprising single or three-phase networks or both. It includes both isolated microgrids and non-isolated microgrids with a single point of connection (POC) to the upstream distribution network. It does not apply to microgrids with two or more points of connection to the upstream distribution network, although such systems can follow the guidelines given in this document. This document applies to microgrids operating at LV or MV or both. DC and hybrid AC/DC microgrids are excluded from the scope, due to the particular characteristics of DC systems (extremely large fault currents and the absence of naturally occurring current zero crossings).

This document defines the principles of protection and dynamic control for microgrids, general technical requirements, and specific technical requirements of fault protection and dynamic control. It addresses new challenges in microgrid protection requirements, transient disturbance control and dynamic disturbance control requirements for microgrids. It focuses on the differences between conventional power system protection and new possible solutions for microgrid protection functions.

Depending on specific situations, additional or stricter requirements can be defined by the microgrid operator in coordination with the distribution system operator (DSO).

This document does not cover protection and dynamic control of active distribution systems. This document does not cover product requirements for measuring relays and protection equipment.

This document does not cover safety aspects in low voltage electrical installations, which are covered by IEC 60364 (all parts and amendments related to low-voltage electrical installations). Requirements relating to low voltage microgrids can be found in IEC 60364-8-2.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60364 (all parts), *Low voltage electrical installations*