

# TECHNICAL SPECIFICATION



---

**High voltage direct current (HVDC) grid systems and connected converter stations – Guideline and parameter lists for functional specifications – Part 2: Parameter lists**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

---

ICS 29.200; 29.240.01

ISBN 978-2-8322-7572-6

**Warning! Make sure that you obtained this publication from an authorized distributor.**

## CONTENTS

FOREWORD.....	9
INTRODUCTION.....	11
1 Scope.....	12
2 Normative references .....	12
3 Terms, definitions and abbreviated terms .....	13
3.1 Terms and definitions.....	13
3.2 Abbreviated terms.....	17
4 Coordination of HVDC grid and AC systems .....	18
4.1 About HVDC grids.....	18
4.2 HVDC grid structure.....	18
4.3 Purpose of the HVDC grid and power network diagram .....	18
4.4 AC/DC power flow optimisation .....	19
4.5 Converter operational functions .....	21
4.5.1 Basic operation functions – Converter normal operation state.....	21
4.5.2 Basic operation functions – Converter abnormal operation state .....	22
4.5.3 Ancillary services.....	24
5 HVDC grid characteristics.....	28
5.1 HVDC circuit topologies .....	28
5.1.1 Availability and reliability .....	28
5.1.2 Basic characteristics and nomenclature .....	28
5.1.3 Attributes of HVDC grids or HVDC grid subsystems.....	29
5.1.4 Attributes of an HVDC station .....	29
5.2 Connection modes .....	30
5.3 Grid operating states .....	30
5.3.1 General .....	30
5.3.2 Normal state .....	30
5.3.3 Alert state.....	30
5.3.4 Emergency state.....	30
5.3.5 Blackout state.....	30
5.3.6 Restoration.....	30
5.4 DC voltages .....	31
5.4.1 General .....	31
5.4.2 Nominal DC system voltage .....	32
5.4.3 Steady-state DC pole voltage .....	32
5.4.4 Temporary DC pole voltage .....	32
5.4.5 DC neutral bus voltage .....	33
5.5 Insulation coordination .....	35
5.6 Short-circuit characteristics.....	35
5.6.1 Calculation of short-circuit currents in HVDC grids.....	35
5.6.2 Short-circuit current design requirements .....	37
5.7 Steady-state voltage and current distortions .....	37
5.7.1 Emissions and impacts .....	37
5.7.2 Rights and obligations of a connectee .....	39
5.7.3 Similarities between HVDC grids and AC networks .....	39
5.7.4 Voltage and current distortion limits .....	39
5.7.5 Allocation of limits to individual connectees .....	39

5.7.6	Frequency-dependent DC system impedance .....	39
5.8	DC system restoration.....	39
5.8.1	General .....	39
5.8.2	Post-DC fault recovery.....	40
5.8.3	Restoration from blackout.....	40
6	HVDC grid control.....	40
6.1	Closed-loop control functions .....	40
6.1.1	General .....	40
6.1.2	Core control functions.....	40
6.1.3	Coordinating control functions .....	40
6.2	Controller hierarchy .....	40
6.2.1	General .....	40
6.2.2	Internal converter control.....	40
6.2.3	DC node voltage control .....	40
6.2.4	Coordinated HVDC grid control.....	41
6.2.5	AC/DC grid control.....	44
6.3	Propagation of information .....	44
6.4	Open-loop controls.....	48
6.4.1	Coordination of connection modes between HVDC stations and their PoC-DC .....	48
6.4.2	Operating sequences for HVDC grid installations.....	48
6.4.3	Post-DC fault recovery.....	49
7	HVDC grid protection.....	49
7.1	General.....	49
7.2	DC fault separation .....	49
7.3	Protection system related installations and equipment .....	50
7.3.1	AC/DC converter station .....	50
7.3.2	HVDC grid topology and equipment .....	50
7.4	HVDC grid protection zones .....	50
7.4.1	General .....	50
7.4.2	Permanent stop P.....	53
7.4.3	Permanent stop PQ .....	54
7.4.4	Temporary stop P .....	54
7.4.5	Temporary stop PQ .....	54
7.4.6	Continued operation .....	54
7.4.7	Example of a protection zone matrix .....	54
7.5	DC protection.....	55
7.5.1	General .....	55
7.5.2	DC converter protections .....	55
7.5.3	HVDC grid protections .....	55
7.5.4	HVDC grid protection communication.....	55
8	AC/DC converter stations .....	55
8.1	Purpose .....	55
8.2	AC/DC converter station types .....	55
8.3	Overall requirements.....	55
8.3.1	Robustness of AC/DC converter stations .....	55
8.3.2	Availability and reliability .....	56
8.3.3	Active power reversal .....	56

8.4	Main circuit design .....	56
8.4.1	General characteristics .....	56
8.4.2	DC side .....	57
8.4.3	AC side.....	62
8.5	HVDC grid control and protection interface .....	62
8.6	Controls .....	63
8.6.1	General .....	63
8.6.2	Automated vs manual operation.....	63
8.6.3	Control modes and support of coordination .....	63
8.6.4	Limitation strategies .....	64
8.6.5	Operating sequences for AC/DC converter station .....	65
8.6.6	Dynamic behaviour .....	65
8.7	Protection .....	66
8.7.1	General .....	66
8.7.2	Configuration requirements.....	66
8.7.3	Function requirements .....	66
8.7.4	Fault separation strategy for faults inside the AC/DC converter station .....	66
8.7.5	Coordination of the DC protection with the HVDC grid .....	66
8.7.6	Example for coordination of the DC protection with the HVDC grid .....	66
9	HVDC grid installations.....	66
9.1	General.....	66
9.2	DC switching station .....	66
9.2.1	Purpose .....	66
9.2.2	Overall requirements .....	67
9.2.3	Main circuit design.....	67
9.2.4	HVDC grid control and protection interface .....	74
9.2.5	Controls.....	75
9.2.6	Protection.....	78
9.3	HVDC transmission lines.....	79
9.3.1	Purpose.....	79
9.3.2	Overall requirements .....	79
9.3.3	Main circuit design.....	80
9.3.4	HVDC grid control and protection interface .....	82
9.3.5	Controls.....	83
9.3.6	Protection.....	83
9.4	DC/DC converter stations .....	83
10	Studies and associated models .....	84
10.1	General.....	84
10.2	Description of studies .....	84
10.2.1	General .....	84
10.2.2	HVDC grid planning studies .....	84
10.2.3	HVDC grid design studies.....	84
10.2.4	HVDC grid extension studies .....	84
10.2.5	Studies for HVDC grid installation refurbishments and other modifications .....	84
10.3	Models and interfaces.....	84
10.3.1	General .....	84
10.3.2	Model interfaces and integration compatibility.....	85
10.3.3	Model capability.....	85

10.3.4	Model format .....	85
10.3.5	Model maintenance and portability .....	86
10.3.6	Model aggregation .....	86
10.3.7	Model testing and validation .....	86
11	Testing .....	87
11.1	General .....	87
11.2	Off-site testing .....	88
11.2.1	General .....	88
11.2.2	Factory system tests .....	88
11.3	On-site testing .....	88
	Bibliography .....	89
Figure 1	– Definition of the point of connection-AC and the point of connection-DC at an AC/DC converter station .....	14
Figure 2	– Rigid bipolar HVDC system .....	16
Figure 3	– Generic AC over- and undervoltage ride through profile of an AC/DC converter station: Different values can be specified for symmetrical and asymmetrical faults .....	24
Figure 4	– Temporary DC pole to earth voltage profiles at a PoC-DC .....	31
Figure 5	– Generic neutral bus voltage profile at a PoC-DC .....	34
Figure 6	– Standard approximation function .....	37
Figure 7	– Typical DC node voltage control modes (illustration in DC voltage/power plane) .....	41
Figure 8	– Generation of final converter schedules including converter control modes and its parameters .....	45
Figure 9	– Propagation of switching commands to individual HVDC stations .....	46
Figure 10	– Operating sequences as transitions between operating states .....	48
Figure 11	– Example voltage and current traces in the event of "permanent stop" .....	51
Figure 12	– Example voltage and current traces in the event of "temporary stop P" .....	52
Figure 13	– Example voltage and current traces in the event of "continued operation" .....	53
Table 1	– Nomenclature of HVDC circuit topologies .....	19
Table 2	– Active and reactive power characteristics for a given AC system voltage operating range of an AC/DC converter station .....	19
Table 3	– Parameters of an HVDC transmission line .....	21
Table 4	– Parameter list for AC system frequency following a frequency / power droop operation of an AC/DC converter station .....	21
Table 5	– Parameter list for DC voltage / DC power droop operation of an AC/DC converter station .....	22
Table 6	– Parameters describing the operation conditions of the AC network at an AC/DC converter station prior to and after a fault .....	22
Table 7	– Time requirements for power restoration in the event of temporary faults .....	23
Table 8	– AC undervoltage ride through requirements for an AC/DC converter station .....	23
Table 9	– AC overvoltage ride through requirements for an AC/DC converter station .....	24
Table 10	– Coordination of power associated with primary frequency control .....	25
Table 11	– FCR parameters for an AC/DC converter station, parameters for active power frequency response in FSM .....	26

Table 12 – Voltage range capability parameters for an AC/DC converter station .....	27
Table 13 – Reactive power capability parameters for an AC/DC converter station .....	27
Table 14 – Parameters describing electromechanical oscillations .....	27
Table 15 – Parameters describing post-fault active power recovery at an AC/DC converter station .....	28
Table 16 – Characteristics of the HVDC grid .....	28
Table 17 – DC circuit earthing parameters .....	29
Table 18 – Parameters for each return path .....	30
Table 19 – Nominal DC system voltage at a PoC-DC .....	32
Table 20 – DC pole voltage range parameters at a PoC-DC of an HVDC station – Steady-state .....	32
Table 21 – DC pole voltage range parameters at a PoC-DC of an HVDC station – Temporary undervoltages .....	32
Table 22 – DC pole voltage range parameters at a PoC-DC of an HVDC station – Temporary overvoltages .....	33
Table 23 – DC neutral bus voltage range parameters.....	34
Table 24 – Insulation levels at a PoC-DC.....	35
Table 25 – Maximum converter current of an HVDC station into the HVDC grid .....	35
Table 26 – Component data – Earthing branch .....	36
Table 27 – Component data – Standalone DC capacitors and DC filters of an HVDC station .....	36
Table 28 – Component data – DC line reactors of an HVDC station .....	36
Table 29 – Component data – DC lines (OHL, cable including electrode lines) <sup>a</sup> .....	36
Table 30 – Short-circuit current parameters at a PoC-DC.....	37
Table 31 – Equivalent impedances for calculating voltage and current distortions at a PoC-DC .....	38
Table 32 – Pre-existing DC voltage and current distortions at a PoC-DC.....	38
Table 33 – Planning levels and permissible DC voltage and current distortions at a PoC-DC .....	38
Table 34 – Coupling factors for calculating voltage distortions at a remote bus caused by emissions at a PoC-DC .....	39
Table 35 – Specification of DC system impedance .....	39
Table 36 – DC node voltage control parameters.....	41
Table 37 – System state variables and equipment status signals (interface list) .....	42
Table 38 – General interface (signal list) for autonomous adaption control rules .....	42
Table 39 – General interface (signal list) for defining an observation .....	43
Table 40 – General interface (signal list) for defining countermeasures of rules .....	43
Table 41 – Interface parameters required from the HVDC grid control layer .....	44
Table 42 – General interface (signal list) for orders from TSOs .....	44
Table 43 – General interface (signal list) defining a "converter schedule" .....	45
Table 44 – General interface (signal list) defining "switching commands" .....	46
Table 45 – General signal interface (physical quantities) of the "station information" .....	47
Table 46 – General signal interface (control parameters) of the "station information" .....	48
Table 47 – Unified description of operating sequences .....	49
Table 48 – Parameters for recovery sequences after DC line faults .....	49

Table 49 – Example of an HVDC grid protection zone matrix .....	50
Table 50 – DC protection parameter list .....	50
Table 51 – DC converter protection parameter list .....	55
Table 52 – Converter station topology .....	56
Table 53 – Energy dissipation/absorption capability at a PoC .....	57
Table 54 – DC connection modes of the AC/DC converter station .....	58
Table 55 – DC circuit re-configuration time requirements .....	58
Table 56 – Repetition of DC fault events and recovery attempts .....	59
Table 57 – DC circuit energisation .....	60
Table 58 – Connecting the AC/DC converter station .....	60
Table 59 – Disconnecting the AC/DC converter station .....	60
Table 60 – DC circuit de-energisation .....	61
Table 61 – Parameters for the automatic control interface of the AC/DC converter station according to standard protocols .....	63
Table 62 – Parameters for the automatic control interface of the AC/DC converter station according to proprietary protocols .....	63
Table 63 – Parameters for the available control modes of the AC/DC converter station .....	64
Table 64 – Limitation strategies .....	65
Table 65 – Operating states and transitions for the AC/DC converter station .....	65
Table 66 – Protection coordination of the AC/DC converter station and the HVDC grid (for main and backup concept including the separation concept and the FSD) .....	66
Table 67 – DC switching station topology .....	67
Table 68 – Temporary energy dissipation/absorption capability of the DC switching station .....	68
Table 69 – Power flow controlling capability of a DC SU .....	68
Table 70 – DC connection modes of a DC SU for PoC-DCx .....	69
Table 71 – DC circuit re-configuration time requirements .....	69
Table 72 – Repetition of DC fault events and recovery attempts .....	71
Table 73 – DC circuit energisation .....	72
Table 75 – Disconnecting the DC switching station .....	72
Table 76 – DC circuit de-energisation .....	73
Table 77 – Parameters for the automatic control interface of the DC switching station according to standard protocols .....	75
Table 78 – Parameters for the automatic control interface of the DC switching station according to proprietary protocols .....	75
Table 79 – Parameters for the available control modes of the DC switching station .....	76
Table 80 – Limitation strategies .....	77
Table 81 – Operating states and transitions for a SU of the DC switching station .....	78
Table 82 – Protection coordination of the DC switching station and the HVDC grid (for main and backup concept including the separation concept and the FSD) .....	79
Table 83 – DC line power transmission parameters for the transmission line including all different HVDC transmission line sections, if any .....	80
Table 84 – Frequency range for specification of DC system impedance .....	82
Table 85 – Parameters defining the model generalities .....	84

Table 86 – Parameters to characterize the model capability.....	85
Table 87 – Parameters to define the model format.....	85
Table 88 – Parameters defining the model aggregation.....	86
Table 89 – Parameters defining the model validation .....	86
Table 90 – Parameters for testing .....	87
Table 91 – Minimum set of parameters to be defined for all test scenarios.....	87



## INTERNATIONAL ELECTROTECHNICAL COMMISSION

## HIGH VOLTAGE DIRECT CURRENT (HVDC) GRID SYSTEMS AND CONNECTED CONVERTER STATIONS – GUIDELINE AND PARAMETER LISTS FOR FUNCTIONAL SPECIFICATIONS –

### Part 2: Parameter lists

#### FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC TS 63291-2 has been prepared by IEC technical committee TC 115: High Voltage Direct Current (HVDC) transmission for DC voltages above 100 kV. It is a Technical Specification.

The text of this Technical Specification is based on the following documents:

Draft	Report on voting
115/320/DTS	115/329/RVDTS

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Technical Specification is English.

This Technical Specification is to be used in conjunction with IEC TS 63291-1:2023.

A list of all parts in the IEC 63291 series, published under the general title *High voltage direct current (HVDC) grid systems and connected converter stations – Guideline and parameter lists for functional specifications*, can be found on the IEC website.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at [www.iec.ch/members\\_experts/refdocs](http://www.iec.ch/members_experts/refdocs). The main document types developed by IEC are described in greater detail at [www.iec.ch/publications](http://www.iec.ch/publications).

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under [webstore.iec.ch](http://webstore.iec.ch) in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

**IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.**

## INTRODUCTION

In the preparation of this document, special care has been taken to as far as possible describe the requirements in a technologically independent way. In order to achieve that, a function of interest is described by a comprehensive set of parameters. The parameters are selected based on a systematic analysis of physical phenomena relevant to achieve the requested functionality.

Reflecting the early stage of technology, the technical parameters need comprehensive explanations and background information. This need is reflected in the dual character of the content, which is presented in the two corresponding parts:

- IEC TS 63291-1, Guideline containing the explanations and the background information in context with the parameter lists;
- IEC TS 63291-2, Parameter lists containing the essential lists of parameters and values describing properties of the AC as well as the DC system (operating conditions) and parameters describing the performance of the newly installed component (performance requirements).

IEC TS 63291-1 and IEC TS 63291-2 have the same structure to aid the reader.

At the time of writing there is no real-life multi-national, multi-vendor HVDC grid project to which the guideline and parameter lists can be applied. Practical experiences in the near future are expected to provide input for developing these guideline and parameter lists further.

# HIGH VOLTAGE DIRECT CURRENT (HVDC) GRID SYSTEMS AND CONNECTED CONVERTER STATIONS – GUIDELINE AND PARAMETER LISTS FOR FUNCTIONAL SPECIFICATIONS –

## Part 2: Parameter lists

### 1 Scope

This document defines aspects on planning, specification, and execution of multi-vendor HVDC grid systems also referred to as HVDC grids. The terms "HVDC grid systems" or "HVDC grids" are used in this document to describe HVDC systems for power transmission having more than two HVDC stations connected to a common DC circuit. The DC circuit can be of radial or meshed topology or a combination thereof. In this document, the term "HVDC grids" is used.

While this document focuses on requirements specific for HVDC grids, some requirements are considered applicable to all HVDC systems in general, i.e., including point-to-point HVDC systems. Existing IEC (e.g., IEC TR 63363-1 [1]), Cigre or other relevant documents have been used for reference as far as possible.

Corresponding to electric power transmission applications, this document is applicable to high voltage systems, i.e., those having typically nominal DC voltages higher than 50 kV with respect to earth are considered in this document.

NOTE While the physical principles of DC networks are basically voltage independent, the technical options for designing equipment get much wider with lower DC voltage levels, e.g. in the case of converters or switchgear.

This document covers technical aspects of:

- coordination of HVDC grid and AC systems,
- HVDC grid characteristics,
- HVDC grid control,
- HVDC grid protection,
- AC/DC converter stations,
- HVDC grid installations, including DC switching stations and HVDC transmission lines,
- studies and associated models,
- testing.

Beyond the scope of this document, the following content is proposed for future work:

- DC/DC converter stations.

### 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 62747:2014, *Terminology for voltage-sourced converters (VSC) for high-voltage direct current (HVDC) systems*  
IEC 62747:2014/AMD1:2019

IEC TS 63291-1:2023, *High voltage direct current (HVDC) grid systems and connected converter stations – Guideline and parameter lists for functional specifications – Part 1: Guideline*