

INTERNATIONAL
STANDARD

ISO/IEC
11518-1

First edition
1995-06-01

**Information technology —
High-Performance Parallel Interface —**

Part 1:

Mechanical, electrical and signalling protocol
specification (HIPPI-PH)

*Technologies de l'information — Interface parallèle à haute
performance —*

*Partie 1: Spécification du protocole mécanique, électrique et de
signalisation (HIPPI-PH)*



Reference number
ISO/IEC 11518-1:1995(E)

Contents	Page
Foreword	v
Introduction	vi
1 Scope	1
2 Definitions, editorial conventions, and abbreviations	1
3 HIPPI structure	2
3.1 Configuration characteristics	2
3.2 Logical framing hierarchy	2
4 Service interface	2
4.1 Service primitives	2
4.2 Sequences of primitives	3
4.3 Service primitives summary	3
4.4 Operational sequences	3
4.5 Initiate connection service primitives	4
4.6 Complete the connection service primitives	4
4.7 Flow control service primitives	5
4.8 Packet service primitives	6
4.9 Data transfer service primitives	7
4.10 Hangup service primitives	7
4.11 Control service primitives	8
4.12 Status service primitives	9
5 Interface format and signals	10
5.1 Physical framing hierarchy	10
5.2 Data rate options	11
5.3 Usage of signals	11
5.4 Error detection	13
6 State transitions	14
6.1 State exit	14
6.2 Interlocks	14
6.3 Source READY pseudo-code	14
6.4 Destination READY pseudo-code	14
6.5 Source pseudo-code	15
6.6 Destination pseudo-code	18
7 Timing	21
7.1 Source CLOCK signal	21
7.2 Destination CLOCK signal	22
7.3 DATA BUS and PARITY BUS timing	22
7.4 Source control signals	22
7.5 I-Field information	22
7.6 LLRC	22
7.7 Destination control signals	22
7.8 Source wait gaps	22
7.9 Destination wait gaps	22
8 Physical characteristics	23
8.1 Differential circuit characteristics	23
8.2 INTERCONNECT signal characteristics	24
8.3 Ground signals	24
8.4 Reserved signals	24
8.5 Cable specifications	24
8.6 Cable grounding	25
8.7 Connector specifications	25
8.8 Connector pin assignments	25

© ISO/IEC 1995

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

ISO/IEC Copyright Office • Case postale 56 • CH-1211 Genève 20 • Switzerland
 Printed in Switzerland

Annex A	Waveform examples	29
A.1	Introduction	29
A.2	Connection and start packet.....	29
A.3	End burst, start burst.....	30
A.4	End burst, end packet, start packet, start burst	31
A.5	End burst, end packet, disconnect	31
A.6	Illegal end termination	32
A.7	Rejected connection sequence.....	32
A.8	Aborted connection sequence	33
Annex B	Implementation suggestions	34
B.1	Data rate option control	34
B.2	Source READY counter	34
B.3	I-Field sampling.....	34
B.4	Short bursts.....	34
B.5	Switching and the I-Field	35
B.6	Byte ordering.....	35
Annex C	Error checking	36
C.1	Byte parity.....	36
C.2	LLRC	36
C.3	Burst length check	36
C.4	Sample LLRC circuit.....	36
Annex D	Propagation delay calculation example	38
D.1	CLOCK.....	38
D.2	Loading data	38
D.3	Cable skew	38
D.4	Setup time	38
D.5	Hold time	38
D.6	Tuning delay.....	38
Annex E	Component options	40
E.1	Cable availability and colour coding.....	40
E.2	Cable lengths	40
E.3	Connector alignment guide.....	40
E.4	Maximum connector footprint.....	40
E.5	Connector availability.....	40
E.6	Connector jackscrew torque.....	40
E.7	Line driver and receiver availability	40
	Alphabetical index.....	43

Tables

Table 1	Data rate options.....	11
Table 2	Connector pin assignments.....	26
Table B.1	Byte assignments.....	35
Table E.1	Connector wire assignments.....	41

Figures

Figure 1	Control hierarchy.....	vi
Figure 2	Logical framing hierarchy.....	2
Figure 3	HIPPI-PH service interface.....	2
Figure 4	Initiate the connection service primitives.....	4
Figure 5	Complete the connection service primitives.....	4
Figure 6	Flow control service primitives.....	5
Figure 7	Packet service primitives.....	6
Figure 8	Data transfer service primitives.....	7
Figure 9	Hangup service primitives.....	7
Figure 10	Control service primitives.....	8
Figure 11	Status service primitives.....	9
Figure 12	Physical framing hierarchy.....	10
Figure 13	Interface signal summary.....	10
Figure 14	Data packing.....	12
Figure 15	Source READY flow diagram.....	14
Figure 16	Destination READY flow diagram.....	14
Figure 17	Source flow diagram.....	16
Figure 18	Destination flow diagram.....	19
Figure 19	Source driven signals at the Source.....	21
Figure 20	Source driven signals at the Destination.....	21
Figure 21	Differential circuit.....	23
Figure 22	INTERCONNECT circuit.....	24
Figure 23	Cable connector – tabs.....	27
Figure 24	Bulkhead connector – receptacle.....	28
Figure A.1	Typical HIPPI-PH waveforms.....	29
Figure A.2	Connect, start packet, start burst.....	30
Figure A.3	End burst, start burst.....	30
Figure A.4	End burst, end packet, start packet, start burst.....	31
Figure A.5	End burst, end packet, disconnect.....	31
Figure A.6	Illegal end termination.....	32
Figure A.7	Rejected connection sequence.....	32
Figure A.8	Aborted connection sequence.....	33
Figure B.1	Physical layer switching.....	35
Figure B.2	Switching with intermediate nodes.....	35
Figure B.3	Ordered byte stream mapping.....	35
Figure B.4	Bit significance within byte 0.....	35
Figure C.1	Parity and LLRC example.....	37
Figure C.2	Representative LLRC circuit.....	37
Figure D.1	Propagation delay example block diagram.....	39
Figure E.1	Connector alignment guide.....	42
Figure E.2	Maximum connector footprint.....	42

Foreword

ISO (the International Organization for Standardization) and IEC (the International Electrotechnical Commission) form the specialized system for worldwide standardization. National bodies that are members of ISO or IEC participate in the development of International Standards through technical committees established by the respective organization to deal with particular fields of technical activity. ISO and IEC technical committees collaborate in fields of mutual interest. Other international organizations, governmental and non-governmental, in liaison with ISO and IEC, also take part in the work.

In the field of information technology, ISO and IEC have established a joint technical committee, ISO/IEC JTC 1. Draft International Standards adopted by the joint technical committee are circulated to national bodies for voting. Publication as an International Standard requires approval by at least 75 % of the national bodies casting a vote.

International Standard ISO/IEC 11518-1 was prepared by Joint Technical Committee ISO/IEC JTC 1, *Information technology*, Subcommittee SC 25, *Interconnection of information technology equipment*.

ISO/IEC 11518 consists of the following parts, under the general title *Information technology — High-Performance Parallel Interface*:

- *Part 1: Mechanical, electrical and signalling protocol specification (HIPPI-PH)*
- *Part 2: Framing Protocol (HIPPI-FP)*
- *Part 3: Encapsulation of ISO 8802-3 — Logical link control protocol data units (HIPPI-LE)*
- *Part 4: Mapping of HIPPI to IPI device generic command sets (HIPPI-IPI)*
- *Part 5: Memory Interface (HIPPI-MI)*
- *Part 6: Physical Switch Control (HIPPI-SC)*

Annexes A to E of this part of ISO/IEC 11518 are for information only.

Introduction

This part of ISO/IEC 11518 defines the physical layer of an efficient simplex high-performance point-to-point interface operating at speeds of 800 or 1 600 Mbit/s. The -PH abbreviation stands for "physical layer".

Characteristics of this HIPPI physical layer interface include

- point-to-point connections use one or two copper twisted-pair cables for distances of up to 25 m.
- the HIPPI-PH is a simplex interface, capable of transferring data in one direction only. Two HIPPI-PHs may be used to implement a full-duplex interface.
- data transfers are performed and flow controlled in increments of bursts, each burst normally containing 256 words.
- signalling and control sequences are kept simple, and a look-ahead flow control is used, to allow average transfer rates for large file transfers to approach the peak transfer rate, even over distances longer than specified for the HIPPI-PH cables.
- the HIPPI-PH provides support for low-latency, real-time, and variable size packet transfers.
- the HIPPI-PH is designed to facilitate use in a circuit-switched environment. In support of this feature, a limited information field is available for subdevice addressing or other nonspecified control functions during the connection phase of operation. One round-trip cable delay is required to establish or terminate a connection.
- the HIPPI-PH is also designed to transmit multiple packets after a connection has been established. No round-trip cable delays are required between packets.

Figure 1 shows the interrelationship of the different clauses of this part of ISO/IEC 11518. The upper-layer protocols and station management protocols are not covered in this part of ISO/IEC 11518.




Figure 1 – Control hierarchy

Information technology – High-Performance Parallel Interface –

Part 1: Mechanical, electrical, and signalling protocol specification (HIPPI-PH)

1 Scope

This part of ISO/IEC 11518 provides the mechanical, electrical and signalling protocol specifications for an efficient simplex high-performance point-to-point interface between pieces of data-processing equipment.

The interface described in this part of ISO/IEC 11518 can be operated at peak data rates of 800 or 1 600 Mbit/s, over distances of up to 25 m by means of copper cabling. A distance-independent signalling protocol allows the average data rates to approach the peak data rates, even over distances longer than specified for the HIPPI-PH.

The purpose of this part of ISO/IEC 11518 is to facilitate the development and use of computer systems by providing a common interface at the physical and data framing layers. It provides an efficient interconnection between computers, high-performance display systems, and high-performance, intelligent block-transfer peripherals. The interface is optimized for large block transfers.