



ISO/IEC 29341-6-2

Edition 1.0 2008-11

# INTERNATIONAL STANDARD

**Information technology – UPnP Device Architecture –  
Part 6-2: Heating, Ventilation and Air Conditioning Device Control Protocol –  
Zone Thermostat Device**



**THIS PUBLICATION IS COPYRIGHT PROTECTED**  
**Copyright © 2008 ISO/IEC, Geneva, Switzerland**

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about ISO/IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office  
3, rue de Varembe  
CH-1211 Geneva 20  
Switzerland  
Email: [inmail@iec.ch](mailto:inmail@iec.ch)  
Web: [www.iec.ch](http://www.iec.ch)

## **About the IEC**

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

## **About IEC publications**

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: [www.iec.ch/searchpub](http://www.iec.ch/searchpub)

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: [www.iec.ch/online\\_news/justpub](http://www.iec.ch/online_news/justpub)

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: [www.electropedia.org](http://www.electropedia.org)

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: [www.iec.ch/webstore/custserv](http://www.iec.ch/webstore/custserv)

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: [csc@iec.ch](mailto:csc@iec.ch)  
Tel.: +41 22 919 02 11  
Fax: +41 22 919 03 00



ISO/IEC 29341-6-2

Edition 1.0 2008-11

# INTERNATIONAL STANDARD

---

**Information technology – UPnP Device Architecture –  
Part 6-2: Heating, Ventilation and Air Conditioning Device Control Protocol –  
Zone Thermostat Device**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

PRICE CODE

**C**

ICS 35.200

ISBN 2-8318-1007-6

## CONTENTS

FOREWORD .....	3
ORIGINAL UPNP DOCUMENTS (informative) .....	5
<b>1. Overview and Scope .....</b>	<b>7</b>
<b>2. Device Definitions .....</b>	<b>8</b>
2.1. Device Type .....	8
2.2. Device Model.....	8
2.2.1. Description of Device Requirements .....	8
2.2.2. Relationships Between Services.....	9
2.3. Theory of Operation .....	9
<b>3. XML Device Description .....</b>	<b>10</b>
<b>4. Test .....</b>	<b>12</b>

## LIST OF TABLES

Table 1: Device Requirements .....	8
------------------------------------	---

## **INFORMATION TECHNOLOGY – UPNP DEVICE ARCHITECTURE –**

### **Part 6-2: Heating, Ventilation and Air Conditioning Device Control Protocol – Zone Thermostat Device**

#### **FOREWORD**

- 1) ISO (International Organization for Standardization) and IEC (International Electrotechnical Commission) form the specialized system for worldwide standardization. National bodies that are members of ISO or IEC participate in the development of International Standards. Their preparation is entrusted to technical committees; any ISO and IEC member body interested in the subject dealt with may participate in this preparatory work. International governmental and non-governmental organizations liaising with ISO and IEC also participate in this preparation.
- 2) In the field of information technology, ISO and IEC have established a joint technical committee, ISO/IEC JTC 1. Draft International Standards adopted by the joint technical committee are circulated to national bodies for voting. Publication as an International Standard requires approval by at least 75 % of the national bodies casting a vote.
- 3) The formal decisions or agreements of IEC and ISO on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC and ISO member bodies.
- 4) IEC, ISO and ISO/IEC publications have the form of recommendations for international use and are accepted by IEC and ISO member bodies in that sense. While all reasonable efforts are made to ensure that the technical content of IEC, ISO and ISO/IEC publications is accurate, IEC or ISO cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 5) In order to promote international uniformity, IEC and ISO member bodies undertake to apply IEC, ISO and ISO/IEC publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any ISO/IEC publication and the corresponding national or regional publication should be clearly indicated in the latter.
- 6) ISO and IEC provide no marking procedure to indicate their approval and cannot be rendered responsible for any equipment declared to be in conformity with an ISO/IEC publication.
- 7) All users should ensure that they have the latest edition of this publication.
- 8) No liability shall attach to IEC or ISO or its directors, employees, servants or agents including individual experts and members of their technical committees and IEC or ISO member bodies for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication of, use of, or reliance upon, this ISO/IEC publication or any other IEC, ISO or ISO/IEC publications.
- 9) Attention is drawn to the normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.

IEC and ISO draw attention to the fact that it is claimed that compliance with this document may involve the use of patents as indicated below.

ISO and IEC take no position concerning the evidence, validity and scope of the putative patent rights. The holders of the putative patent rights have assured IEC and ISO that they are willing to negotiate free licences or licences under reasonable and non-discriminatory terms and conditions with applicants throughout the world. In this respect, the statements of the holders of the putative patent rights are registered with IEC and ISO.

Intel Corporation has informed IEC and ISO that it has patent applications or granted patents.

Information may be obtained from:

Intel Corporation  
Standards Licensing Department  
5200 NE Elam Young Parkway  
MS: JFS-98  
USA – Hillsboro, Oregon 97124

Microsoft Corporation has informed IEC and ISO that it has patent applications or granted patents as listed below:

6101499 / US; 6687755 / US; 6910068 / US; 7130895 / US; 6725281 / US; 7089307 / US; 7069312 / US;  
10/783 524 / US

Information may be obtained from:

Microsoft Corporation  
One Microsoft Way  
USA – Redmond WA 98052

Philips International B.V. has informed IEC and ISO that it has patent applications or granted patents.

Information may be obtained from:

Philips International B.V. – IP&S  
High Tech campus, building 44 3A21  
NL – 5656 Eindhoven

NXP B.V. (NL) has informed IEC and ISO that it has patent applications or granted patents.

Information may be obtained from:

NXP B.V. (NL)  
High Tech campus 60  
NL – 5656 AG Eindhoven

Matsushita Electric Industrial Co. Ltd. has informed IEC and ISO that it has patent applications or granted patents.

Information may be obtained from:

Matsushita Electric Industrial Co. Ltd.  
1-3-7 Shiomi, Chuoh-ku  
JP – Osaka 540-6139

Hewlett Packard Company has informed IEC and ISO that it has patent applications or granted patents as listed below:

5 956 487 / US; 6 170 007 / US; 6 139 177 / US; 6 529 936 / US; 6 470 339 / US; 6 571 388 / US; 6 205 466 / US

Information may be obtained from:

Hewlett Packard Company  
1501 Page Mill Road  
USA – Palo Alto, CA 94304

Samsung Electronics Co. Ltd. has informed IEC and ISO that it has patent applications or granted patents.

Information may be obtained from:

Digital Media Business, Samsung Electronics Co. Ltd.  
416 Maetan-3 Dong, Yeongtang-Gu,  
KR – Suwon City 443-742

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights other than those identified above. IEC and ISO shall not be held responsible for identifying any or all such patent rights.

ISO/IEC 29341-6-2 was prepared by UPnP Implementers Corporation and adopted, under the PAS procedure, by joint technical committee ISO/IEC JTC 1, *Information technology*, in parallel with its approval by national bodies of ISO and IEC.

The list of all currently available parts of the ISO/IEC 29341 series, under the general title *Universal plug and play (UPnP) architecture*, can be found on the IEC web site.

This International Standard has been approved by vote of the member bodies, and the voting results may be obtained from the address given on the second title page.

## ORIGINAL UPnP DOCUMENTS (informative)

Reference may be made in this document to original UPnP documents. These references are retained in order to maintain consistency between the specifications as published by ISO/IEC and by UPnP Implementers Corporation. The following table indicates the original UPnP document titles and the corresponding part of ISO/IEC 29341:

UPnP Document Title	ISO/IEC 29341 Part
UPnP Device Architecture 1.0	ISO/IEC 29341-1
UPnP Basic:1 Device	ISO/IEC 29341-2
UPnP AV Architecture:1	ISO/IEC 29341-3-1
UPnP MediaRenderer:1 Device	ISO/IEC 29341-3-2
UPnP MediaServer:1 Device	ISO/IEC 29341-3-3
UPnP AVTransport:1 Service	ISO/IEC 29341-3-10
UPnP ConnectionManager:1 Service	ISO/IEC 29341-3-11
UPnP ContentDirectory:1 Service	ISO/IEC 29341-3-12
UPnP RenderingControl:1 Service	ISO/IEC 29341-3-13
UPnP MediaRenderer:2 Device	ISO/IEC 29341-4-2
UPnP MediaServer:2 Device	ISO/IEC 29341-4-3
UPnP AV Datastructure Template:1	ISO/IEC 29341-4-4
UPnP AVTransport:2 Service	ISO/IEC 29341-4-10
UPnP ConnectionManager:2 Service	ISO/IEC 29341-4-11
UPnP ContentDirectory:2 Service	ISO/IEC 29341-4-12
UPnP RenderingControl:2 Service	ISO/IEC 29341-4-13
UPnP ScheduledRecording:1	ISO/IEC 29341-4-14
UPnP DigitalSecurityCamera:1 Device	ISO/IEC 29341-5-1
UPnP DigitalSecurityCameraMotionImage:1 Service	ISO/IEC 29341-5-10
UPnP DigitalSecurityCameraSettings:1 Service	ISO/IEC 29341-5-11
UPnP DigitalSecurityCameraStillImage:1 Service	ISO/IEC 29341-5-12
UPnP HVAC_System:1 Device	ISO/IEC 29341-6-1
UPnP HVAC_ZoneThermostat:1 Device	ISO/IEC 29341-6-2
UPnP ControlValve:1 Service	ISO/IEC 29341-6-10
UPnP HVAC_FanOperatingMode:1 Service	ISO/IEC 29341-6-11
UPnP FanSpeed:1 Service	ISO/IEC 29341-6-12
UPnP HouseStatus:1 Service	ISO/IEC 29341-6-13
UPnP HVAC_SetpointSchedule:1 Service	ISO/IEC 29341-6-14
UPnP TemperatureSensor:1 Service	ISO/IEC 29341-6-15
UPnP TemperatureSetpoint:1 Service	ISO/IEC 29341-6-16
UPnP HVAC_UserOperatingMode:1 Service	ISO/IEC 29341-6-17
UPnP BinaryLight:1 Device	ISO/IEC 29341-7-1
UPnP DimmableLight:1 Device	ISO/IEC 29341-7-2
UPnP Dimming:1 Service	ISO/IEC 29341-7-10
UPnP SwitchPower:1 Service	ISO/IEC 29341-7-11
UPnP InternetGatewayDevice:1 Device	ISO/IEC 29341-8-1
UPnP LANDevice:1 Device	ISO/IEC 29341-8-2
UPnP WANDevice:1 Device	ISO/IEC 29341-8-3
UPnP WANConnectionDevice:1 Device	ISO/IEC 29341-8-4
UPnP WLANAccessPointDevice:1 Device	ISO/IEC 29341-8-5
UPnP LANHostConfigManagement:1 Service	ISO/IEC 29341-8-10
UPnP Layer3Forwarding:1 Service	ISO/IEC 29341-8-11
UPnP LinkAuthentication:1 Service	ISO/IEC 29341-8-12
UPnP RadiusClient:1 Service	ISO/IEC 29341-8-13
UPnP WANCableLinkConfig:1 Service	ISO/IEC 29341-8-14
UPnP WANCommonInterfaceConfig:1 Service	ISO/IEC 29341-8-15
UPnP WANDSLLinkConfig:1 Service	ISO/IEC 29341-8-16
UPnP WANEthernetLinkConfig:1 Service	ISO/IEC 29341-8-17
UPnP WANIPConnection:1 Service	ISO/IEC 29341-8-18
UPnP WANPOTSLinkConfig:1 Service	ISO/IEC 29341-8-19
UPnP WANPPPPConnection:1 Service	ISO/IEC 29341-8-20
UPnP WLANConfiguration:1 Service	ISO/IEC 29341-8-21
UPnP Printer:1 Device	ISO/IEC 29341-9-1
UPnP Scanner:1.0 Device	ISO/IEC 29341-9-2
UPnP ExternalActivity:1 Service	ISO/IEC 29341-9-10
UPnP Feeder:1.0 Service	ISO/IEC 29341-9-11
UPnP PrintBasic:1 Service	ISO/IEC 29341-9-12
UPnP Scan:1 Service	ISO/IEC 29341-9-13
UPnP QoS Architecture:1.0	ISO/IEC 29341-10-1
UPnP QoSDevice:1 Service	ISO/IEC 29341-10-10
UPnP QoSManager:1 Service	ISO/IEC 29341-10-11
UPnP QoSPolicyHolder:1 Service	ISO/IEC 29341-10-12
UPnP QoS Architecture:2	ISO/IEC 29341-11-1
UPnP QOS v2 Schema Files	ISO/IEC 29341-11-2

<b>UPnP Document Title</b>	<b>ISO/IEC 29341 Part</b>
UPnP QosDevice:2 Service	ISO/IEC 29341-11-10
UPnP QosManager:2 Service	ISO/IEC 29341-11-11
UPnP QosPolicyHolder:2 Service	ISO/IEC 29341-11-12
UPnP RemoteUIClientDevice:1 Device	ISO/IEC 29341-12-1
UPnP RemoteUIServerDevice:1 Device	ISO/IEC 29341-12-2
UPnP RemoteUIClient:1 Service	ISO/IEC 29341-12-10
UPnP RemoteUIServer:1 Service	ISO/IEC 29341-12-11
UPnP DeviceSecurity:1 Service	ISO/IEC 29341-13-10
UPnP SecurityConsole:1 Service	ISO/IEC 29341-13-11




# 1. Overview and Scope

The HVAC\_ZoneThermostat is intended to be a sub device of the HVAC\_System device. Any number of HVAC\_ZoneThermostats may be included in the system device.

HVAC\_ZoneThermostat is a zone level controller for heating and/or cooling. It provides the following functionality:

- The ability to set or get zone level operating and fan modes.
- Temperature in the zone.
- Zone level Heating and/or cooling temperature setpoints.
- Optional fan speed control.
- Optional zone level daily schedule for events and heating and cooling setpoints.



Solid lines indicate interfaces exposed via UPnP

Dotted lines indicate interfaces and services not directly visible via UPnP

**Figure 1 HVAC\_ZoneThermostat:1 Functional Diagram**

## 2. Device Definitions

### 2.1. Device Type

The following device type identifies a device that is compliant with this template:

urn:schemas-upnp-org:device:**HVAC\_ZoneThermostat:1**

### 2.2. Device Model

Products that expose devices of the type urn:schemas-upnp-org:device:**HVAC\_ZoneThermostat:1** must implement minimum version numbers of all required embedded devices and services specified in the table below.

**Table 1: Device Requirements**

DeviceType	Root	Req. or Opt. <sup>1</sup>	ServiceType	Req. or Opt. <sup>1</sup>	Service ID <sup>2</sup>
HVAC_ZoneThermostat:1	Root	R			
			HVAC_UserOperatingMode:1	R	ZoneUserMode
			HVAC_FanOperatingMode:1	O	ZoneFanMode
			FanSpeed:1	O	ZoneFanSpeed
			ControlValve:1	O	HeatingValve
			ControlValve:1	O	CoolingValve
			ControlValve:1	O	AirDamper
			TemperatureSetpoint:1	This device is required to include either a heating or cooling setpoint or both	HeatingSetpoint
			TemperatureSetpoint:1	This device is required to include either a heating or cooling setpoint or both	CoolingSetpoint
			TemperatureSensor:1	O	ZoneTemperature
			HVAC_SetpointSchedule:1	O	ZoneSchedule
<i>Non-standard devices embedded by a UPnP vendor go here.</i>	<i>TBD</i>	<i>X</i>	<i>TBD</i>	<i>TBD</i>	<i>TBD</i>

<sup>1</sup> R = Required, O = Optional, X = Non-standard.

<sup>2</sup> Prefixed by urn:[upnp-org:serviceId](#): .

#### 2.2.1. Description of Device Requirements

The HVAC\_ZoneThermostat is intended to be a sub device of the HVAC\_System device. Any number of HVAC\_ZoneThermostats may be included in the system device. Each time a ZoneThermostat is added the System device must go bye-bye and then re-advertise its existence via normal UPnP protocols.

In the ZoneThermostat devices these services allow the user to select modes for zone operation. One zone can be set to cool while another can be set to heat. The system modes and the zone modes may be different.

At least one TemperatureSetpoint service must be present – heating or cooling. Both may be present for ZoneThermostats that support both heating and cooling.

### 2.2.2. Relationships Between Services

TemperatureSensor may be internally wired to a PID controller

Some user operating modes provide a TemperatureSetpoint variable. Example: EnergySavings mode typically implies an “above freezing” TemperatureSetpoint.

FanSpeed and ControlValves variables may be determined by internal PID, equipment and fan controllers.

## 2.3. Theory of Operation

A HVAC system includes all the heating and cooling equipment necessary to independently condition a whole house or a region of a house. Large homes may include several independent systems. Small homes may only have one system. Individual systems may be zoned.

A forced air system may typically include a furnace with heat exchangers and a fan or a blower, an air conditioning compressor unit, filters, duct work, temperature sensors, temperature setpoints, mode controls and in zoned systems electrically controllable valve or dampers.

Hydronic systems are usually zoned and may typically include a boiler, cooler, pumps, valves, radiators, temperature sensors, temperature setpoints and mode controls.

This device, HVAC\_ZoneThermostat, is a container for the HVAC control elements related to a particular zone. It is not necessarily a recognizable single physical device. All the elements are not necessarily exposed. This DCP is targeted at user control and does not expose lower level operational details.

The controls and interfaces for each zone may be contained in a single physical device or distributed among other devices. This DCP illustrates them in a single device called a HVAC\_ZoneThermostat. Other DCP's may use the same services but show them used in other containers.

### 3. XML Device Description

```
<?xml version="1.0"?>
<root xmlns="urn:schemas-upnp-org:device-1-0">
  <specVersion>
    <major>1</major>
    <minor>0</minor>
  </specVersion>
  <URLBase>base URL for all relative URLs</URLBase>
  <device>
    <deviceType>urn:schemas-upnp-
org:device:HVAC_ZoneThermostat:1</deviceType>
    <friendlyName>short user-friendly title</friendlyName>
    <manufacturer>manufacturer name</manufacturer>
    <manufacturerURL>URL to manufacturer site</manufacturerURL>
    <modelDescription>long user-friendly title</modelDescription>
    <modelName>model name</modelName>
    <modelName>model name</modelName>
    <modelNumber>model number</modelNumber>
    <modelURL>URL to model site</modelURL>
    <serialNumber>manufacturer's serial number</serialNumber>
    <UDN>uuid:UUID</UDN>
    <UPC>Universal Product Code</UPC>
    <iconList>
      <icon>
        <mimetype>image/format</mimetype>
        <width>horizontal pixels</width>
        <height>vertical pixels</height>
        <depth>color depth</depth>
        <url>URL to icon</url>
      </icon>
      XML to declare other icons, if any, go here
    </iconList>
    <serviceList>
      <service>
        <serviceType>urn:schemas-upnp-org:service:
HVAC_UserOperatingMode:1</serviceType>
        <serviceId>urn:upnp-org:serviceId:ZoneUserMode</serviceId>
        <SCPDURL>URL to service description</SCPDURL>
        <controlURL>URL for control</controlURL>
        <eventSubURL>URL for eventing</eventSubURL>
      </service>
    </serviceList>
    <service>
      <serviceType>urn:schemas-upnp-org:service:
HVAC_FanOperatingMode:1</serviceType>
      <serviceId>urn:upnp-org:serviceId:ZoneFanMode</serviceId>
      <SCPDURL>URL to service description</SCPDURL>
      <controlURL>URL for control</controlURL>
      <eventSubURL>URL for eventing</eventSubURL>
    </service>
    <service>
      <serviceType>urn:schemas-upnp-
org:service:ControlValve:1</serviceType>
      <serviceId>urn:upnp-org:serviceId:HeatingValve</serviceId>
      <SCPDURL>URL to service description</SCPDURL>
      <controlURL>URL for control</controlURL>
      <eventSubURL>URL for eventing</eventSubURL>
    </service>
    <service>
      <serviceType>urn:schemas-upnp-
org:service:ControlValve:1</serviceType>
      <serviceId>urn:upnp-org:serviceId:CoolingValve</serviceId>
```

```

        <SCPDURL>URL to service description</SCPDURL>
        <controlURL>URL for control</controlURL>
        <eventSubURL>URL for eventing</eventSubURL>
    </service>
</service>
    <serviceType>urn:schemas-upnp-
org:service:ControlValve:1</serviceType>
    <serviceId>urn:upnp-org:serviceId:AirDamper</serviceId>
    <SCPDURL>URL to service description</SCPDURL>
    <controlURL>URL for control</controlURL>
    <eventSubURL>URL for eventing</eventSubURL>
</service>
    <serviceType>urn:schemas-upnp-org:service:FanSpeed:1</serviceType>
    <serviceId>urn:upnp-org:serviceId:ZoneFanSpeed</serviceId>
    <SCPDURL>URL to service description</SCPDURL>
    <controlURL>URL for control</controlURL>
    <eventSubURL>URL for eventing</eventSubURL>
</service>
</service>
    <serviceType>urn:schemas-upnp-org:service:
TemperatureSetpoint:1</serviceType>
    <serviceId>urn:upnp-org:serviceId:HeatingSetpoint</serviceId>
    <SCPDURL>URL to service description</SCPDURL>
    <controlURL>URL for control</controlURL>
    <eventSubURL>URL for eventing</eventSubURL>
</service>
</service>
    <serviceType>urn:schemas-upnp-org:service:
TemperatureSetpoint:1</serviceType>
    <serviceId>urn:upnp-org:serviceId:CoolingSetpoint</serviceId>
    <SCPDURL>URL to service description</SCPDURL>
    <controlURL>URL for control</controlURL>
    <eventSubURL>URL for eventing</eventSubURL>
</service>
</service>
    <serviceType>urn:schemas-upnp-org:service:
TemperatureSensor:1</serviceType>
    <serviceId>urn:upnp-org:serviceId:ZoneTemperature</serviceId>
    <SCPDURL>URL to service description</SCPDURL>
    <controlURL>URL for control</controlURL>
    <eventSubURL>URL for eventing</eventSubURL>
</service>
</service>
    <serviceType>urn:schemas-upnp-org:service:HVAC SetpointSchedule:1
</serviceType>
    <serviceId>urn:upnp-org:serviceId:ZoneSchedule</serviceId>
    <SCPDURL>URL to service description</SCPDURL>
    <controlURL>URL for control</controlURL>
    <eventSubURL>URL for eventing</eventSubURL>
</service>
</service>

    <Declarations for other services defined by a UPnP Forum working
    committee (if any) go here
    <Declarations for other services added by UPnP vendor (if any) go here
</serviceList>
<deviceList>
    <Description of embedded devices defined by a UPnP Forum working
    committee (if any) go here
    <Description of embedded devices added by UPnP vendor (if any) go here
</deviceList>
    <presentationURL>URL for presentation</presentationURL>
</device>
</root>

```

## 4. Test

Testing of the UPnP functions Addressing, Discovery, Description, Control (Syntax) and Eventing are performed by the UPnP Test Tool v1.1 based on the following documents:

- UPnP Device Architecture v1.0
- The Device Definitions in chapter 2 of this document
- The XML Device Description in chapter 3 of this document
- The UPnP Test Tool device template test file: *HVAC\_ZoneThermostat1.xml*
- The template documents for the services referenced by this device, together with their respective UPnP Test Tool service template test files.



INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

3, rue de Varembé  
PO Box 131  
CH-1211 Geneva 20  
Switzerland

Tel: + 41 22 919 02 11  
Fax: + 41 22 919 03 00  
[info@iec.ch](mailto:info@iec.ch)  
[www.iec.ch](http://www.iec.ch)